

## Declaration of Conformity

### We

ÖNMETAL DÖKÜM SANAYİ TİC. LTD. ŞTİ. İSTANBUL / TURKEY

Declare under our responsibility that the product

**Cast Iron Solid Fuel Fired Boilers**

TYPES: THOR - 03, THOR - 04, THOR - 05, THOR - 06, THOR - 07, THOR - 08, THOR - 10

Max. allowable pressure: PS : 4 bar	Volume ( lt ):	
Allowable min. / max.: 50 °C / 90 °C	THOR - 03 : 14,2	THOR - 07 : 29,0
Test pressure: 5,2 bar	THOR - 04 : 17,9	THOR - 08 : 32,7
Test fluid: Water	THOR - 05 : 21,6	THOR - 10 : 40,4
QS System: SZUTEST	THOR - 06 : 25,3	

Is in conformity with the requirements of the directives

Directive	Standard	Remark
97/23/EC Pressure Equipment Directive	EN 303-5	TÜV Industrie Service GmbH TÜV SÜD Group Cert. Report No.  Module B
97/23/EC Pressure Equipment Directive	EN 303-5	TÜV Industrie Service GmbH TÜV SÜD Group Cert. Report No.  Module C1

ÖNMETAL DÖKÜM  
SAN. TIC. LTD. ŞTİ.