



Description	OFF	ON
SW1 Gas set	MTN	LPG (G31)
SW2 HTG temperature range	35°/78°	20°/45°
SW3 HTG time delay	3 min	0 min
SW4 (NOT USED) DHW OFF temperature	Fix OFF = 75° ON = 60°	Set point OFF=set +3° ON=set +2°
SW5 Pump functions	Standard	Unable
SW6 (NOT USED) Auto filling in	Not able	Able

SPARE = all switches OFF