

Verification of Conformity

EMC Directive 2004/108/EC

Certification No.: TOS14122667

Test Report Ref. No.: 68.5.52.14.0608.02

Holder Of Certificate: **Salus Limited**
9/F, Tower One, Lippo Centre, 89 Queensway, HongKong

Manufacturer: **1.Computime Electronics (Shenzhen) Company Limited**
2.Asia Electronic Dongguan

Product: **Wired Wiring Center , Wired Wiring Center extension**

Model No.: **SAL6HI1, KL08NSB, SAL6HJ1, KL04NSB**

Parameters: **230 V ac, 50 Hz,**
Total Load Max.: 5A;
Pump/Boiler Relay Load Max.: 3A for SAL6HI1;
Total Load Max.: 3A for SAL6HJ1

Standards: **EN 60730-2-9:2010;**
EN 60730-1:2011

The statement is based on a single evaluation of one sample of above mentioned products. It does not imply an assessment of the whole production and does not permit the use of the test lab. Logo.

The manufacturer should ensure that all products in series production are in conformity with the product sample detailed in this report. The applicant should hold the whole technical report at disposal of the competent all the right.

Issued Date:2014-12-10



Colin Liang
Chief Director



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Verification of Conformity

LVD Directive 2006/95/EC

Certification No.: TOS14122666

Test Report Ref. No.: 68.5.51.14.0607.02

Holder Of Certificate: Salus Limited
9/F, Tower One, Lippo Centre, 89 Queensway, Hong Kong

Manufacturer : 1.Computime Electronics (Shenzhen) Company Limited
2.Asia Electronic Dongguan

Product: Wired Wiring Center , Wired Wiring Center extension

Model No.: SAL6HI1, KL08NSB, SAL6HJ1, KL04NSB

Parameters: 230 V ac, 50 Hz,
Total Load Max.: 5A;
Pump/Boiler Relay Load Max.: 3A for SAL6HI1;
Total Load Max.: 3A for SAL6HJ1

Standards: EN 60730-2-9:2010;
EN 60730-1:2011

The statement is based on a single evaluation of one sample of above mentioned products. It does not imply an assessment of the whole production and does not permit the use of the test lab. Logo.

The manufacturer should ensure that all products in series production are in conformity with the product sample detailed in this report. The applicant should hold the whole technical report at disposal of the competent authorities.

Issued Date:2014-12-10


Colin Liang
Chief Director



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.