

PUCIHAR

PUCIHAR-P d.o.o.
Veliki Vrh 7
1293 Šmarje – Sap
SLOVENIJA

Tel.: + 386 (0)1 780 41 83
Fax: + 386 (0)1 780 41 84
gsm: + 386 (0)41 618 841

E-mail: info@pucihar.com

Šmarje Sap, 15.6.2010

Declaration of conformity

Represented by the undersigned, declare that Brackets for panel radiators *PUCIHAR-P* with selling label:

002 – Bracket C, 003 – Bracket H, 004 – Bracket HK1, 009 – Bracket CA, 010 Bracket CAK, 017 – Bracket K, 018 – Bracket F, 019 – Bracket FC, 020 Bracket D, 021 – Bracket A1, 022 – Bracket LN, 027 – Bracket DX, 031 – Bracket L1, 032 – Bracket L2, 050 – Bracket T, 051 – Bracket TH

meets all the requirements of Slovenian and European standards.

Brackets are designed for mounting of panel radiators for heating residential, commercial and other spaces under the central heating.

Tests of load capacity and deflection are made in:

Univerza v Ljubljani
Fakulteta za strojništvo



LANEM
Fakulteta za strojništvo
Aškerčeva 6
1000 Ljubljana

Brackets are designed in accordance with standard:

SIST EN 845-1: 2004+A1:2008 – Specifications for ancillary components
for masonry – Part 1: Ties, tension straps, hangers and brackets

Tested in accordance with standard:


SIST EN 846-10

COBBIS number of report:

COBBIS.SI-ID 11410459

Primož Pucihar


PUCIHAR-P d.o.o.
VELIKI VRH 7
ŠMARJE-SAP



PUCIHAR

PUCIHAR-P d.o.o.
Veliki Vrh 7
1293 Šmarje – Sap
SLOVENIJA

Tel.: + 386 (0)1 780 41 83
Fax: + 386 (0)1 780 41 84
gsm: + 386 (0)41 618 841

E-mail: info@pucihar.com

Šmarje Sap, 15.6.2010

Declaration of Conformity

Represented by the undersigned, declare that

003 Bracket H

With selling label:

H-300, H-400, H-500, H-600, H-700, H-800, H-900

Meets all the requirements of standard SIST EN 845-1:2004+A1:2008

Description of product: Radiator bracket H, bracket for fixing of panel radiators

Material of brackets: ISO 1461 zinc coated steel
Polypopilene PPR 722

Dimensions: L=45mm
t=1,5mm

Load capacity: 1500N

Deflection under load: 0,95mm

Harmonised standard used:

SIST EN 845-1: 2004+A1:2008 – Specifications for ancillary components for masonry – Part 1: Ties, tension straps, hangers and brackets

Tested in accordance with standard:

SIST EN 846-10

Univerza v Ljubljani
Fakulteta za strojništvo



Testing laboratory:


LANEM
Laboratorij za nelinearno mehaniko
Fakulteta za strojništvo
Aškerčeva 6
SI-1000 Ljubljana

COBBIS number of report: COBBIS.SI-ID 11410459

Primož Pucihar

 PUCIHAR-P d.o.o.
VELIKI VRH 7
SI-ŠMARJE-SAP





PUCIHAR

PUCIHAR-P d.o.o.
Veliki Vrh 7
1293 Šmarje – Sap
SLOVENIJA

Tel.: + 386 (0)1 780 41 83
Fax: + 386 (0)1 780 41 84
gsm: + 386 (0)41 618 841

E-mail: info@pucihar.com

Šmarje Sap, 15.6.2010

Declaration of Conformity

Represented by the undersigned, declare that

002 Bracket C

With selling label:

C-300, C-400, C-500, C-600, C-700, C-800, C-900

Meets all the requirements of standard SIST EN 845-1:2004+A1:2008

Description of product: Radiator bracket C, bracket for fixing of panel radiators without welded hangers on the rear side.

*Material of brackets: ISO 1461 zinc coated steel
Polypopilene PPR 722*

*Dimensions: L=32mm
t=1,5mm*

Load capacity: 1500N

Deflection under load: 1,05mm

Harmonised standard used:

SIST EN 845-1: 2004+A1:2008 – Specifications for ancillary components for masonry – Part 1: Ties, tension straps, hangers and brackets

Tested in accordance with standard:

SIST EN 846-10

Testing laboratory:

*Univerza v Ljubljani
Fakulteta za strojništvo*



*LANEM
Laboratorij za nelinearno mehaniko
Fakulteta za strojništvo
Aškerčeva 6
SI-1000 Ljubljana*

COBBIS number of report: COBBIS.SI-ID 11410459

Primož Pucihar



PUCIHAR-P d.o.o.
VELIKI VRH 7
SI-ŠMARJE-SAP