

Destinatar

Firma
Referinta
Adresa
Phone
Fax
E-mail

Expeditor

Cod articol :

103040020

Articol:

FEKA VS 550 T - NA

Date pompa

Free passage : 50 mm
Presiune nominala:
Temperatura min. fluid 0
Temperatura max. fluid 50 °C
Temperatura max. ambianta 40 °C

Date de functionare cerute

Debit :
Inaltime de pompare :
Fluid pompat : Apă
Temperatura fluid: 20 °C
Densitate 998.3 kg/m³
Vasozitate cinematica: 1.005 mm²/s
Presiune de vapori: 2.34 kPa



Date disponibile:

Debit :
Inaltime de pompare :

Materiale

Corp pompa AISI 304
Rotor AISI 304
Arbore motor AISI 316
Disc suport etansare AISI 304
Carcasa motorului AISI 304
Calota de protectie AISI 304
Etansare mec. completa pe partea pozitiva Silicon carbide/Silicon carbide

Curve tolerance according to ISO 9906



Date motor

Marca : DAB
Putere nominala P2: 0.55 kW
Viteza nominala: 2800 1/min
Tensiune nominala : 3~ 400 V
Curent nominal : 1.64 A
Grad de protectie: IP 68

50 Hz

Masa 16.3 kg

Dimensiuni de gabarit mm

A	203				
B	170				
D	172				
DNM	2" F				
H	492				
H1	98				

Racorduri pompa:

Partea cu aspiratia: /
Partea cu refularea: 2 " F / --


Destinatar

Expedito

Firma
Referinta
Adresa
Phone
Fax
E-mail

FEKA VS 550 T - NA

Curve tolerance according to ISO 9906



Date disponibile:

Partea cu aspiratia:

Partea cu refularea:

2" F
--

Debit :

Înaltime de pompare :

Viteza nominala:

2800 1/min

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_IT

OWNER_

ISSUE_DATE

03/25/2021



DESEN DIMENSIONAL

03/25/2021

Pagina 3 / 3


DAB PUMPS S.p.A.
Via Marco Polo, 14 - 35035 Mestrino (PD), Italy
Tel. +39 049 5125000 - Fax +39 049 5125950
www.dabpumps.com

Destinatar

Expeditor

Firma
Referinta
Adresa
Phone
Fax
E-mail

FEKA VS 550 T - NA



Dimensiuni in mm

Racorduri pompa:

1	A	203							
2	B	170							
3	D	172							Aspiratie
4	DNM	2" F							
5	H	492							Refulare
6	H1	98							2" F
7									--
8									
9									
10									
11									
12									

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_IC

OWNER_

ISSUE_DATE

03/25/2021