

Destinatar

Firma
Referinta
Adresa
Phone
Fax
E-mail

Expeditor

Cod articol :

60191275

Articol:

FEKA FXC 25.22 T-NA

Tip de instalatie:

Wet - Pump only

Date pompa

Free passage : 50 mm
Max. immersion depth : 20 m
Temperatura min. fluid 0 °C
Temperatura max. fluid 50 °C

Date de functionare cerute

Debit :

Inaltime de pompare :

Fluid pompat : Apă

Temperatura fluid: 20 °C

Densitate 998.3 kg/m³

Vasozitate cinematica: 1.005 mm²/s

Presiune de vapori: 2.34 kPa

Date disponibile:



Debit :

Inaltime de pompare :

Materiale

Maner Fonta EN GJL 200
Pump body / motor Fonta EN GJL 200
Rotor Cast iron (EN GJL 250)
Etansare mec. completa pe partea pozitiva SIC/SIC-C
Etansare mec. completa pe partea negativa SIC/Carbon
Garnitura OR NBR
Arbore motor Otel inox AISI 304

Curve tolerance according to ISO 9906



Date motor

Marca : DAB
Putere nominala P2: 2.3 kW
Viteza nominala: 2870 1/min
Tensiune nominala : 3~ 400 V
Curent nominal : 5 A
Grad de protectie: IP 68

Masa 44 kg

Accessory weight :

Dimensiuni de gabarit mm

A	322				
B	218				
DN1	65				
H	496				
H1	103				

Racorduri pompa:

Partea cu aspiratia: --
Partea cu refularea: DN 65 PN10/6


Destinatar

Expedito

Firma
Referinta
Adresa
Phone
Fax
E-mail

FEKA FXC 25.22 T-NA

Curve tolerance according to ISO 9906



Partea cu aspiratia:

Partea cu refularea:

DN 65 PN10/6

Debit :

Înaltime de pompare :

Viteza nominala:

2870 1/min

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_ID

OWNER_

ISSUE_DATE



DESEN DIMENSIONAL

01/19/2022

Pagina 3 / 3



DAB PUMPS S.p.A.
Via Marco Polo, 14 - 35035 Mestrino (PD), Italy
Tel. +39 049 5125000 - Fax +39 049 5125950
www.dabpumps.com

Destinatar

Expeditor

Firma
Referinta
Adresa
Phone
Fax
E-mail

FEKA FXC 25.22 T-NA



Dimensiuni in mm

Racorduri pompa:

1	A	322					
2	B	218					
3	DN1	65					Aspiratie
4	H	496					
5	H1	103					
6							
7							Refulare
8							DN 65 PN10/6
9							--
10							
11							
12							

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_IC

OWNER_

ISSUE_DATE