

VERIFICATION OF COMPLIANCE

No.: LVD GZES1711018947HS
Applicant: GD Midea Air-conditioning Equipment Co., Ltd.
Lingang Road, Beijiao, Shunde, Foshan, 528311, Guangdong,
China
Manufacturer: Same as applicant
Product Name: **Air Conditioner**
Product Description: **Split-Type Air-Conditioner**
Model No.: See page 2
Trade Mark: **Midea**
Rating: See page 2
Protection against Electric Shock: Class I
Degree of Protection: IP24 for outdoor unit
Additional Information: Refrigerant: R32
This verification replaces LVD GZES1710016921HS

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60335-2-40: 2003 + A11: 2004 + A12: 2005 + A1:
2006 + A2: 2009 + A13: 2012
EN 60335-1: 2012 + A11: 2014
EN 62233: 2008

as shown in the

Test Report Number(s): GZES160400371005

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant harmonized standards under the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.


Senior Technical Manager
SGS-CSTC



2018-01-05

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.:

LVD GZES1711018947HS

Other information added:

Rating:

Indoor unit	Outdoor unit	Rating
MCD-36HRFN8-QRD0, MCD-36HRFNX-QRD0	MOD30U-36HFN8-QRD0	220 V – 240 V; 50 Hz; indoor unit: 170 W; 1,4 A; outdoor unit: 4700 W; 21,5 A
MUE-36HRFN8-QRD0, MUE-36HRFNX-QRD0		
MTI-36HRFN8-QRD0, MTI-36HRFNX-QRD0		220 V – 240 V; 50 Hz; indoor unit: 210 W; 1,6 A; outdoor unit: 4700 W; 21,5 A



David Guo
Senior Technical Manager
SGS-CSTC



2018-01-05

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)