



CONFORMITY DECLARATION ABOUT OUR BOLLY ST

The Underwriter "Cordivari S.r.l.", declares that its production of Bolly ST 1 and 2 is manufactured in accordance with Uni En 12897:2006 standard rule.

They are manufactured in Carbon Steel S 235 JR G2 UNI EN 10025, and internally coated with Polywarm suitable for drinkable water according D.M. 174 of 06/04/04.

All tanks are subject to Hydraulic Proof Test at 1.22 times the max working pressure of 10 bar for capacity up to 800lt. 8 bar for capacities of 1000lt and 1500lt

They can be equipped with one or two fix coils suitable for working with hot water at 12 bar pressure and at a max of 110 °C.

The tanks are insulated with hard polyurethane foam, thickness 50 mm and thermal conductivity 0,023 W/mK for capacities up to 500lt.

For capacities > 500 lt 100mm soft polyurethane foam with thermal conductivity 0,035W/mk.

Quality Manager

Mr. Marini Fabrizio

A handwritten signature in black ink, appearing to read 'Fabrizio Marini', written over the printed name.