



Number	KIP-15775/G	Scope	Regulation (EU) 2016/426
Issue date	16-05-2018	Module	B
Expire date	15-05-2028		
PIN	0476CQ1150	Report	150301150/4
Replaces	—	Page	1 of 1

EU TYPE-EXAMINATION CERTIFICATE

Kiwa Cermet Italia declares that the products type:

Condensing gas-fired air heaters

Trade mark: **TECNOCLIMA**

Models: PMX 30, PMX 40, PMX 50, PMX 60, PMX 90, PMX 120, CMX 30, CMX 40, CMX 50, CMX 60, CMX 90, CMX 120, SMX 30, SMX 40, SMX 50, SMX 60, SMX 90, SMX 120, CMX 30/K, CMX 40/K, CMX 50/K, CMX 60/K, CMX 90/K, CMX 120/K

Placed on the market by: **TECNOCLIMA S.p.A.**
Viale Industria 19, 38057 Pergine Valsugana (TN)
Italy

meet the essential requirements as described in the **Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

Appliance type: B₂₃, B_{23P}, C₁₃, C₃₃, C₆₃

Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Related to the following gas groups

Group	mbar
E	20
H	20;25
L	25

Group	mbar
LL	20
P	30; 37; 50
Esi	20/25

Group	mbar
E(S)	20
Er	20/25
E(R)	20

The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

The assessment test have been performed using the following standards as guidelines:

EN 1020:2009, EN 1196:2011

The validity of this certificate can be verified on request at the following e-mail address: info@kiwa.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Chief Operating Officer
Giampiero Belcredi



SGQ N° 007A
SGA N° 010D
PRD N° 069B
FSM N° 004I
PRS N° 089C

