

| | |
|--|--|
| TEST REPORT IEC 60335-2-40 Safety of household and similar electrical appliances Part 2-40: Particular requirements for electrical heat pumps, air conditioners and dehumidifiers | |
| Report Number | 64.111.13.00382.13 Rev.00 |
| Date of issue | 2018-06-20 |
| Total number of pages | 190 |
| Applicant's name | GD Midea Heating & Ventilating Equipment Co., Ltd. |
| Address | Penglai Industry Road, Beijiao, Shunde, 528311 Foshan, Guangdong, PEOPLE'S REPUBLIC OF CHINA. |
| Test specification: | |
| Standard | IEC 60335-2-40:2002 (Fourth Edition) + A1:2005 (incl. Corr.1:2006) + A2:2005 in conjunction with IEC 60335-1:2010 (Fifth Edition) |
| Test procedure | CE-LVD and CE-MD |
| Non-standard test method | N/A |
| Test Report Form No. | IEC60335_2_40J |
| Test Report Form(s) Originator | VDE |
| Master TRF | Dated 2014-06 |
| Copyright © 2014 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved. | |
| This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. | |
| If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. | |
| This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02. | |
| General disclaimer: | |
| The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report. | |

| | | |
|--|---|---|
| Test item description | | Multi-split type air conditioner (indoor unit) |
| Trade Mark | | Midea, MDV |
| Manufacturer | | Same as applicant |
| Model/Type reference | | MI-36DL/DHN1-C, MI-45DL/DHN1-C etc. (for further models can refer to attachment No.4) |
| Ratings | | 220-240V ~, 50Hz, Class I, IP20 for SMK-D140/MN1, IPX0 for other models, for other ratings can refer to attachment No.4. |
| Testing procedure and testing location: | | |
| <input checked="" type="checkbox"/> | Testing Laboratory: | TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch |
| Testing location/ address | | Location 1: 5F, Communication Building, 163 Pingyun Rd, Huangpu Ave. West, Guangzhou 510656, P. R. China Location 2: B1 Floor, No. 3 Chuangqi Building, TusPark, 63 Chuangqi Road, Shilou Town, Panyu District, Guangzhou 511447, P.R. China |
| <input type="checkbox"/> | Associated CB Testing Laboratory: | |
| Testing location/ address | | -- |
| Tested by (name + signature) | | Duke Yang  |
| Approved by (name + signature) | | Sam Yang  |
| <input type="checkbox"/> | Testing procedure: TMP/CTF Stage 1: | |
| Testing location/ address | | N/A |
| Tested by (name + signature) | | N/A |
| Approved by (name + signature) | | N/A |
| <input type="checkbox"/> | Testing procedure: WMT/CTF Stage 2: | |
| Testing location/ address | | N/A |
| Tested by (name + signature) | | N/A |
| Witnessed by (name + signature) | | N/A |
| Approved by (name + signature) | | N/A |
| <input type="checkbox"/> | Testing procedure: SMT/CTF Stage 3 or 4: | |
| Testing location/ address | | N/A |
| Tested by (name + signature) | | N/A |
| Witnessed by (name + signature) | | N/A |
| Approved by (name + signature) | | N/A |
| Supervised by (name + signature) | | N/A |



List of Attachments (including a total number of pages in each attachment):

- a) Attachment No.1: 2 pages of report for EN 60335-1:2012/A11:2014.
- b) Attachment No.2: 2 pages of report for EN 60335-1:2012/A13:2017.
- c) Attachment No.3: 17 pages of report DIFFERENCES for EN 60335-2-40:2003 (incl. Corr.:2006) + A11:2004 + A12:2005 + A1:2006 + A2:2009 + A13:2012 and EN 60335-1:2012.
- d) Attachment No.4: 17 pages of model list.
- e) Attachment No.5: 109 pages of rating labels.

Summary of testing:

Tests performed (name of test and test clause):

1. EN 60335-1:2012 + A11:2014 + A13:2017, EN 60335-2-40:2003 + A11:2004 + A12:2005 + A1:2006 + A2:2009 + A13:2012, EN 62233:2008.
2. In part 1 of original report 64.111.13.00382.01 Rev.00, the representation models were selected for tests.
3. In part 1 of original report 64.111.13.00382.02 Rev.00, the additional tests of clause 8, 10, 11,13, 16, 19, 25, 27, 29, 30 and 31 were carried out on models MDV-D36Q1/N1-D, MDV-D71G/N1Y-11D5, MDV-D45G/N1Y-11D5, MDV-D36G/N1Y-11D5 and MDV-D22G/N1Y-11D5.
4. In part 1 of original report 64.111.13.00382.03 Rev.00, the additional tests of clause 8, 10, 11,13, 16, 19, 25, 27, 29, 30 and 31 were carried out on models MDV-DxQ4/N1-E(x=140,90, 80, 71,56), MDV-DxT2/N1-DA5(x=71, 56) and MDV-DxT3/N1-C(x=71, 56, 36).
5. In original report 64.111.13.00382.04 Rev.00, additional test of clause 7, 8, 10, 11, 13, 15, 16, 17, 19, 25, 27, 29, 30 and 31 were carried out on models MI-36Q4/DHN1-D, MI-80Q4/DHN1-D, MI-112Q4/DHN1-D, MI-140Q4/DHN1-D, MI-15G/DHN1-S, MI-56G/DHN1-S, MI-90G/DHN1-R3, MI-28Q4/DHN1-A3 and MI-45Q4/DHN1-A3 as representative.
6. In original report 64.111.13.00382.04 Rev.01 is for adding alternative fan motor and main control board based on issued models, the additional test of clause 10, 11, 13, 19, 24, 27, 29 and annex EE were carried out on models MDV-D80T2/N1-BA5 MDV-D56T2/N1-DA5, MDV-D90T1/N1-B and MDV-D160T1/N1-B as representative.
7. In original report 64.111.13.00382.05 Rev.00 is for adding new models, the full test and construction checking were carried out on models MI-36DL/DHN1-C, MI-71DL/DHN1-C, MI-90DL/DHN1-C, MI-140DL/DHN1-C, MI-56T2/DHN1-DA5, MI-71T2/DHN1-DA5, MI-90T2/DHN1-BA5, MI-112T2/DHN1-BA5, MI-140T2/DHN1-BA5, MI-45Z/DHN1-F3B, MI-56Z/DHN1-F3B and MI-80Z/DHN1-F3B as

Testing location:

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

Location 1: 5F, Communication Building, 163 Pingyun Rd, Huangpu Ave. West, Guangzhou 510656, P. R. China

Location 2: B1 Floor, No. 3 Chuangqi Building, TusPark, 63 Chuangqi Road, Shilou Town, Panyu District, Guangzhou 511447, P.R. China

For report 64.111.13.00382.12 Rev.00:
Clause 10, 11, 13 and 19 on Location 2
Other test on location 1.

For report 64.111.13.00382.12 Rev.01:
Clause 10, 11, 13 and 19 on Location 2
Other test on location 1.

For report 64.111.13.00382.13 Rev.00:
5F, Communication Building, 163 Pingyun Rd, Huangpu Ave. West, Guangzhou 510656, P. R. China

| | |
|---|--|
| <p>representative.</p> | |
| <p>8. The report 64.111.13.00382.06 Rev.00 is for upgrading standard and adding new models based on report 64.111.13.00382.05Rev.00, the test of clauses 7, 8, 10, 11, 13, 15, 17, 19, 20, 23, 24, 25, 27, 29, 30, annex EE, EMF and construction checking were carried out on models MDV-D56Q1/N1-D, MDV-D71Q1/N1-D, MI-36G/N1-S, MI-56G/N1-S, MI-56Q4/N1-E, MI-71Q4/N1-E, MI-80Q4/N1-E, MI-90Q4/N1-E, MI-140Q4/N1-E, MI-36T2/N1-EA5, MI-56T2/N1-EA5, MI-71T2/N1-EA5, MI-90T2/N1-EA5, MI-112T2/N1-EA5, MI-140T2/N1-EA5, MI-28Q4/N1-A3 and MI-45Q4/N1-A3 as representative.</p> <p>9. The report 64.111.13.00382.07 Rev.00 is for adding new models based on report 64.111.13.00382.06 Rev.00, the test of clauses 7, 8, 10, 11, 13, 15, 17, 19, 20, 23, 24, 25, 27, 29, 30, annex EE, EMF and construction checking were carried out on models MI-80T1/DHN1-B, MI-112T1/DHN1-B, MI-160T1/DHN1-B, MI-280T1/DHN1-B, MI-140T1/DHN1-FA and MI-280T1/DHN1-FA as representative.</p> <p>10. The report 64.111.13.00382.08 Rev.00 is for adding new models based on report 64.111.13.00382.07 Rev.00, the test of clauses 7, 8, 10, 11, 13, 15, 17, 19, 20, 23, 25, 27, 29, annex EE, EMF and construction checking were carried out on models MI-28G/DHN1-M, MI-56G/DHN1-M and MI-90G/DHN1-M as representative.</p> <p>11. The report 64.111.13.00382.09 Rev.00 is for adding new models based on report 64.111.13.00382.08 Rev.00, all tests were carried on models MI-28T2/DHN1-EA5, MI-90T2/DHN1-EA5 and MI-140T2/DHN1-EA5, and construction check on other models.</p> <p>12. The report 64.111.13.00382.09 Rev.01 is for adding alternative fan motor based on report 64.111.13.00382.09 Rev.00, additional test of clause 10, 11, 13, 19.2 were carried out on model MDV-D36T2/N1-DA5, MDV-D56T2/N1-DA5, MDV-D71T2/N1-DA5 independently.</p> <p>13. For test report 64.111.13.00382.10 Rev.00, full tests were conducted on new model SMK-D140/MN1.</p> <p>14. For test report 64.111.13.00382.10 Rev.01, tests of clause 17 and 30 were conducted on alternative transformer EI28(8+8)4/P4-3.93L1.</p> <p>15. For test report 64.111.13.00382.11 Rev.00, full tests were conducted on new model MI2-36T2DN1, MI2-56T2DN1, MI2-71T2DN1, MI2-112T2DN1, MI2-140T2DN1, MI2-36Q1DN1,</p> | |

| | |
|--|--|
| <p>MI2-71Q1DN1, MI2-45Q2DN1, MI2-71Q2DN1, MI2-80Q4DN1, MI2-140Q4DN1, MI2-45Q4CDN1, MI2-36DLDN1, MI2-90DLDN1, MI2-140DLDN1, MI2-45F4DN1, MI2-80F4DN1, MI2-80F5DN1, MI2-112T1DN1, MI2-160T1DN1, MI2-280T1DN1, MI2-140FADN1, MI2-280FADN1.</p> <p>16. For test report 64.111.13.00382.12 Rev.00, full tests were conducted on models MI2-28GDN1, MI2-56GDN1, MI2-90GDN1, MI2-28ZDN1 and MI2-45ZDN1 and clause 10, 11, 13, 19 on model MI2-80T1DN1.</p> <p>17. For test report 64.111.13.00382.12 Rev.01, clause 10, 11, 13, 19.2 on models MDV-D36T2/N1-DA5, MDV-D56T2/N1-DA5, MDV-D71T2/N1-DA5.</p> <p>18. For test report 64.111.13.00382.13 Rev.00, after review, clause 30 is carried on alternative PCB material, terminal block, varistor samples</p> | |
|--|--|

Summary of compliance with National Differences:

List of countries addressed:

The product fulfils the requirements of EN 60335-1:2012 + A11:2014 + A13:2017, EN 60335-2-40:2003 + A11:2004 + A12:2005 + A1:2006 + A2:2009 + A13:2012, EN 62233:2008.

Copy of marking plate:

See attachment No.5 for details.

Remark:

1. The height of CE marking shall be higher than 5mm and the height of WEEE marking shall be higher than 7mm.
2. The rating labels with trademark MDV is the same as above rating labels with trademark Midea except for the trademark is different.
3. The indoor units must be placed on the market together with the outdoor unit of multi-split type air conditioner, both of manufacturer's name and address are affixed on the outdoor unit.
4. According to the EU directives which have been aligned with EU NLF (new legislative framework), both of manufacturer and importer's name and address shall be affixed on the product or, where that is not possible, on its packaging or in a document accompanying the product before the product is placed on the EU market.

| | |
|---|--------------------|
| Test item particulars | : |
| Classification of installation and use | : Fixed appliances |
| Supply Connection | : Fixed wiring |
| | : |
| Possible test case verdicts: | |
| - test case does not apply to the test object..... | : N/A |
| - test object does meet the requirement | : P (Pass) |
| - test object does not meet the requirement..... | : F (Fail) |
| Testing | : |

| | |
|---|---|
| Date of receipt of test item | 2011-10-20, 2012-07-28, 2012-10-08, 2012-11-29, 2013-01-20, 2013-05-20, 2014-01-13, 2014-06-15, 2014-07-02, 2014-09-04, 2014-12-04, 2015-06-08, 2016-07-15, 2016-11-10, 2017-10-23, 2017-09-01, 2018-03-02, 2018-04-23, 2018-06-06 |
| Date (s) of performance of tests..... | 2011-10-20 to 2011-12-12, 2012-05-20 to 2012-07-24, 2012-07-20 to 2012-09-07, 2012-10-08 to 2012-11-13, 2012-11-29 to 2013-01-15, 2013-01-20 to 2013-03-22, 2013-05-20 to 2013-07-22, 2014-01-13 to 2014-03-24, 2014-06-15 to 2014-07-24, 2014-07-02 to 2014-07-30, 2014-09-05 to 2014-09-30, 2015-03-01 to 2015-03-31, 2015-09-01 to 2015-10-15, 2016-07-15 to 2016-10-24, 2016-11-15 to 2016-12-01, 2017-10-23 to 2017-11-07, 2017-12-06 to 2017-12-12, 2017-09-02 to 2017-11-27, 2018-03-05 to 2018-04-28, 2018-4-24 to 2018-05-28, 2018-06-07 to 2018-06-15 |
| General remarks: "(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report. Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator. This TRF includes an <u>appendix EMF</u> containing the IEC/EN 62233 requirements (see below). IEC 62233:2005 (1. Edition) EN 62233:2008 (incl. Corr.1:2008) | |
| Manufacturer's Declaration per sub-clause 4.2.5 of IECCE 02: The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided : <div style="float: right; margin-left: 20px;"> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable </div> | |
| When differences exist; they shall be identified in the General product information section. | |
| Name and address of factory (ies)..... : GD Midea Heating & Ventilating Equipment Co., Ltd. Penglai Industry Road, Beijiao, Shunde, 528311 Foshan, Guangdong, PEOPLE'S REPUBLIC OF CHINA. | |

General product information:

1. The appliances are multi-split type air conditioner indoor unit.
2. The main power is supplied from indoor unit separately which not supply by manufactory.
3. MDVC-xxxx series models are cooling mode only, while MDV-xxxxx series models have cooling and heating mode.
4. MIC-xxxx series models are cooling mode only, while MI-xxxxx series models have cooling and heating mode.
5. All models in same series have the similar construction.
6. The products from P1 to P5, Q1 to Q10, R1 to R10, S1 to S4 series are subcooling indoor units, and it must be used together with subcooling outdoor unit sepecified in report 64.111.13.00385.08.
7. Difference description for A series as below:
 - a. The models A1 to A8 are identical with the electric system and mechanical construction except for the fan motor and dimension.
 - b. The model A17 is the same as model A18 except the model name and heat exchanger.
 - c. The models A18, A19 and A20 are the same except the model name.
 - d. The model A21 is the same as model A22 except the model name.
 - e. The model A23 is the same as model A24 except the model name.
8. Difference description for B series as below:
 - a. The models B1 to B10 and B16 to B20 are identical with the models N1 to N10 and N16 to N20 except for front panel.
 - b. The models B21, B22, B23, B24, B25 and B26 are wall-mounted air conditioner, the models B21, B22, B23 are the same except for rating labels.
 - c. The models B27 and B28 are the same in construction except for evaporators.
 - d. The models B31 to B34 are the same as models B27 to B30 except for models name.
 - e. The models B35, B37 and 38 are similar in construction except for fan motor.
 - f. The model B38 and B40 are similar in construction except for main PCB and fan motor.
 - g. The model B40 and B39 are same except for rating label.
 - h. The model B47 is same as B48 except for the heating exchanger, cover of electrical box and model name is different.
 - i. The models B49, E50 is same as B48 except for the model name is different.
 - j. The model B51 is same as B52 except for the model name is different.
 - k. The models B53, B54 and B55 are the same except the model name is different.
 - l. The models B56 to B64 only have cooling mode, the models B47 to B55 have cooling and heating mode.
9. Difference description for C series as below:
 - a. The models C1 to C5 are identical with the electric system and mechanical construction except for the fan motor and dimension.
 - b. The models C11 to C14 are the similar in construction except for heating exchanger.
 - c. The model C19 is the same as model C20 except for the model name, fan motor capacitor and capacity code setting.
 - d. The model C21 is the similar as model C20 in construction except for fan motor, heat changer, model name, fan motor capacitor and capacity code setting.
10. Difference description for D series as below: The models D1 to D6 have the same construction except for the fan motor, fan motor capacitor and dimension.
11. Difference description for E series as below:
 - a. The models E1 and E2 have the same construction.
 - b. The models E3 and E4 are identical with models E1 and E2 except different fan motor, fan motor capacitor and dimension.
 - c. The models E9 and E10 are the same in construction except for evaporators.
 - d. The model E13 is same as E14 except for the model name and capacity code is different.
 - e. The model E15 is same as E14 except for the model name, flow direction of refrigerant and capacity code is different.
 - f. The model E16 is same as E17 except for the model name and capacity code is different.
 - g. The model E16 is same as E14 except for the heating exchanger, capacity code and model name is different.
12. Difference description for F series as below: The models F1 to F5 have the same construction except for the fan motor, fan motor capacitor and dimension.

13. Difference description for G series as below:

- a. The models G1 to G10 have the same construction except for the fan motor, fan motor capacitor and dimension.
- b. The models G21 and G22 are middle static pressure duct type air conditioner, it is the same except for G21 has cooling mode only.
- c. The models G21 to G27 are the same in construction except for evaporators.
- d. The models G33 and G34 are the same except for nameplate.
- e. The models G35 and G34 are similar in construction except for fan motor is different.
- f. The model G39 is the same as model G40 except the model name.
- g. The models G40, G41 and G42 are the same except the model name, capacitor code and heat exchanger.
- h. The model G44 is same as model G43 except the model name, capacitor code and heat exchanger.
- i. The models G44 is same as model G45 except the model name, capacitor code, heat exchanger and size of appliance.
- j. The model G46 is the same as model G47 except the model name, capacitor code and heat exchanger.
- k. The model G48 is the same as model G47 except the model name.
- l. The model G50 is the same as model G42 except for the model name and capacity code setting.
- m. The model G51 is the same as model G42 except for the model name and capacity code setting.
- n. The models G52 and G53 are the same as model G42 respectively except for the rating label.

14. Difference description for H series as below:

- a. The models H1 to H6 are identical with the electric system and mechanical construction except for the fan motor and dimension.
- b. The models H13, H14 and H15, H16 are the same except for nameplate.
- c. The models H17 and H18 are the same except for nameplate.
- d. The models H17 and H16 are similar in construction except for fan motor is different.
- e. The models H19 and H18 are similar in construction except for appearance is different.
- f. The model H27 is the same as model H28 except the model name.
- g. The models H28, H29 and H30 are the same except the model name, capacitor code and heat exchanger.
- h. The model H31 is the same as model H32 except the model name, capacitor code and heat exchanger.
- i. The model H31 is the same as model H30 except the model name and heat exchanger.

15. Difference description for I series as below:

- a. The models I1 to I 4 have the same mechanical construction except different rated current.

16. Difference description for J series as below:

- a. The models J1 to J21 have the same mechanical construction except different dimension.
- b. The code 'F1B', 'F2B', 'F3B' denote different installation method and air return method.

17. Difference description for K series as below:

- a. The models K1 to K14 have the same mechanical construction except different dimension.
- b. The code 'F4', 'F5' denote different air return method.
- c. The models K29 to K35 are the same models K43 to K49 respectively except the model name and return air construction.
- d. The models K36 to K41 are the same models K43 to K49 respectively except the model name and return air construction.
- e. The model K43 is the same as model K44 except the model name.
- f. The model K45 is the same as model K46 except the model name.
- g. The model K47 is the same as model K48 except the model name.
- h. The model K49 is the same as model K48 except the model name, and heat exchanger.
- i. The models K44, K46 and K49 are the same except the model name and heat exchanger.

18. Difference description for L series as below:

- a. The models L1 to L9 have the same mechanical construction except different fan motor, fan motor capacitor and dimension.
- b. The models L19, L20, L21, L22, L23 and L24 are high static pressure duct type air conditioners, L19 and L20 are the same except for nameplate; L21 and L20 are the same except for fan motor.

19. Difference description for M series as below:

- a. The models M1 to M10 are identical with the electric system and mechanical construction except for the fan motor and dimension.
- b. The models M21, M22, M23 and M24 are the same except for nameplate.
- c. The models M25, M26, M27, M28, M29 and M30 are similar in construction except for fan motor is different.
- d. The models M41 and M42 are the same except for nameplate.
- e. The models M43, M44, M45 and M46 are the same except for nameplate.
- f. The models M42 is same as M46 except the heating exchanger and model name is different.
- g. The models M47, M48 and M49 are the same except for model name.
- h. The models M49 is same as M50 except for the heating exchanger and electromagnetic valve is different.
- i. The models M51 to M60 only have cooling mode; the models M41 to M50 have cooling and heating mode.

20. Difference description for N series as below: The models N1 to N10 are identical with the electric system and mechanical construction except for the fan motor and dimension.

21. Difference description for P series as below:

- a. The new models P1 to P5 are the similar as issued models B48 to B52 respectively in construction.
- b. The models P1, P2 and P3 are the same except for the model name.
- c. The models P4 and P5 are the same except for the model name.
- d. The model P4 is the same as model P3 except for fan motor and the size of appliance.

22. Difference description for Q series as below:

- a. The model Q1 is the same as model Q2 except for the model name.
- b. The model Q3 is the same as model Q4 except for the model name.
- c. The model Q2 is the same as model Q4 except for the heat exchanger, fan motor capacitor and model name.
- d. The model Q4 is the same as model Q5 except for the heat exchanger, fan motor and model name.
- e. The model Q5 is the same as model Q6 except for the fan motor and model name.
- f. The model Q6 is the same as model Q8 except for the fan motor and model name.
- g. The model Q8 is the same as model Q9 except for the model name.
- h. The model Q10 is the same as model Q9 except for the heat exchanger, fan motor capacitor and model name.

23. Difference description for R series as below:

- a. The model R1 is the same as model R2 except for the heat exchanger.
- b. The model R3 is the same as model R2 except for the capacitor and heat exchanger.
- c. The model R4 is the same as model R5 except for the size of holes of heat exchanger.
- d. The model R7 is the same as model R8 except for the heat exchanger.
- e. The model R9 is the same as model R8 except for the fan motor and electronic expansion valve.

24. Difference description for S series as below:

- a. The models S1, S2, S3 and S4 are the similar as models E14, E15, E16 and E17 respectively in construction.
- b. The model S1 is the same as model S2 except for the model name.
- c. The model S3 is the same as model S4 except for the model name.
- d. The model S3 is the same as model S2 except for the fan motor, heat exchanger and size of appliance.

25. Difference description for T series as below:

- a. The model T1 is the same as model T2 except for the model name and capacity code setting.
- b. The model T3 is the same as model T4 except for the model name and capacity code setting.
- c. The model T5 is the same as model T6 except for the model name and capacity code setting.
- d. The models T7, T8 and T9 are the same except for the model name and capacity code setting.
- e. The model T10 is the same as model T11 except for the model name and capacity code setting.
- f. The models T12, T13 and T14 are the same except for the model name and capacity code setting.

26. Difference description for U series as below:

- a. The model U1 is the same as model U2 except for the heat exchanger.
- b. The model U3 is the same as model U4 except for the heat exchanger.
- c. The model U5 is the same as model U4 except for the heat exchanger.
- d. The model U6 is the same as model U7 except for the rating label.
- e. The model U7 is the same as model U8 except for the speed of fan motor and rating label.

The models U1 to U8 are the same as models U9 to U16 respectively except the U1 to U8 have heating mode and cooling mode but the models U9 to U16 only have the cooling mode.

27. Difference description for V series as below:

- a. The model V1 is the same as model V2, V3 except for the heat exchanger.
- b. The model V4 is the same as model V5 except for the heat exchanger.
- c. The model V6 is the same as model V7 except for the heat exchanger.
- d. The model V8 is the same as model V9 except for the heat exchanger.

28. This report 64.111.13.00382.09 Rev.01 supersedes original report 64.111.13.00382.09 Rev.00, issued for adding alternative fan motor for model G23-G38.

29. This report 64.111.13.00382.10 Rev.00, dated 2017-11-07 supersedes original report 64.111.13.00382.09 Rev.01, issued for adding model SMK-D140/MN1 which is a water heat exchanger.

30. The test report 64.111.13.00382.10 Rev.01, supersedes the report 64.111.13.00382.10 Rev.00, dated on 2017-11-07 was modified on 2017-12-12 to include for following changes, which were considered technical modifications:

- a) Adding alternative transformer model EI28(8+8)4/P4-3.93L1 for model series A, B35-B64, series I, series K, series M, U3-U5 and U11-U13 in table 24.1.
Adding alternative Indoor Terminal block II for B1-B34, B39, B40, B45, B46, B47-B64, series G, series H, series P and T1-T14 and Terminal block I for B39, B40, B45, B46, F3, F4, F5, F8, F9, F10, L7-L9, L16-L18, series O, series S and T1-T14 and Indoor Terminal block III for series G and H13-H26 model JXO-5A in table 24.1.
Adding alternative Indoor Terminal block II model JXG-3E for model series E and M1-M20 and Indoor Terminal block I for model M21-M40 in table 24.1.
Adding alternative fuse model 30T for model W1 in table 24.1.
- b) Adding alternative main control board MDV-D36Q4.D.1.1.1-2 for model series K and M1-M20. Model MDV-D36Q4.D.1.1.1-2 is the same as MDV-D22T2.D.1.7.1-1 except changing the chip from rear to front and adding the transient voltage suppressor on the board. Details can be referred to photo documents.

31. The test report 64.111.13.00382.11 Rev.00, supersedes the report 64.111.13.00382.10 Rev.01, dated on 2017-12-12 was modified on 2018-01-03 to include for following changes, which were considered technical modifications:

- a) Add new indoor unit models series X1 to X10 in model list. difference description for series X as below:
 - i. The model X1 is the same as model X2, X3 except for the dial the code adjustment for capacity.
 - ii. The model X3 is the same as model X4 except for the heat exchanger, wind wheel and shell.
 - iii. The model X4 is the same as model X5 except for the heat exchanger.
 - iv. The model X5 is the same as model X6 except for the heat exchanger, fan motor and shell.
 - v. The model X7 is the same as model X8 except for the heat exchanger and dial the code adjustment for capacity.
 - vi. The model X8 is the same as model X9 except for the dial the code adjustment for capacity.
 - vii. The model X9 is the same as model X10 except for the heat exchanger, wind wheel, fan motor, volute and shell.
- b) Add new indoor unit models series Y1 to Y7 in model list. difference description for series Y as below:
 - i. The model Y1 is the same as model Y2 except for the flat surface.
 - ii. The model Y2 is the same as model Y4 except for the dial the code adjustment for capacity and heat exchanger.
 - iii. The model Y3 is the same as model Y4 except for the dial the code adjustment for capacity.
 - iv. The model Y4 is the same as model Y6 except for the dial the code adjustment for capacity and heat exchanger.

- v. The model Y5 is the same as model Y6 except for the dial the code adjustment for capacity.
 - vi. The model Y6 is the same as model Y7 except for the dial the code adjustment for capacity and heat exchanger.
 - c) Add new indoor unit models series Z1 to Z6 in model list. difference description for series Z as below:
 - i. The model Z1 is the same as model Z2, Z3 except for the dial the code adjustment for capacity.
 - ii. The model Z4 is the same as model Z5, Z6 except for the dial the code adjustment for capacity.
 - iii. The model Z3 is the same as model Z6 except for the dial the code adjustment for capacity and heat exchanger.
 - d) Add new indoor unit models series AA1 to AA10 in model list. difference description for series AA as below:
 - iv. The model AA1 is the same as model AA2 except for the dial the code adjustment for capacity.
 - v. The model AA3 is the same as model AA4, AA5, AA6 except for the dial the code adjustment for capacity.
 - vi. The model AA10 is the same as model AA7, AA8, AA9 except for the dial the code adjustment for capacity and heat exchanger, AA7, AA8, AA9 only code adjustment for capacity difference.
 - e) Add new indoor unit models series AB1 to AB4 in model list. difference description for series AB as below:
 - i. The model AB1 is the same as model AB2, AB3, AA6 except for the dial the code adjustment for capacity.
 - f) Add new indoor unit models series AC1 to AC8 in model list. difference description for series AC as below:
 - i. The model AC1 is the same as model AC2, AC3 except for the dial the code adjustment for capacity and heating exchange.
 - ii. The model AC3 is the same as model AC4 except for the dial the code adjustment for capacity.
 - iii. The model AC5 is same as model AC6 and the model AC7 is same as model AC8.
 - g) Add new indoor unit models series AD1 to AD21 in model list. difference description for series AD as below:
 - i. The model AD1 is same as model AD2, the model AD3 is same as model AD4 and the model AD5 is same as model AD6.
 - ii. The model AD4 is the same as model AD5 except for the dial the code adjustment for capacity and fan motor.
 - iii. The model AD5 is same as model AD6, AD7 except for the heating exchange.
 - iv. The model AD1 to AD7 difference description is same as model AD8 to AD14 and model AD15 to AD21, except for the model AD1 to AD7 is built-in no shell and other model have a shell.
 - v. The model AD8 to AD14 is same as model AD15 to AD21 except for the return air port position is different.
 - h) Add new indoor unit models series AE1 to AE14 in model list. difference description for series AE as below:
 - i. The model AE1 is the same as model AE2, model AE5 is same as model AE6 and model AE7 is same as model AE8, AE9, except for the dial the code adjustment for capacity.
 - ii. The model AE3 is the same as model AE4 except for the air quantity and dial code adjustment for capacity.
 - iii. The model AE10 to model AE14 difference description is same as AE4 to AE9.
32. The test report 64.111.13.00382.12 Rev.00, supersedes the report 64.111.13.00382.11 Rev.00, dated on 2018-01-03 was modified on 2018-05-21 to include for following changes, which were considered technical modifications:
- a) Add new indoor unit models series AF1 to AF8 in model list. difference description for series AF as below:
 - i. The model AF1 is same as model AF2 except for the heating exchange and nameplate.
 - ii. The model AF3 is same as model AF4 except for the heating exchange and nameplate.
 - iii. The model AF4 is same as model AF5 except for the nameplate.
 - iv. The model AF6 is same as model AF7 and AF8 except for the nameplate.
 - b) Adding alternative fan motor ZKSP-240-8-1, main control board, reactor (R05094A) in model AE1 and AE2. new main control board change the bridge is going from 35A to 25A, the reactor was changed from 25mH to 9,4mH, and moved to the upper right corner of the image electronic control box, reduce an electrolytic capacitor on the main board and change the capacity from 820uF to 560uF in table 24,1. Details can be referred to photo documents.
 - c) The alternative reactor(9,4mH) and PCB must be used in conjunction with the alternative fan motor

ZKSP-240-8-1.

- d) Model AE3 to AE6 and AE10 to AE11 terminal block and cord anchorage Change the location. Details can be referred to photo document.
- e) Model AE7 to AE9 and AE12 to AE14 compressor capacitor and reactor Change the location. Details can be referred to photo document.
- f) Adding alternative PCB material in all models.
- g) Add new indoor unit models series AG1 to AG4 in model list. difference description for series AG as below:
 - i. The model AG1 is same as model AG2 except for the heating exchange and nameplate
 - ii. The model AG2 is same as model AG3 except for the heating exchange and nameplate
 - iii. The model AG3 is same as model AG4 only except for the nameplate.

33. The test report 64.111.13.00382.12 Rev.01, supersedes the report 64.111.13.00382.12 Rev.00, dated on 2018-05-21 was modified on 2018-06-04 to include for following changes, which were considered technical modifications:

- a) Adding alternative fan motor YSK27-4C by manufacturer Welling or Yongan and alternative fan motor YSK27-4C(YSK28-4C4) by manufacturer Tongde for models G23, G24, G25, G26 and G27 in table 24,1.
- b) Adding alternative fan motor YKSS-36-4-65 by manufacturer Welling, alternative fan motor YKSS-36-4-65(YSK36-4D) by manufacturer Tongde and alternative fan motor YKSS-36-4-65(YSK40-4P3-1) by manufacturer Yongan for models G33 and G34 in table 24,1.
- c) Adding alternative fan motor YKSS-61-4-63 by manufacturer Welling, alternative fan motor YKSS-61-4-63 (YSK60-4P3) by manufacturer Tongde and alternative fan motor YKSS-61-4-63 (YF110-61-4S6) by manufacturer Match-Well for models G35 in table 24,1.
- d) Adding alternative faceplate in Photo documentation.
- e) Update net weight form 17kg to 18,5kg for models MDV-D22T2/N1-DA5, MDV-D28T2/N1-DA5 and MDV-D36T2/N1-DA5 in marking plate.

34. The test report 64.111.13.00382.13 Rev.00, supersedes the report 64.111.13.00382.12 Rev.01, dated on 2018-06-04 was modified on 2018-06-20 to include for following changes, which were considered technical modifications:

- a) Updating standard EN 60335-1:2012/A13:2017 base on EN 60335-1:2012 and EN 60335-1:2012/A11:2014.
- b) Adding alternative PCB material for all models.
- c) Adding alternative varistor, Y capacitor for models U1 to U7.
- d) Adding alternative varistor, optocoupler and terminal block for models H13 to H19.
- e) Adding alternative varistor, optocoupler and fan motor capacitor for models L1 to L9, L19, L20 and L21.
- f) Adding alternative varistor, optocoupler and terminal block for models T series.
- g) Adding alternative varistor, optocoupler, fan motor capacitor and terminal block for models G series
- h) Adding alternative varistor, Y capacitor and terminal block for models X series
- i) Adding alternative varistor, Y capacitor and fan motor capacitor for model R9.
- j) Adding alternative varistor, optocoupler and terminal block for models H27 to H33
- k) Adding alternative varistor, Y capacitor and terminal block for models AE series.
- l) Adding alternative varistor and optocoupler for models D1 to D6
- m) Adding alternative varistor, fan motor capacitor and optocoupler for models E series.
- n) Adding alternative varistor, fan motor capacitor and optocoupler for models M series.
- o) Adding alternative varistor, fan motor capacitor and optocoupler for models C11 to C14 and C19 to C21.
- p) Adding alternative varistor, optocoupler and terminal block for models Z series
- q) Adding alternative varistor and Y capacitor for models AA series.
- r) Adding alternative varistor and terminal block for models AB series.
- s) Adding alternative varistor and terminal block for models Y series
- t) Adding alternative varistor, Y capacitor and terminal block for models AF series.
- u) Adding alternative varistor, terminal block and optocoupler for models O1.
- v) Adding alternative varistor, fan motor capacitor and optocoupler for models A1 to A8.
- w) Adding alternative varistor, fan motor capacitor and optocoupler for models K1 to K14.
- x) Adding alternative varistor and optocoupler for models I1 to I4.
- y) Adding alternative varistor and optocoupler for models F1 to F5.

| IEC 60335-2-40 | | | |
|-----------------------|---|-------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 5 | GENERAL CONDITIONS FOR THE TESTS | | - |
| | Tests performed according to clause 5, e.g. nature of supply, sequence of testing, etc. | | P |
| 5.2 | Tests of clause 21 carried out on separate samples. Tests of clauses 11, 19 and 21 require pressure measurements made at various points in refrigerating system (IEC 60335-2-40/A1) | | P |
| | At least one additional specially prepared sample required for tests of annex FF (Leak simulation tests) (IEC 60335-2-40/A1) | | N/A |
| | Temperatures on refrigerant piping measured during test of clause 11 (IEC 60335-2-40/A1) | | N/A |
| 5.6 | Appropriate controls rendered inoperative during test (IEC 60335-2-40) | | P |
| 5.7 | Tests of clauses 10 and 11 carried out under most severe operating conditions within operating temperature range specified by manufacturer. Annex AA provide examples of such temperature conditions (IEC 60335-2-40) | | P |
| 5.10 | For split-package units, refrigerant lines installed in accordance with installation instructions (IEC 60335-2-40) | Only indoor units | N/A |
| | Refrigerant line length is maximum length stated in installation instructions or (IEC 60335-2-40) | | N/A |
| | 7,5 m, whichever is shorter (IEC 60335-2-40) | | N/A |
| | Thermal insulation of refrigerant lines applied in accordance with installation instructions (IEC 60335-2-40) | | N/A |
| 5.101 | Motor-compressor subjected to relevant test of clause 19 of IEC 60335-2-34, unless (IEC 60335-2-40) | | N/A |
| | motor-compressor comply with that standard (IEC 60335-2-40) | | N/A |
| 5.102 | Motor-compressors tested and comply with IEC 60335-2-34 need not additionally tested for clause 21 (IEC 60335-2-40/A1) | | N/A |
| 6 | CLASSIFICATION | | |
| 6.1 | Protection against electric shock: Class I, II, III (IEC 60335-2-40).....: | Class I | P |
| 6.2 | Protection against harmful ingress of water, IP degree in accordance with IEC 60529 (IEC 60335-2-40) | | - |
| | - appliances or parts intended for outdoor use be at least IPX4 (IEC 60335-2-40); | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - appliances intended only for indoor use (excluding laundry rooms) be IPX0 (IEC 60335-2-40); | IP20 for SMK-D140/MN1 only, IPX0 for other models | P |
| | - appliances intended to be used in laundry rooms be at least IPX1 (IEC 60335-2-40). | | N/A |
| 6.101 | Degree of accessibility (accessible/not accessible to the general public) (IEC 60335-2-40) | Accessible to the general public | P |
| 7 | MARKING AND INSTRUCTIONS | | - |
| 7.1 | Rated voltage or voltage range (V).....: | 220-240 | P |
| | Symbol for nature of supply including number of phases, unless for single phase operation (IEC 60335-2-40).....: | ~ | P |
| | Rated frequency (Hz) | 50 | P |
| | Rated power input (W), or | | N/A |
| | Rated current (A) | See rating labels | P |
| | Manufacturer's or responsible vendor's name, trademark or identification mark.....: | Midea, MDV | P |
| | Model or type reference.....: | See rating labels | P |
| | Symbol IEC 60417-5172, for class II appliances | | N/A |
| | IP number, other than IPX0.....: | IPX0 | N/A |
| | Symbol IEC 60417-5180, for class III appliances, unless | | N/A |
| | the appliance is operated by batteries only | | N/A |
| | Symbol IEC 60417-5036, for the enclosure of electrically-operated water valves in external hose-sets for connection of an appliance to the water mains, if the working voltage exceeds extra-low voltage | | N/A |
| | Mass of refrigerant or of each refrigerant in blend (except for azeotropic type) (IEC 60335-2-40) | | N/A |
| | Refrigerant identification (IEC 60335-2-40).....: | | N/A |
| | Permissible excessive operating pressure for sanitary hot water heat pumps (IEC 60335-2-40)..: | | N/A |
| | Maximum operating pressure for heat exchanger for hydronic fan coil/air handling units (IEC 60335-2-40/A2) | See rating labels | P |
| | Permissible excessive operating pressure of refrigerant circuit for suction and discharge, if they differ (IEC 60335-2-40).....: | | N/A |
| | Symbol for degree of protection against ingress of water, other than IPX0 (IEC 60335-2-40) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Separate marking of appliances with all rated characteristics of supplementary heaters (IEC 60335-2-40).....: | For some models (see attachment No.4 for details) | P |
| | Marking of direction of fluid flow (IEC 60335-2-40) | | P |
| | Flame symbol and instruction manual symbol of 7.6 visible when flammable refrigerant employed and following conditions exist (IEC 60335-2-40/A1): | | - |
| | - accessing parts expected to be subjected to maintenance or repair (IEC 60335-2-40/A1); | | N/A |
| | - observing appliance under sale or installed conditions (IEC 60335-2-40/A1); | | N/A |
| | - observing appliance packaging, if appliance charged with refrigerant (IEC 60335-2-40/A1). | | N/A |
| | If flammable refrigerant used, symbols for “read operator’s manual”, “operator’s manual; operating instructions” and “service indicator; read technical manual” (symbols 0790, 1641 and 1659 of ISO 7000) placed on appliance in location visible to persons required to know information. Perpendicular height be at least 10 mm (IEC 60335-2-40/A1 corr.1) | | N/A |
| | Additional warning symbol (flame symbol: B.3.2 of ISO 3864) placed on nameplate of unit near declaration of refrigerant type and charge information. Perpendicular height be at least 10 mm, and symbol need not be in colour (IEC 60335-2-40/A1) | | N/A |
| | Following warning also applied to appliance when flammable refrigerant employed. WARNING Appliance shall be installed, operated and stored in a room with a floor area larger than ‘X’ m ² (only applies to appliances that are not fixed appliances) (IEC 60335-2-40/A1) | | N/A |
| | Not fixed appliances, minimum room size X specified on appliance. X in marking determined in m ² by procedure described in paragraph 2 of annex GG for unventilated areas and X in marking be 4 if refrigerant charge of appliance is less than m ₁ (see annex GG, paragraph 1.1) (IEC 60335-2-40/A1) | | N/A |
| | Maximum allowable pressure for low-pressure side and high-pressure side marked on product (IEC 60335-2-40/A1) | | N/A |
| | If not already visible when accessing service port and if service port provided, service port marked to identify type of refrigerant. If refrigerant is flammable, symbol B.3.2 of ISO 3864, be included, without specifying the colour (IEC 60335-2-40/A1) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.2 | Warning for stationary appliances for multiple supply | | N/A |
| | Warning placed in vicinity of terminal cover | | N/A |
| 7.3 | Range of rated values marked with the lower and upper limits separated by a hyphen | | P |
| | Different rated values marked with the values separated by an oblique stroke | | N/A |
| 7.4 | Appliances adjustable for different rated voltages, the voltage setting is clearly discernible | | N/A |
| | Requirement met if frequent changes are not required and the rated voltage to which the appliance is to be adjusted is determined from a wiring diagram | | N/A |
| 7.5 | Appliances with more than one rated voltage or one or more rated voltage ranges, marked with rated input or rated current for each rated voltage or range, unless | | N/A |
| | the power input is related to the arithmetic mean value of the rated voltage range | | P |
| | Relation between marking for upper and lower limits of rated power input or rated current and voltage is clear | | N/A |
| 7.6 | Correct symbols used | | P |
| | Flammable refrigerant, warning symbol B.3.2 of ISO 3864, including colour and format, permanently placed on appliance. Perpendicular height of triangle containing "Caution, risk of fire" symbol be at least 30 mm (IEC 60335-2-40/A1) | | N/A |
| | Flammable refrigerant, symbol requiring reference to manual [0790 of ISO 7000], including colour and format, permanently placed on appliance (IEC 60335-2-40/A1 corr.1) | | N/A |
| | Symbol for nature of supply placed next to rated voltage | | P |
| | Symbol for class II appliances placed unlikely to be confused with other marking | | N/A |
| | Units of physical quantities and their symbols according to international standardized system | | P |
| 7.7 | Connection diagram fixed to appliances to be connected to more than two supply conductors and appliances for multiple supply, unless | | N/A |
| | correct mode of connection is obvious | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.8 | Except for type Z attachment, terminals for connection to the supply mains indicated as follows: | | - |
| | - marking of terminals exclusively for the neutral conductor (letter N) | | P |
| | - marking of protective earthing terminals (symbol IEC 60417-5019) | | P |
| | - marking not placed on removable parts | | P |
| 7.9 | Marking or placing of switches which may cause a hazard | | N/A |
| 7.10 | Indications of switches on stationary appliances and controls on all appliances by use of figures, letters or other visual means | "ON/OFF" | P |
| | This applies also to switches which are part of a control | | N/A |
| | If figures are used, the off position indicated by the figure 0 | | N/A |
| | The figure 0 indicates only OFF position, unless no confusion with the OFF position | | N/A |
| 7.11 | Indication for direction of adjustment of controls | | P |
| 7.12 | Instructions for safe use provided | | P |
| | Details concerning precautions during user maintenance | | P |
| | Appliances not accessible to general public, classification of clause 6.101 included (IEC 60335-2-40) | | N/A |
| | Appliances using flammable refrigerants, an installation, service and operation manual, either separate or combined manuals, provided and include information given in annex DD (IEC 60335-2-40/A1) | | N/A |
| | The instructions state that: | | - |
| | - the appliance is not to be used by persons (including children) with reduced physical, sensory or mental capabilities, or lack of experience and knowledge, unless they have been given supervision or instruction | Replaced by EN 60335-1:2012 | N/A |
| | - children being supervised not to play with the appliance | Replaced by EN 60335-1:2012 | N/A |
| | For a part of class III construction supplied from a detachable power supply unit, the instructions state that the appliance is only to be used with the unit provided | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Instructions for class III appliances state that it must only be supplied at SELV, unless | | N/A |
| | it is a battery-operated appliance, the battery being charged outside the appliance | | N/A |
| 7.12.1 | Sufficient details for installation supplied | | P |
| | For an appliance intended to be permanently connected to the water mains and not connected by a hose-set, this is stated | | N/A |
| | Sufficient details for installation or maintenance supplied (IEC 60335-2-40): | | - |
| | - that the appliance shall be installed in accordance with national wiring regulations (IEC 60335-2-40); | | P |
| | - the dimensions of the space necessary for correct installation of the appliance including the minimum permissible distance to adjacent structures (IEC 60335-2-40); | | P |
| | - for appliances with supplementary heaters, the minimum clearance from the appliance to combustible surfaces (IEC 60335-2-40); | For some models (see attachment No.4 for details) | P |
| | - a wiring diagram with a clear indication of the connections and wiring to external control devices and supply cord (IEC 60335-2-40); | | P |
| | - the range of external static pressures at which the appliance was tested (add-on heat pumps and appliances with supplementary heaters only) (IEC 60335-2-40); | | P |
| | - the method of connection to the appliance to the electrical supply and interconnection of separate components (IEC 60335-2-40); | | P |
| | - indication of which parts of the appliance are suitable for outdoor use, if applicable (IEC 60335-2-40); | | N/A |
| | - details of type and rating of fuses (IEC 60335-2-40); | | P |
| | - details of supplementary heating elements that may be used in conjunction with the appliance, including fitting instructions either with the appliance or with the supplementary heater (IEC 60335-2-40); | | P |
| | - maximum and minimum water or brine operating temperatures (IEC 60335-2-40); | | P |
| | - maximum and minimum water or brine operating pressures (IEC 60335-2-40). | | P |
| | Open storage tanks of heat pumps for water heating, accompanied by an instruction sheet which state that the vent shall not be obstructed (IEC 60335-2-40) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.12.2 | Stationary appliances not fitted with means for disconnection from the supply mains having a contact separation in all poles that provide full disconnection under overvoltage category III, the instructions state that means for disconnection must be incorporated in the fixed wiring in accordance with the wiring rules | Stated in the manual | P |
| 7.12.3 | Insulation of the fixed wiring in contact with parts exceeding 50 K during clause 11; instructions state that the fixed wiring must be protected | | N/A |
| 7.12.4 | Instructions for built-in appliances: | | - |
| | - dimensions of space | For some models | P |
| | - dimensions and position of supporting and fixing | | P |
| | - minimum distances between parts and surrounding structure | | P |
| | - minimum dimensions of ventilating openings and arrangement | | P |
| | - connection to supply mains and interconnection of separate components | | P |
| | - allow disconnection of the appliance after installation, by accessible plug or a switch in the fixed wiring, unless | | P |
| | a switch complying with 24.3 | | N/A |
| 7.12.5 | Replacement cord instructions, type X attachment with a specially prepared cord | | N/A |
| | Replacement cord instructions, type Y attachment | | P |
| | Replacement cord instructions, type Z attachment | | N/A |
| 7.12.6 | Caution in the instructions for appliances incorporating a non-self-resetting thermal cut-out that is reset by disconnection of the supply mains, if this cut-out is required to comply with the standard | | N/A |
| 7.12.7 | Instructions for fixed appliances stating how the appliance is to be fixed | | P |
| 7.12.8 | Instructions for appliances connected to the water mains: | | - |
| | - max. inlet water pressure (Pa) | | N/A |
| | - min. inlet water pressure, if necessary (Pa) | | N/A |
| | Instructions concerning new and old hose-sets for appliances connected to the water mains by detachable hose-sets | | N/A |
| 7.13 | Instructions and other texts in an official language | English | P |
| 7.14 | Marking clearly legible and durable, rubbing test as specified | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7.15 | Markings on a main part | | P |
| | Marking clearly discernible from the outside, if necessary after removal of a cover | | P |
| | For portable appliances, cover can be removed or opened without a tool | | N/A |
| | For stationary appliances, name, trademark or identification mark and model or type reference visible after installation | | N/A |
| | For fixed appliances, name, trademark or identification mark and model or type reference visible after installation according to the instructions | | P |
| | Indications for switches and controls placed on or near the components. Marking not on parts which can be positioned or repositioned in such a way that the marking is misleading | | N/A |
| | Marking on panel allowed, provided panel in place for intended operation of appliance (IEC 60335-2-40) | | P |
| 7.16 | Marking of a possible replaceable thermal link or fuse link clearly visible with regard to replacing the link | | P |
| 7.101 | Marking of fuses and overload protective devices, if replaceable (IEC 60335-2-40): | | - |
| | - fuse rated current in amperes, type and rated voltage or (IEC 60335-2-40) | | P |
| | - manufacturer and model of overload protective device (IEC 60335-2-40) | | N/A |
| 7.102 | Marking for connection with aluminium wire, if necessary (IEC 60335-2-40) | | N/A |
| 8 | PROTECTION AGAINST ACCESS TO LIVE PARTS | | - |
| 8.1 | Adequate protection against accidental contact with live parts | | P |
| 8.1.1 | Requirement applies for all positions, detachable parts removed | | P |
| | Lamps behind a detachable cover not removed, if conditions met | | N/A |
| | Insertion or removal of lamps, protection against contact with live parts of the lamp cap | | N/A |
| | Use of test probe B of IEC 61032, with a force not exceeding 1 N: no contact with live parts | | P |
| | Use of test probe B of IEC 61032 through openings, with a force of 20 N: no contact with live parts | | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 8.1.2 | Use of test probe 13 of IEC 61032, with a force not exceeding 1 N, through openings in class 0 appliances and class II appliances/constructions: no contact with live parts | | P |
| | Test probe 13 also applied through openings in earthed metal enclosures having a non-conductive coating: no contact with live parts | | P |
| 8.1.3 | For appliances other than class II, use of test probe 41 of IEC 61032, with a force not exceeding 1 N: no contact with live parts of visible glowing heating elements | No visible glowing heating elements used. | N/A |
| 8.1.4 | Accessible part not considered live if: | | - |
| | - safety extra-low a.c. voltage: peak value not exceeding 42,4 V | | N/A |
| | - safety extra-low d.c. voltage: not exceeding 42,4 V | | N/A |
| | - or separated from live parts by protective impedance | | N/A |
| | If protective impedance: d.c. current not exceeding 2 mA, and | | N/A |
| | a.c. peak value not exceeding 0,7 mA | | N/A |
| | - for peak values over 42,4 V up to and including 450 V, capacitance not exceeding 0,1 μ F | | N/A |
| | - for peak values over 450 V up to and including 15 kV, discharge not exceeding 45 μ C | | N/A |
| | - for peak values over 15kV, the energy in the discharge not exceeding 350 mJ | | N/A |
| 8.1.5 | Live parts protected at least by basic insulation before installation or assembly: | | - |
| | - built-in appliances | | N/A |
| | - fixed appliances | | P |
| | - appliances delivered in separate units | | N/A |
| 8.2 | Class II appliances and constructions constructed so that there is adequate protection against accidental contact with basic insulation and metal parts separated from live parts by basic insulation only | Class II construction | P |
| | Only possible to touch parts separated from live parts by double or reinforced insulation | | P |
| 9 | STARTING OF MOTOR-OPERATED APPLIANCES | | - |
| | Requirements and tests are specified in part 2 when necessary | | N/A |
| 10 | POWER INPUT AND CURRENT | | - |

| IEC 60335-2-40 | | | |
|-----------------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 10.1 | Power input at normal operating temperature, rated voltage and normal operation not deviating from rated power input by more than shown in table 1...: | | N/A |
| | Test carried out at upper and lower limits of the ranges for appliances with one or more rated voltage ranges, unless | | N/A |
| | the rated power input is related to the arithmetic mean value | | N/A |
| 10.2 | Current at normal operating temperature, rated voltage and normal operation not deviating from rated current by more than shown in table 2 | (see appended table) | P |
| | Test carried out at upper and lower limits of the ranges for appliances with one or more rated voltage ranges, unless | | N/A |
| | the rated current is related to the arithmetic mean value of the range | | P |
| 11 | HEATING | | - |
| 11.1 | No excessive temperatures in normal use (IEC 60335-2-40) | | P |
| | Compliance is checked by the tests of annex C, if (IEC 60335-2-40): | | - |
| | - temperature of motor winding exceeds values shown in table 3 (IEC 60335-2-40) | | N/A |
| | - there is doubt about classification of insulation system of the motor (IEC 60335-2-40) | | N/A |
| 11.2 | Placing and mounting of appliance (IEC/EN 60335-2-40): | | - |
| | - clearances to adjacent surfaces (IEC 60335-2-40); | | P |
| | - flow rates for liquid source or sink equipment be minimum, except for fan coils where flow rates and liquid temperatures be maximum (IEC 60335-2-40/A2); | | N/A |
| | - static pressures (IEC 60335-2-40); | | N/A |
| | - means of adjusting the flow, flow for tests be minimum obtainable (IEC 60335-2-40); | | P |
| | - adjustable limit controls set at maximum cut-out setting and minimum differential (IEC 60335-2-40). | | P |
| | Appliances with supplementary heaters, use test casing of clause 11.9 (IEC 60335-2-40) | For some models (see attachment No.4 for details) | P |
| 11.2.1 | Appliances with supplementary heaters, inlet duct connected to inlet air opening (IEC 60335-2-40) | For some models (see attachment No.4 for details) | P |
| 11.2.2 | Appliance without supplementary heaters, air outlet used (IEC 60335-2-40) | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 11.3 | Temperature rise determine by thermocouples or resistance method (IEC 60335-2-40) | Resistance method: fan motor, transformer, Thermocouples method: other parts | P |
| 11.4 | Test performed at supply voltage between 0,94 and 1,06 times the rated voltage (IEC 60335-2-40) | 254,4V and 206,8V | P |
| | Heating elements energized at voltage which gives an electrical input of 1,15 times maximum rated power input (IEC 60335-2-40) | | N/A |
| 11.5 | Test conducted in heating mode and cooling mode, if both exist (IEC 60335-2-40) | | P |
| | All supplementary heating elements operative simultaneously (IEC 60335-2-40) | | P |
| 11.6 | Defrost test in most unfavourable conditions, if needed (IEC/EN 60335-2-40) | | N/A |
| 11.7 | Appliances operated continuously until steady conditions except for defrost tests (IEC 60335-2-40) | | P |
| 11.8 | Temperatures not exceeding values of table 3 (IEC 60335-2-40/A2) | (See appended tables) | P |
| | Protective devices do not operate (IEC 60335-2-40) | | P |
| | Sealing compound not flowing out (IEC 60335-2-40) | | P |
| | Temperature of air in outlet duct not exceed 90 °C (IEC 60335-2-40) | | P |
| 11.9 | Test casing and installation of appliances in accordance with manufacturer's instructions (IEC 60335-2-40) | For some models (see attachment No.4 for details) | P |
| | Glass fibre insulation for appliances without indication of minimum clearances according to manufacturer; thermocouple in contact with enclosure (IEC 60335-2-40) | | N/A |
| 13 | LEAKAGE CURRENT AND ELECTRIC STRENGTH AT OPERATING TEMPERATURE | | - |
| 13.1 | Leakage current not excessive and electric strength adequate | | P |
| | Heating appliances operated at 1,15 times the rated power input (W) | | N/A |
| | Motor-operated appliances and combined appliances supplied at 1,06 times the rated voltage (V)..... | 254,4V~ | P |
| | Protective impedance and radio interference filters disconnected before carrying out the tests | | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 13.2 | For class 0, class II and class III appliances, leakage current measured by means of the circuit described in figure 4 of IEC 60990 | | N/A |
| | For other appliances, a low impedance ammeter may be used | | P |
| | Leakage current measurements: (IEC 60335-2-40) | (see appended table) | P |
| 13.3 | The appliance is disconnected from the supply | | P |
| | Electric strength tests according to table 4.....: (see appended table) | (see appended table) | P |
| | No breakdown during the tests | | P |
| 14 | TRANSIENT OVERVOLTAGES | | - |
| | Appliances withstand the transient over-voltages to which they may be subjected | | N/A |
| | Clearances having a value less than specified in table 16 subjected to an impulse voltage test, the test voltage specified in table 6: (see appended table) | | N/A |
| | No flashover during the test, unless | | N/A |
| | of functional insulation if the appliance complies with clause 19 with the clearance short-circuited | | N/A |
| 15 | MOISTURE RESISTANCE | | - |
| 15.1 | Enclosure provides degree of moisture protection against ingress of water (rain, overflow from drain pan or defrosting), tests of clause 15.2, 15.3, 11.6 and 16) (IEC 60335-2-40) | | P |
| | Motor-compressor not operated and detachable parts removed during tests of clause 15.2 and 15.3 (IEC 60335-2-40/A2) | | N/A |
| 15.2 | Tests in accordance with IEC 60529 in appliances other than IPX0, as specified (IEC 60335-2-40).....: (see appended table) | | N/A |
| 15.3 | Drain pan filled to brim and subjected to continuous overflow and fan(s) switched on (IEC 60335-2-40) | | P |
| 15.101 | Spillage test as specified (IEC 60335-2-40/A2) | | P |
| | After spillage completed, appliance withstand test of clause 16 (IEC 60335-2-40/A2) | | P |
| 16 | LEAKAGE CURRENT AND ELECTRIC STRENGTH | | - |
| 16.1 | Leakage current not excessive and electric strength adequate | | P |
| | Protective impedance disconnected from live parts before carrying out the tests | | P |
| | Tests carried out at room temperature and not connected to the supply | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 16.2 | Single-phase appliances: test voltage 1,06 times rated voltage (V) | 254,4V | P |
| | Three-phase appliances: test voltage 1,06 times rated voltage divided by $\sqrt{3}$ (V) | | N/A |
| | Leakage current measurements (IEC 60335-2-40) | (see appended table) | P |
| | Limit values doubled if: | | - |
| | - all controls have an off position in all poles, or | | N/A |
| | - the appliance has no control other than a thermal cut-out, or | | N/A |
| | - all thermostats, temperature limiters and energy regulators do not have an off position, or | | N/A |
| | - the appliance has radio interference filters | | N/A |
| | With the radio interference filters disconnected, the leakage current do not exceed limits specified | (see appended table) | P |
| 16.3 | Electric strength tests according to table 7..... | (see appended table) | P |
| | Test voltage applied between the supply cord and inlet bushing and cord guard and cord anchorage as specified | (see appended table) | P |
| | No breakdown during the tests | | P |
| 17 | OVERLOAD PROTECTION OF TRANSFORMERS AND ASSOCIATED CIRCUITS | | - |
| | No excessive temperatures in transformer or associated circuits in event of short-circuits likely to occur in normal use | (see appended table) | P |
| | Appliance supplied with 1,06 or 0,94 times rated voltage under the most unfavourable short-circuit or overload likely to occur in normal use (V) | 254,4 V~ | P |
| | Basic insulation is not short-circuited | | P |
| | Temperature rise of insulation of the conductors of safety extra-low voltage circuits not exceeding the relevant value specified in table 3 by more than 15 K | | N/A |
| | Temperature of the winding not exceeding the value specified in table 8 | | P |
| | However, limits do not apply to fail-safe transformers complying with sub-clause 15.5 of IEC 61558-1 | | N/A |
| 18 | ENDURANCE | | - |
| | Requirements and tests are specified in part 2 when necessary | | N/A |
| 19 | ABNORMAL OPERATION | | - |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 19.1 | The risk of fire or mechanical damage under abnormal or careless operation obviated (tests 19.2-19.14) (IEC 60335-2-40) | | P |
| | Failure of transfer medium flow or of any control device not result in a hazard (IEC 60335-2-40) | | P |
| | Electronic circuits so designed and applied that a fault will not render the appliance unsafe (electric shock, fire or mechanical hazard, dangerous malfunction) (test 19.11 and 19.12) (IEC 60335-2-40) | | P |
| 19.2 | Test of appliance with motor rotors, other than motor-compressors, operated for 15 days (360 h) or until protection device opens circuit (IEC 60335-2-40) | | P |
| | Insulation of motor windings (IEC 60335-2-40) | (See appended table) | P |
| | Temperature of enclosure does not exceed (°C) (IEC 60335-2-40)..... | (See appended table) | P |
| | Temperature of the windings does not exceed the values shown in the table ; temperature (°C) (IEC 60335-2-40)..... | (See appended table) | P |
| | Electric strength test as specified in 16.3, 72 h after the beginning of the test (IEC 60335-2-40) | | P |
| | 30 mA residual current device does not open (IEC 60335-2-40) | | P |
| | At the end, leakage current between windings and enclosure does not exceed 2 mA (IEC 60335-2-40) | | P |
| 19.3 | Motor-compressor complies with IEC 60335-2-34 (IEC 60335-2-40) | | N/A |
| | Test of motor-compressor with rotor locked as specified in clause 19.101 of IEC 60335-2-34 and comply with 19.104 of that standard (IEC 60335-2-40) | | N/A |
| 19.4 | Test of three-phase motors operated under conditions of clause 11 with one phase disconnected until steady conditions or protective device operates (IEC 60335-2-40) | | N/A |
| 19.5 | Test of appliance with heat transfer medium flow of the outdoor heat exchanger restricted or shut off when reaching steady conditions (IEC 60335-2-40) | (See appended table) | P |
| | Test of appliance with heat transfer flow of the indoor heat exchanger restricted or shut off when reaching steady conditions (IEC 60335-2-40) | | P |
| | Disconnection of motor common to both the outdoor and the indoor heat exchangers when reaching steady conditions (IEC 60335-2-40) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 19.6 | Test of appliances using water as heat transfer medium (IEC 60335-2-40) | For SMK-D140/MN1 only | P |
| 19.7 | Test of air to air appliances at rated voltage or at the upper limit of the rated voltage range. Dry-bulb temperature is 5 K below values specified by manufacturer (IEC 60335-2-40) | | P |
| | Test with the dry-bulb temperature 10 K over the values specified by manufacturer (IEC 60335-2-40) | | P |
| 19.8 | Test of appliances with supplementary heaters (IEC 60335-2-40) | The test performed and the test result is positive. | P |
| 19.9 | Test at temperature permitting continuous operation of the motor-compressor and electric heating elements at same time (IEC 60335-2-40) | | N/A |
| 19.10 | Test of appliance with any defect which expected during normal use (IEC 60335-2-40) | (see appended table) | P |
| 19.10.101 | Test of clause 19.10 repeated on class 0I appliances and class I appliances incorporating tubular sheathed or embedded heating elements (IEC 60335-2-40/A2) | Embedded heating elements | P |
| | However, controls not short-circuited but one end of element connected to sheath of heating element (IEC 60335-2-40/A2) | | N/A |
| | Test repeated with polarity of supply to appliance reversed and with other end of element connected to sheath (IEC 60335-2-40/A2) | | P |
| | Test not carried out on appliances intended to permanently connected to fixed wiring and on appliances where an all-pole disconnection occurs during test of clause 19.10 (IEC 60335-2-40/A2) | | N/A |
| 19.11 | Electronic circuits, compliance checked by evaluation of the fault conditions specified in clause 19.11.2 for all circuits or parts of circuits (IEC 60335-2-40), unless | | P |
| | they comply with conditions specified in clause 19.11.1 (IEC 60335-2-40) | | N/A |
| | Windings temperature not exceeding values shown in table 8 (IEC 60335-2-40) | | P |
| | Appliance comply with conditions of clause 19.14 (IEC 60335-2-40) | | P |
| | Appliance withstands test: a conductor becomes open circuited and three conditions are met (IEC 60335-2-40) | | N/A |
| 19.11.1 | Before applying the fault conditions a) to f) in 19.11.2, it is checked if circuits or parts of circuit meet both of following conditions (IEC 60335-2-40): | | - |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - electronic circuit is low-power circuit, that is, maximum power at low-power points not exceed 15 W according to tests specified (IEC 60335-2-40) | | N/A |
| | - protection against electric shock, fire hazard, mechanical hazard or dangerous malfunction in other parts of appliance does not rely on correct functioning of electronic circuit (IEC 60335-2-40) | | P |
| 19.11.2 | Fault conditions applied one at a time, appliance operated under conditions specified in clause 11, but supplied at rated voltage, duration of tests as specified (IEC 60335-2-40): | | - |
| | a) short circuit of creepage distances and clearances between live parts of different potential, if these distances less than values specified in clause 29.1, unless relevant part is adequately encapsulated (IEC 60335-2-40) | | N/A |
| | b) open circuit at terminals of any component (IEC 60335-2-40) | | P |
| | c) short circuit if capacitors, unless they comply with IEC 60384-14 (IEC 60335-2-40) | | P |
| | d) short circuit of any two terminals of an electronic component, other than integrated circuits. This fault condition not applied between circuits of an optocoupler (IEC 60335-2-40) | | P |
| | e) failure of triacs in diode mode (IEC 60335-2-40) | | P |
| | f) failure of an integrated circuit. Possible hazardous situations of appliance assessed to ensure that safety not rely on correct functioning of such component (IEC 60335-2-40) | | P |
| | Short-circuit of low-power circuits (IEC 60335-2-40) | | N/A |
| | Duration of tests (IEC 60335-2-40): | | - |
| | - as specified in clause 11.7 but only for one operating cycle, if fault cannot recognised by user (IEC 60335-2-40); | | P |
| | - as specified in clause 19.2, if fault can recognised by user (IEC 60335-2-40); | | P |
| | - until steady conditions established (IEC 60335-2-40). | | P |
| | Test ended if interruption of supply occurs within the appliance (IEC 60335-2-40) | | P |
| | If electronic circuit operates to ensure compliance with clause 19, relevant test repeated with single fault a) to f) simulated (IEC 60335-2-40) | | N/A |
| | Fault condition f) applied to encapsulated or similar components (IEC 60335-2-40) | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | PTC's, NTC's and VDR's resistors not short-circuited if used as specified by manufacturer (IEC 60335-2-40) | | P |
| 19.12 | If safety of appliance for any of fault conditions specified in clause 19.11.2 depends on operation of miniature fuse-link complying with IEC 60127, test repeated with fuse-link replaced by an ammeter (IEC 60335-2-40) | | P |
| | Current $\leq 2,1$ times rated current of fuse-link, circuit not adequately protected (fuse-link short-circuited) (IEC 60335-2-40) | | N/A |
| | Current $\geq 2,75$ times rated current of fuse-link, circuit adequately protected (IEC 60335-2-40) | | P |
| | Current $\geq 2,1$ and $\leq 2,75$ times rated current, fuse-link short-circuited and test carried out during specified time (IEC 60335-2-40) | | N/A |
| 19.13 | Appliances with PTC heating elements test as specified (IEC 60335-2-40) | | N/A |
| 19.14 | During tests of clause 19.2 to 19.10.101 and 19.11, 19.12 and 19.13 if appropriate, appliances not emit flames, molten metal, poisonous or ignitable gas in hazardous amounts (IEC 60335-2-40/A2) | | P |
| | Enclosures not deform (IEC 60335-2-40) | | P |
| | Temperature rise not exceed values shown in table 9 (IEC 60335-2-40) | (See appended table) | P |
| | Electric strength test, test voltage as specified in table 4 (IEC 60335-2-40) | | P |
| 19.15 | For appliances with a mains voltage selector switch, the switch is set to the lowest rated voltage position and the highest value of rated voltage is applied | | N/A |
| 19.101 | All appliances provided with supplementary heaters and free air discharge subjected to specified test in each mode of operation (IEC 60335-2-40/A2) | For some models (see attachment No.4 for details) | P |
| | During test temperature not exceed 150 °C but an overshoot of 25 °C is permitted during first hour (IEC 60335-2-40/A2) | | P |
| 20 | STABILITY AND MECHANICAL HAZARDS | | - |
| 20.1 | Appliances having adequate stability | Fixed appliance | N/A |
| | Tilting test through an angle of 10°, appliance placed on an inclined plane/horizontal support, not connected to the supply mains; appliance does not overturn | | N/A |
| | Tilting test repeated on appliances with heating elements, angle of inclination increased to 15° | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Possible heating test in overturned position; temperature rise does not exceed values shown in table 9 | | N/A |
| 20.2 | Moving parts adequately arranged or enclosed as to provide protection against personal injury | | P |
| | Protective enclosures, guards and similar parts are non-detachable, and | | P |
| | have adequate mechanical strength | | P |
| | Enclosures that can be opened by overriding an interlock are considered to be detachable parts | | P |
| | Self-resetting thermal cut-outs and overcurrent protective devices not causing a hazard by unexpected closure | Used for fan motor | P |
| | Not possible to touch dangerous moving parts with the test probe described | | P |
| 21 | MECHANICAL STRENGTH | | - |
| 21.1 | Appliance has adequate mechanical strength and is constructed as to withstand rough handling | | P |
| | Checked by applying 3 blows to every point of the enclosure like to be weak, in accordance with test Ehb of IEC 60068-2-75, spring hammer test, with an impact energy of 0,5 J | (see appended table) | P |
| | The appliance shows no damage impairing compliance with this standard, and | | P |
| | compliance with 8.1, 15.1 and clause 29 not impaired | | P |
| | If doubt, supplementary or reinforced insulation subjected to the electric strength test of 16.3 | | N/A |
| | If necessary, repetition of groups of three blows on a new sample | | N/A |
| | Safety requirements specified in annex EE applied. Pressure test in annex EE applies to parts other than pressure vessels (IEC 60335-2-40/A1) | | P |
| | Safety requirements of ISO 5149 applied (IEC 60335-2-40/A2) | | P |
| 21.2 | Accessible parts of solid insulation having strength to prevent penetration by sharp implements | | P |
| | Test not applicable if the thickness of supplementary insulation is at least 1 mm and reinforced insulation at least 2 mm | | P |
| | The insulation is tested as specified, and does withstand the electric strength test of 16.3 | | N/A |
| 22 | CONSTRUCTION | | - |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.1 | Appliance marked with the first numeral of the IP system, relevant requirements of IEC 60529 are fulfilled | | P |
| 22.2 | Stationary appliance: means to ensure all-pole disconnection from the supply being provided: | | - |
| | - a supply cord fitted with a plug, or | | N/A |
| | - a switch complying with 24.3, or | | N/A |
| | - a statement in the instruction sheet that a disconnection incorporated in the fixed wiring is to be provided, or | | P |
| | - an appliance inlet | | N/A |
| | Singe-pole switches and single-pole protective devices for the disconnection of heating elements in single-phase, permanently connected class 01 and class I appliances, connected to the phase conductor | | N/A |
| 22.3 | Appliance provided with pins: no undue strain on socket-outlets | | N/A |
| | Applied torque not exceeding 0,25 Nm | | N/A |
| | Pull force of 50 N to each pin after the appliance has being placed in the heating cabinet; when cooled to room temperature the pins are not displaced by more than 1 mm | | N/A |
| | Each pin subjected to a torque of 0,4 Nm; the pins are not rotating, unless | | N/A |
| | rotating does not impair compliance with this standard | | N/A |
| 22.4 | Appliance for heating liquids and appliance causing undue vibration not provided with pins for insertion into socket-outlets | | N/A |
| 22.5 | No risk of electric shock when touching the pins of the plug, for appliances having a capacitor with rated capacitance exceeding 0,1 μ F, the appliance being disconnected from the supply at the instant of voltage peak | | N/A |
| | Voltage not exceeding 34 V (V).....: | | N/A |
| 22.6 | Electrical insulation not affected by condensing water or leaking liquid | | P |
| | Electrical insulation of class II appliances not affected if a hose ruptures or seal leaks | class II construction | P |
| | In case of doubt, test as described | | P |
| | Electrical insulation not affected by snow penetration to appliance enclosure (IEC 60335-2-40) | | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.7 | Adequate safeguards against the risk of excessive pressure in appliances containing liquid or gases or having steam-producing devices | | N/A |
| 22.8 | Electrical connections not subject to pulling during cleaning of compartments to which access can be gained without the aid of a tool, and that are likely to be cleaned in normal use | | P |
| 22.9 | Insulation, internal wiring, windings, commutators and slip rings not exposed to oil, grease or similar substances, unless | | P |
| | the substance has adequate insulating properties | | N/A |
| 22.10 | Not possible to reset voltage-maintained non-self-resetting thermal cut-outs by the operation of an automatic switching device incorporated within the appliance, if: | | N/A |
| | - a non-self-resetting thermal cut-out is required by the standard, and | | N/A |
| | - a voltage maintained non-self-resetting thermal cut-out is used to meet it | | N/A |
| | Non-self-resetting thermal motor protectors have a trip-free action, unless | | N/A |
| | they are voltage maintained | | N/A |
| | Reset buttons of non-self-resetting controls so located or protected that accidental resetting is unlikely | | N/A |
| 22.11 | Reliable fixing of non-detachable parts that provide the necessary degree of protection against electric shock, moisture or contact with moving parts | | P |
| | Obvious locked position of snap-in devices used for fixing such parts | | P |
| | No deterioration of the fixing properties of snap-in devices used in parts that are likely to be removed during installation or servicing | | P |
| | Tests as described | | P |
| 22.12 | Handles, knobs etc. fixed in a reliable manner | | N/A |
| | Fixing in wrong position of handles, knobs etc. indicating position of switches or similar components not possible | | N/A |
| | Axial force 15 N applied to parts, the shape being so that an axial pull is unlikely to be applied | | N/A |
| | Axial force 30 N applied to parts, the shape being so that an axial pull is likely to be applied | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.13 | Unlikely that handles, when gripped as in normal use, make the operator's hand touch parts having a temperature rise exceeding the value specified for handles which are held for short periods only | | N/A |
| 22.14 | No ragged or sharp edges creating a hazard for the user in normal use, or during user maintenance | | P |
| | No exposed pointed ends of self-tapping screws or other fasteners, likely to be touched by the user in normal use or during user maintenance | | P |
| 22.15 | Storage hooks and the like for flexible cords smooth and well rounded | | N/A |
| 22.16 | Automatic cord reels cause no undue abrasion or damage to the sheath of the flexible cord, no breakage of conductors strands and no undue wear of contacts | | N/A |
| | Cord reel tested with 6000 operations, as specified | | N/A |
| | Electric strength test of 16.3, voltage of 1000 V applied | | N/A |
| 22.17 | Spacers not removable from the outside by hand or by means of a screwdriver or a spanner | | N/A |
| 22.18 | Current-carrying parts and other metal parts resistant to corrosion | | P |
| 22.19 | Driving belts not relied upon to provide the required level of insulation, unless | | N/A |
| | constructed to prevent inappropriate replacement | | N/A |
| 22.20 | Direct contact between live parts and thermal insulation effectively prevented, unless | | N/A |
| | material used is non-corrosive, non-hygroscopic and non-combustible | | P |
| 22.21 | Wood, cotton, silk, ordinary paper and fibrous or hygroscopic material not used as insulation, unless | | P |
| | impregnated | | N/A |
| | This requirement does not apply to magnesium oxide and mineral ceramic fibres used for the electrical insulation of heating elements | | N/A |
| 22.22 | Appliances not containing asbestos | | P |
| 22.23 | Oils containing polychlorinated biphenyl (PCB) not used | | P |
| 22.24 | Bare heating elements adequately supported to prevent contact with accessible metal parts in case of rupture or sagging (IEC 60335-2-40) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Bare heating elements only used with metal enclosures (wood or composite enclosures not allowed) (IEC 60335-2-40) | | N/A |
| 22.25 | Sagging heating conductors, except in class III appliances or class III constructions that do not contain live parts, cannot come into contact with accessible metal parts | | N/A |
| 22.26 | For class III constructions the insulation between parts operating at safety extra-low voltage and other live parts complies with the requirements for double or reinforced insulation | | N/A |
| 22.27 | Parts connected by protective impedance separated by double or reinforced insulation | | N/A |
| 22.28 | Metal parts of class II appliances conductively connected to gas pipes or in contact with water, separated from live parts by double or reinforced insulation | | N/A |
| 22.29 | Class II appliances permanently connected to fixed wiring so constructed that the required degree of access to live parts is maintained after installation | Class I appliance | N/A |
| 22.30 | Parts serving as supplementary or reinforced insulation fixed so that they cannot be removed without being seriously damaged, or | | P |
| | so constructed that they cannot be replaced in an incorrect position, and so that if they are omitted, the appliance is rendered inoperable or manifestly incomplete | | P |
| 22.31 | Neither clearances nor creepage distances over supplementary and reinforced insulation reduced below values specified in clause 29 as a result of wear | | P |
| | Neither clearances nor creepage distances between live parts and accessible parts reduced below values for supplementary insulation if wires, screws etc. become loose | | P |
| 22.32 | Supplementary and reinforced insulation constructed or protected against pollution so that clearances or creepage distances are not reduced below the values in clause 29 | | P |
| | Supplementary insulation of natural or synthetic rubber resistant to ageing, or arranged and dimensioned so that creepage distances are not reduced below values specified in 29.2 | | N/A |
| | Ceramic material not tightly sintered, similar materials or beads alone not used as supplementary or reinforced insulation | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Insulating material in which heating conductors are embedded is considered to be basic insulation, not reinforced insulation | | N/A |
| | Oxygen bomb test at 70 °C for 96 h and 16 h at room temperature | | N/A |
| 22.33 | Conductive liquids that are or may become accessible in normal use and conductive liquids that are in contact with unearthed accessible metal parts are not in direct contact with live parts | | P |
| | Electrodes not used for heating liquids | | N/A |
| | For class II constructions, conductive liquids that are or may become accessible in normal use and conductive liquids that are in contact with unearthed accessible metal parts, not in direct contact with basic or reinforced insulation, unless | | N/A |
| | the reinforced insulation consists of at least 3 layers | | N/A |
| | For class II constructions, conductive liquids which are in contact with live parts, not in direct contact with reinforced insulation, unless | | N/A |
| | the reinforced insulation consists of at least 3 layers | | P |
| | An air layer not used as basic or supplementary insulation in a double insulation system if likely to be bridged by leaking liquid | | N/A |
| 22.34 | Shafts of operating knobs, handles, levers etc. not live, unless | | N/A |
| | the shaft is not accessible when the part is removed | | N/A |
| 22.35 | For other than class III constructions, handles, levers and knobs, held or actuated in normal use, not becoming live in the event of a failure of basic insulation | | N/A |
| | Such parts being of metal, and their shafts or fixings are likely to become live in the event of a failure of basic insulation, are either adequately covered by insulation material or their accessible parts are separated from their shafts or fixings by supplementary insulation | | N/A |
| | This requirement does not apply to handles, levers and knobs on stationary appliances, other than those of electrical components, provided they are reliably connected to an earthing terminal or earthing contact, or separated from live parts by earthed metal | | N/A |
| | Insulating material covering metal handles, levers and knobs withstand the electric strength test of 16.3 for supplementary insulation | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.36 | For appliances other than class III, handles continuously held in the hand in normal use so constructed that when gripped as in normal use, the operators hand is not likely to touch metal parts, unless | | N/A |
| | they are separated from live parts by double or reinforced insulation | | N/A |
| 22.37 | Capacitors in class II appliances not connected to accessible metal parts and their casings, if of metal, separated from accessible metal parts by supplementary insulation, unless | | N/A |
| | the capacitors comply with 22.42 | | N/A |
| 22.38 | Capacitors not connected between the contacts of a thermal cut-out | | P |
| 22.39 | Lamp holders used only for the connection of lamps | | N/A |
| 22.40 | Motor-operated appliances and combined appliances intended to be moved while in operation, or having accessible moving parts, fitted with a switch to control the motor. The actuating member of the switch being easily visible and accessible | | N/A |
| | If the appliance cannot operate continuously, automatically or remotely without giving rise to a hazard, appliances for remote operation being fitted with a switch for stopping the operation. The actuating member of the switch being easily visible and accessible | | N/A |
| 22.41 | No components, other than lamps, containing mercury | | P |
| 22.42 | Protective impedance consisting of at least two separate components | | N/A |
| | Values specified in 8.1.4 not exceeded if any one of the components are short-circuited or open-circuited | | N/A |
| | Resistors checked by the test of 14.1 a) in IEC 60065 | | N/A |
| | Capacitors checked by the tests for class Y capacitors in IEC 60384-14 | | N/A |
| 22.43 | Appliances adjustable for different voltages, accidental changing of the setting of the voltage unlikely to occur | | N/A |
| 22.44 | Appliances not having an enclosure that is shaped or decorated like a toy | | P |
| 22.45 | When air is used as reinforced insulation, clearances not reduced below the values specified in 29.1.3 due to deformation as a result of an external force applied to the enclosure | | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.46 | For programmable protective electronic circuits used to ensure compliance with the standard, the software contains measures to control the fault/error conditions in table R.1 | | N/A |
| | Software that contains measures to control the fault/error conditions specified in table R.2 is to be specified in parts 2 for particular constructions or to address specific hazards | | N/A |
| | These requirements are not applicable to software used for functional purpose or compliance with clause 11 | | N/A |
| 22.47 | Appliances connected to the water mains withstand the water pressure expected in normal use | | P |
| | No leakage from any part, including any inlet water hose | | P |
| 22.48 | Appliances connected to the water mains constructed to prevent backsiphonage of non-potable water | | N/A |
| 22.49 | For remote operation, the duration of operation is to be set before the appliance can be started, unless | | N/A |
| | the appliance switches off automatically or can operate continuously without hazard | | N/A |
| 22.50 | Controls incorporated in the appliance take priority over controls actuated by remote operation | | N/A |
| 22.51 | There is a control on the appliance manually adjusted to the setting for remote operation before the appliance can be operated in this mode | | N/A |
| | There is a visual indication showing that the appliance is adjusted for remote operation | | N/A |
| | These requirements not necessary on appliances that can operate as follows, without giving rise to a hazard: | | - |
| | - continuously, or | | N/A |
| | - automatically, or | | N/A |
| | - remotely | | N/A |
| 22.52 | Socket-outlets on appliances accessible to the user in accordance with the socket-outlet system used in the country in which the appliance is sold | | N/A |
| 22.101 | Appliances intended to be fixed, securely fixed (IEC 60335-2-40) | | P |
| 22.102.1 | At least two thermal cut-outs in appliances with supplementary heating elements for air (first one be self-resetting and other non-self-resetting thermal cut-out) (IEC 60335-2-40/A2) | For some models (see attachment No.4 for details) | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|---------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.102.2 | Appliances provided with supplementary heaters for water incorporate non-self-resetting thermal cut-out, providing all-pole disconnection that operates separately from water thermostats (IEC 60335-2-40/A2) | | N/A |
| | However, for appliances intended to be connected to fixed wiring, the neutral conductor need not be disconnected (IEC 60335-2-40/A2) | | N/A |
| 22.102.3 | Thermal cut-outs of capillary type open in event of leakage from capillary tube (IEC 60335-2-40/A2) | | N/A |
| 22.103 | Non-self-resetting cut-outs independent of other control devices (IEC 60335-2-40) | | P |
| 22.104 | Containers of sanitary hot water heat pumps withstand twice permissible operating pressure in closed containers (IEC 60335-2-40) or | | N/A |
| | 0,15 MPa in open containers (IEC 60335-2-40) | | N/A |
| | without leakage or rupture (IEC 60335-2-40) | | N/A |
| 22.105 | Air or vapour cushion in closed containers not exceeding 10 % (IEC 60335-2-40) | | N/A |
| 22.106 | Pressure relief devices operating at 0,1 MPa over permissible operating pressure (IEC 60335-2-40) | | N/A |
| 22.107 | Water outlet systems of open containers free from obstruction causing over-pressure (IEC 60335-2-40) | | N/A |
| | Vented containers of sanitary hot water heat pumps always open to the atmosphere through appropriate aperture (IEC 60335-2-40) | | N/A |
| 22.108 | Not vented open containers subjected to test in accordance with clause 22.104 to vacuum of 33 kPa for 15 min (IEC 60335-2-40) | | N/A |
| | Container show no deformation which result in a hazard (IEC 60335-2-40) | | N/A |
| 22.109 | Replacement of non-self-resetting thermal cut-outs does not damage other connections (IEC 60335-2-40) | Not for replacement | N/A |
| 22.110 | Non-self-resetting thermal cut-outs operate without short-circuiting live parts of different potential and without causing contact between live parts and enclosure (IEC 60335-2-40) | | P |
| | Test repeated five times without blowing 3 A fuse which connects appliance to earth (IEC 60335-2-40) | | P |
| | Electric strength test as specified in clause 16.3 for supplementary heating elements (IEC 60335-2-40) | | P |
| 22.111 | Manual resetting of thermostats not necessary after power supply interruption (IEC 60335-2-40) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.112 | Construction of refrigerating system comply with requirements of Section 3 of ISO 5149 (IEC 60335-2-40/A1) | | P |
| 22.113 | Flammable refrigerant used, refrigerant tubing protected or enclosed to avoid mechanical damage (IEC 60335-2-40/A1) | | N/A |
| | Tubing protected to extent that it will not be handled or used for carrying during moving of product (IEC 60335-2-40/A1) | | N/A |
| | Tubing located within confines of cabinet considered to be protected from mechanical damage (IEC 60335-2-40/A1) | | N/A |
| 22.114 | Flammable refrigerant used, low temperature solder alloys, such as lead/tin alloys, not acceptable for pipe connections (IEC 60335-2-40/A1) | | N/A |
| 22.115 | Total refrigerant mass (M) of all refrigerating systems within appliance employing flammable refrigerants, not exceed m_3 defined in annex GG (IEC 60335-2-40/A1) | | N/A |
| 22.116 | Appliances using flammable refrigerants constructed that any leaked refrigerant not flow or stagnate so as to cause fire or explosion hazard in areas within appliance where electrical components, which could be a source of ignition and which could function under normal conditions or in event of leak, fitted (IEC 60335-2-40/A1) | | N/A |
| | Separate components, such as thermostats, which charged with less than 0,5 g of flammable gas not considered to cause fire or explosion hazard in event of leakage of gas within component itself (IEC 60335-2-40/A1) | | N/A |
| | All electrical components that could be a source of ignition and which could function under normal conditions or in the event of a leak, comply with one of the following (IEC 60335-2-40/A1): | | - |
| | - IEC 60079-15:2001, Cl. 9 to 26, for group IIA gases or the refrigerant used or an applicable standard that makes electrical components suitable for use in Zone 2, 1 or 0 as defined in IEC 60079-14 (IEC 60335-2-40/A1) | | N/A |
| | - Not be located in an area where a potentially flammable gas mixture will accumulate as demonstrated by the test of annex FF (IEC 60335-2-40/A1) | | N/A |
| | - Be located in an enclosure. The enclosure containing the electrical components comply with IEC 60079-15:2001 for enclosures suitable for use with group IIA gases or the refrigerant used (IEC 60335-2-40/A1) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 22.117 | Temperatures on surfaces that exposed to leakage of flammable refrigerants not exceed auto-ignition temperature of refrigerant reduced by 100 K; some typical values given in annex BB (IEC 60335-2-40/A1) | | N/A |
| 22.118 | Flammable refrigerant used, all appliances charged with refrigerant at manufacturing location or charged on site as recommended by manufacturer (IEC 60335-2-40/A1) | | N/A |
| | Part of appliance that charged on site, which requires brazing or welding in installation not shipped with flammable refrigerant charge. Joints made in installation between parts of refrigerating system, with at least one part charged, made in accordance with following (IEC 60335-2-40/A1): | | - |
| | - A brazed, welded, or mechanical connection shall be made before opening the valves to permit refrigerant to flow between the refrigerating system parts. A vacuum valve shall be provided to evacuate the interconnecting pipe and/or any uncharged refrigerating system part (IEC 60335-2-40/A1) | | N/A |
| | - Reusable mechanical connectors and flared joints are not allowed indoors (IEC 60335-2-40/A1) | | N/A |
| | - Refrigerant tubing shall be protected or enclosed to avoid damage (IEC 60335-2-40/A1) | | N/A |
| | Flexible refrigerant connectors (such as connecting lines between the indoor and outdoor unit) that may be displaced during normal operations shall be protected against mechanical damage (IEC 60335-2-40/A1) | | N/A |
| 23 | INTERNAL WIRING | | - |
| 23.1 | Wireways smooth and free from sharp edges | | P |
| | Wires protected against contact with burrs, cooling fins etc. | | P |
| | Wire holes in metal well-rounded or provided with bushings | | P |
| | Wiring effectively prevented from coming into contact with moving parts | | P |
| 23.2 | Beads etc. on live wires cannot change their position, and are not resting on sharp edges | | N/A |
| | Beads inside flexible metal conduits contained within an insulating sleeve | | N/A |
| 23.3 | Electrical connections and internal conductors movable relatively to each other not exposed to undue stress | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Flexible metallic tubes not causing damage to insulation of conductors | | N/A |
| | Open-coil springs not used | | N/A |
| | Adequate insulating lining provided inside a coiled spring, the turns of which touch one another | | N/A |
| | No damage after 10 000 flexings for conductors flexed during normal use, or | | N/A |
| | 100 flexings for conductors flexed during user maintenance | | N/A |
| | Electric strength test of 16.3, 1000 V between live parts and accessible metal parts | | N/A |
| | Not more than 10 % of the strands of any conductor broken, and | | N/A |
| | not more than 30 % for wiring supplying circuits that consume no more than 15 W | | N/A |
| 23.4 | Bare internal wiring sufficiently rigid and fixed | | P |
| 23.5 | The insulation of internal wiring subjected to the supply mains voltage withstanding the electrical stress likely to occur in normal use | | P |
| | Basic insulation electrically equivalent to the basic insulation of cords complying with IEC 60227 or IEC 60245, or | | P |
| | no breakdown when a voltage of 2000 V is applied for 15 min between the conductor and metal foil wrapped around the insulation | | P |
| 23.6 | Sleeving used as supplementary insulation on internal wiring retained in position by clamping at both ends, or | | P |
| | be such that it can only be removed by breaking or cutting | | P |
| 23.7 | The colour combination green/yellow only used for earthing conductors | | P |
| 23.8 | Aluminium wires not used for internal wiring | | P |
| 23.9 | Stranded conductors not consolidated by soldering where they are subjected to contact pressure, unless | | P |
| | the contact pressure is provided by spring terminals | | N/A |
| 23.10 | The insulation and sheath of internal wiring, incorporated in external hoses for the connection of an appliance to the water mains, at least equivalent to that of light polyvinyl chloride sheathed flexible cord (60227 IEC 52) | | N/A |
| 24 | COMPONENTS | | - |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 24.1 | Components comply with safety requirements in relevant IEC standards | | P |
| | List of components | (see appended table) | P |
| | If components have not been tested and found to comply with relevant IEC standard for the number of cycles specified, they are tested in accordance with 24.1.1 to 24.1.9 | | N/A |
| | For components mentioned in 24.1.1 to 24.1.9 no additional tests specified in the relevant component standard are necessary other than those specified in 24.1.1 to 24.1.9 | | N/A |
| | Components not tested and found to comply with relevant IEC standard and components not marked or not used in accordance with its marking, tested under the conditions occurring in the appliance | | P |
| | Lampholders and starterholders that have not being tested and found to comply with the relevant IEC standard, tested as a part of the appliance and additionally according to the gauging and interchangeability requirements of the relevant IEC standard | | N/A |
| | No additional tests specified for nationally standardized plugs such as those detailed in IEC/TR 60083 or connectors complying with the standard sheets of IEC 60320-1 and IEC 60309 | | N/A |
| | Motor-compressors not tested according to IEC 60335-2-34 (not necessary to meet all requirements of IEC 60335-2-34) (IEC 60335-2-40) | | N/A |
| 24.1.1 | Capacitors likely to be permanently subjected to the supply voltage and used for radio interference suppression or for voltage dividing, complying with IEC 60384-14 | | P |
| | If the capacitors have to be tested, they are tested according to annex F | | N/A |
| 24.1.2 | Safety isolating transformers complying with IEC 61558-2-6 | | N/A |
| | If they have to be tested, they are tested according to annex G | | N/A |
| 24.1.3 | Switches complying with IEC 61058-1, the number of cycles of operation being at least 10 000 | | N/A |
| | If they have to be tested, they are tested according to annex H | | N/A |
| | If the switch operates a relay or contactor, the complete switching system is subjected to the test | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | If the switch only operates a motor starting relay complying with IEC 60730-2-10 with the number of cycles of a least 10 000 as specified, the complete switching system need not be tested | | N/A |
| 24.1.4 | Automatic controls complying with IEC 60730-1 with the relevant part 2. The number of cycles of operation being at least: | | - |
| | - thermostats:..... 10 000 | | N/A |
| | - temperature limiters:..... 1 000 | | N/A |
| | - self-resetting thermal cut-outs:..... 300 | | N/A |
| | - voltage maintained non-self-resetting thermal cut-outs: 1 000 | | N/A |
| | - other non-self-resetting thermal cut-outs: 30 | | N/A |
| | - timers: 3 000 | | N/A |
| | - energy regulators:.....10 000 | | N/A |
| | - thermostats which control motor-compressor (IEC/EN 60335-2-40):.....100 000 | | N/A |
| | - motor-compressor starting relays (IEC/EN 60335-2-40):.....100 000 | | N/A |
| | - automatic thermal motor-protectors for hermetic and semi-hermetic type motor-compressors (not less than number of operations during locked rotor test) (IEC/EN 60335-2-40):.....min 2000 | | N/A |
| | - manual reset thermal motor-protectors for hermetic and semi-hermetic type motor-compressors (IEC/EN 60335-2-40):.....50 | | N/A |
| | - other automatic thermal motor-protectors (IEC/EN 60335-2-40):.....2000 | Approved | P |
| | - other manual reset thermal motor-protectors (IEC/EN 60335-2-40):.....30 | | N/A |
| | The number of cycles for controls operating during clause 11 need not be declared, if the appliance meets the requirements of this standard when they are short-circuited | | N/A |
| | Thermal motor protectors are tested in combination with their motor under the conditions specified in annex D | | N/A |
| | For water valves containing live parts and that are incorporated in external hoses for connection of an appliance to the water mains, the degree of protection declared for subclause 6.5.2 of IEC 60730-2-8 is IPX7 | | N/A |
| 24.1.5 | Appliance couplers complying with IEC 60320-1 | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | However, for appliances classified higher than IPX0, the appliance couplers complying with IEC 60320-2-3 | | N/A |
| | Interconnection couplers complying with IEC 60320-2-2 | | N/A |
| 24.1.6 | Small lamp holders similar to E10 lampholders complying with IEC 60238, the requirements for E10 lampholders being applicable | | N/A |
| 24.1.7 | For remote operation of the appliance via a telecommunication network, the relevant standard for the telecommunication interface circuitry in the appliance is IEC 62151 | | N/A |
| 24.1.8 | The relevant standard for thermal links is IEC 60691 | | P |
| | Thermal links not complying with IEC 60691 are considered to be an intentionally weak part for the purposes of clause 19 | | N/A |
| 24.1.9 | Contactors and relays, other than motor starting relays, tested as part of the appliance | | P |
| | They are also tested in accordance with clause 17 of IEC 60730-1, the number of cycles of operations in 24.1.4 selected according to the contactor or relay function in the appliance.....: | | P |
| 24.2 | Appliances not fitted with: | | - |
| | - switches or automatic controls in flexible cords | | P |
| | - devices causing the protective device in the fixed wiring to operate in the event of a fault in the appliance | | P |
| | - thermal cut-outs that can be reset by soldering, unless | | N/A |
| | the solder has a melting point of at least 230 °C | | N/A |
| 24.3 | Switches intended for all-pole disconnection of stationary appliances are directly connected to the supply terminals and have a contact separation in all poles, providing full disconnection under overvoltage category III conditions | | P |
| 24.4 | Plugs and socket-outlets for extra-low voltage circuits and heating elements, not interchangeable with plugs and socket-outlets listed in IEC/TR 60083 or IEC 60906-1 or with connectors and appliance inlets complying with the standard sheets of IEC 60320-1 | | N/A |
| 24.5 | Capacitors in auxiliary windings of motors marked with their rated voltage and capacitance, and used accordingly | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Voltage across capacitors in series with a motor winding does not exceed 1,1 times rated voltage, when the appliance is supplied at 1,1 times rated voltage under minimum load | The Max. measured value is 441,7V | P |
| 24.6 | Working voltage of motors connected to the supply mains and having basic insulation that is inadequate for the rated voltage of the appliance, not exceeding 42 V | | N/A |
| | In addition, the motors comply with the requirements of annex I | | N/A |
| 24.7 | Detachable hose-sets for connection of appliances to the water mains comply with IEC 61770 | | N/A |
| | They are supplied with the appliance | | N/A |
| | Appliances intended to be permanently connected to the water mains not connected by a detachable hose-set | | N/A |
| 24.8 | Motor running capacitors in appliances for which 30.2.3 is applicable and that are permanently connected in series with a motor winding, not causing a hazard in event of a failure | | P |
| | One or more of the following conditions are to be met: | | - |
| | - the capacitors are of class P2 according to IEC 60252-1 | | P |
| | - the capacitors are housed within a metallic or ceramic enclosure | | P |
| | - the distance of separation of the outer surface to adjacent non-metallic parts exceeds 50 mm | | N/A |
| | - adjacent non-metallic parts within 50 mm withstand the needle-flame test of annex E | | N/A |
| | - adjacent non-metallic parts within 50 mm classified as at least V-1 according to IEC 60695-11-10 | | N/A |
| 24.101 | Replaceable parts of thermal control devices identified by marking (IEC 60335-2-40) | | N/A |
| 25 | SUPPLY CONNECTION AND EXTERNAL FLEXIBLE CORDS | | - |
| 25.1 | Appliance not intended for permanent connection to fixed wiring, means for connection to the supply: | | - |
| | - supply cord fitted with a plug, | Fixed wiring | N/A |
| | - an appliance inlet having at least the same degree of protection against moisture as required for the appliance, or | | N/A |
| | - pins for insertion into socket-outlets | | N/A |
| | Supply cord fitted with plug provided, if (IEC 60335-2-40): | | - |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - appliance only for indoor use (IEC 60335-2-40), | | N/A |
| | - marked with rating of 25 A or less and (IEC 60335-2-40) | | N/A |
| | - complies with code requirements of country where it will be used (IEC 60335-2-40). | | N/A |
| | Appliance inlet not allowed (IEC 60335-2-40) | | N/A |
| 25.2 | Appliance not provided with more than one means of connection to the supply mains | | P |
| | Stationary appliance for multiple supply may be provided with more than one means of connection, provided electric strength test of 1250 V for 1 min between each means of connection causes no breakdown | | N/A |
| 25.3 | Appliance intended to be permanently connected to fixed wiring provided with one of the following means for connection to the supply mains: | | - |
| | - a set of terminals allowing the connection of a flexible cord | | P |
| | - a fitted supply cord | | N/A |
| | - a set of supply leads accommodated in a suitable compartment | | N/A |
| | - a set of terminals for the connection of cables of fixed wiring, cross-sectional areas specified in 26.6, and the appliance allows the connection of the supply conductors after the appliance has been fixed to its support | | P |
| | - a set of terminals and cable entries, conduit entries, knock-outs or glands, allowing connection of appropriate types of cable or conduit, and the appliance allows the connection of the supply conductors after the appliance has been fixed to its support | | N/A |
| | For a fixed appliance constructed so that parts can be removed to facilitate easy installation, this requirement is met if it is possible to connect the fixed wiring without difficulty after a part of the appliance has been fixed to its support | | N/A |
| 25.4 | Cable and conduit entries, rated current of appliance not exceeding 16 A, dimension according to table 10 (mm) | Stated in user manual | P |
| | Introduction of conduit or cable does not reduce clearances or creepage distances below values specified in clause 29 | | P |
| 25.5 | Method for assembling the supply cord to the appliance: | | - |
| | - type X attachment | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - type Y attachment | | P |
| | - type Z attachment, if allowed in relevant part 2 | | N/A |
| | Type X attachment, other than those with a specially prepared cord, not used for flat twin tinsel cords | | N/A |
| | For multi-phase appliances supplied with a supply cord and that are intended to be permanently connected to fixed wiring, the supply cord is assembled to the appliance by type Y attachment | | N/A |
| 25.6 | Plugs fitted with only one flexible cord | | N/A |
| 25.7 | Supply cords, other than for class III appliances, being one of the following types: | | - |
| | - rubber sheathed (at least 60245 IEC 53) | | N/A |
| | - polychloroprene sheathed (at least 60245 IEC 57) | | P |
| | - cross-linked polyvinyl chloride sheathed (at least 60245 IEC 88) | | N/A |
| | - polyvinyl chloride sheathed. Not used if they are likely to touch metal parts having a temperature rise exceeding 75 K during the test of clause 11 | | - |
| | - light polyvinyl chloride sheathed cord (60227 IEC 52), for appliances not exceeding 3 kg | | N/A |
| | - ordinary polyvinyl chloride sheathed cord (60227 IEC 53), for other appliances | | N/A |
| | - heat resistant polyvinyl chloride sheathed. Not used for type X attachment other than specially prepared cords | | - |
| | - heat-resistant light polyvinyl chloride sheathed cord (60227 IEC 56), for appliances not exceeding 3 kg | | N/A |
| | - heat-resistant polyvinyl chloride sheathed cord (60227 IEC 57), for other appliances | | N/A |
| | Supply cords for class III appliances adequately insulated | | N/A |
| | Test with 500 V for 2 min for supply cords of class III appliances that contain live parts | | N/A |
| | Supply cords for outdoor use not lighter than polychloroprene sheathed flexible cord (60245 IEC 57) (IEC 60335-2-40) | Stated in the manual | P |
| 25.8 | Nominal cross-sectional area of supply cords not less than table 11; rated current (A); cross-sectional area (mm ²).....: | Stated in the manual | P |
| 25.9 | Supply cords not in contact with sharp points or edges | | P |
| 25.10 | Supply cord of class I appliances have a green/yellow core for earthing | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 25.11 | Conductors of supply cords not consolidated by soldering where they are subject to contact pressure, unless | | P |
| | the contact pressure is provided by spring terminals | | N/A |
| 25.12 | Insulation of the supply cord not damaged when moulding the cord to part of the enclosure | | N/A |
| 25.13 | Inlet openings so constructed as to prevent damage to the supply cord | | P |
| | If the enclosure at the inlet opening is not of insulating material, a non-detachable lining or bushing complying with 29.3 for supplementary insulation provided | | N/A |
| | If unsheathed supply cord, a similar additional bushing or lining is required, unless the appliance is | | N/A |
| | class 0, or | | N/A |
| | a class III appliance not containing live parts | | N/A |
| 25.14 | Supply cords moved while in operation adequately protected against excessive flexing | | N/A |
| | Flexing test, as described: | | - |
| | - applied force (N).....: | | N/A |
| | - number of flexings.....: | | N/A |
| | The test does not result in: | | - |
| | - short-circuit between the conductors, such that the current exceeds a value of twice the rated current | | N/A |
| | - breakage of more than 10 % of the strands of any conductor | | N/A |
| | - separation of the conductor from its terminal | | N/A |
| | - loosening of any cord guard | | N/A |
| | - damage to the cord or the cord guard | | N/A |
| | - broken strands piercing the insulation and becoming accessible | | N/A |
| 25.15 | For appliances with supply cord and appliances to be permanently connected to fixed wiring by a flexible cord, conductors of the supply cord relieved from strain, twisting and abrasion by use of cord anchorage | | P |
| | The cord cannot be pushed into the appliance to such an extent that the cord or internal parts of the appliance can be damaged | | P |
| | Pull and torque test of supply cord, values shown in table 12: mass (kg); pull (N); torque (not on automatic cord reel) (Nm) | 100N; 0,35Nm | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Cord not damaged and max. 2 mm displacement of the cord | | P |
| 25.16 | Cord anchorages for type X attachments constructed and located so that: | | - |
| | - replacement of the cord is easily possible | | N/A |
| | - it is clear how the relief from strain and the prevention of twisting are obtained | | N/A |
| | - they are suitable for different types of supply cord | | N/A |
| | - cord cannot touch the clamping screws of cord anchorage if these screws are accessible, unless | | N/A |
| | they are separated from accessible metal parts by supplementary insulation | | N/A |
| | - the cord is not clamped by a metal screw which bears directly on the cord | | N/A |
| | - at least one part of the cord anchorage securely fixed to the appliance, unless | | N/A |
| | it is part of a specially prepared cord | | N/A |
| | - screws which have to be operated when replacing the cord do not fix any other component, unless | | N/A |
| | the appliance becomes inoperative or incomplete or the parts cannot be removed without a tool | | N/A |
| | - if labyrinths can be bypassed the test of 25.15 is nevertheless withstood | | N/A |
| | - for class 0, 0I and I appliances they are of insulating material or are provided with an insulating lining, unless | | N/A |
| | failure of the insulation of the cord does not make accessible metal parts live | | N/A |
| | - for class II appliances they are of insulating material, or | | N/A |
| | if of metal, they are insulated from accessible metal parts by supplementary insulation | | N/A |
| | After the test of 25.15, under the conditions specified, the conductors have not moved by more than 1 mm in the terminals | | N/A |
| 25.17 | Adequate cord anchorages for type Y and Z attachment, test with the cord supplied with the appliance | | P |
| 25.18 | Cord anchorages only accessible with the aid of a tool, or | | P |
| | Constructed so that the cord can only be fitted with the aid of a tool | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 25.19 | Type X attachment, glands not used as cord anchorage in portable appliances | | N/A |
| | Tying the cord into a knot or tying the cord with string not used | | N/A |
| 25.20 | The insulated conductors of the supply cord for type Y and Z attachment additionally insulated from accessible metal parts | | P |
| 25.21 | Space for supply cord for type X attachment or for connection of fixed wiring constructed: | | - |
| | - to permit checking of conductors with respect to correct positioning and connection before fitting any cover | | P |
| | - so there is no risk of damage to the conductors or their insulation when fitting the cover | | P |
| | - for portable appliances, so that the uninsulated end of a conductor, if it becomes free from the terminal, prevented from contact with accessible metal parts | | N/A |
| | 2 N test to the conductor for portable appliances; no contact with accessible metal parts | | N/A |
| 25.22 | Appliance inlets: | | - |
| | - live parts not accessible during insertion or removal | | N/A |
| | Requirement not applicable to appliance inlets complying with IEC 60320-1 | | N/A |
| | - connector can be inserted without difficulty | | N/A |
| | - the appliance is not supported by the connector | | N/A |
| | - not for cold conditions if temp. rise of external metal parts exceeds 75 K during clause 11, unless | | N/A |
| | the supply cord is unlikely to touch such metal parts | | N/A |
| 25.23 | Interconnection cords comply with the requirements for the supply cord, except that: | | P |
| | - the cross-sectional area of the conductors is determined on the basis of the maximum current during clause 11 | | P |
| | - the thickness of the insulation may be reduced | | N/A |
| | If necessary, electric strength test of 16.3 | | N/A |
| 25.24 | Interconnection cords not detachable without the aid of a tool if compliance with this standard is impaired when they are disconnected | | P |
| 25.25 | Dimensions of pins that are inserted into socket-outlets compatible with the dimensions of the relevant socket-outlet. | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Dimensions of pins and engagement face in accordance with the dimensions of the relevant plug in IEC/TR 60083 | | N/A |
| 26 | TERMINALS FOR EXTERNAL CONDUCTORS | | - |
| 26.1 | Appliances provided with terminals or equally effective devices for connection of external conductors | | P |
| | Terminals only accessible after removal of a non-detachable cover, except | | P |
| | for class III appliances that do not contain live parts | | N/A |
| | Earthing terminals may be accessible if a tool is required to make the connections and means are provided to clamp the wire independently from its connection | | P |
| 26.2 | Appliances with type X attachment and appliances for the connection of cables to fixed wiring provided with terminals in which connections are made by means of screws, nuts or similar devices, unless | | N/A |
| | the connections are soldered | | N/A |
| | Screws and nuts not used to fix any other component, except | | N/A |
| | internal conductors, if so arranged that they are unlikely to be displaced when fitting the supply conductors | | N/A |
| | If soldered connections used, the conductor so positioned or fixed that reliance is not placed on soldering alone, unless | | N/A |
| | barriers provided so that neither clearances nor creepage distances between live parts and other metal parts reduced below the values for supplementary insulation if the conductor becomes free at the soldered joint | | N/A |
| 26.3 | Terminals for type X attachment and for connection of cables of fixed wiring so constructed that the conductor is clamped between metal surfaces with sufficient contact pressure but without damaging the conductor | | P |
| | Terminals fixed so that when the clamping means is tightened or loosened: | | - |
| | - the terminal does not become loose | | P |
| | - internal wiring is not subjected to stress | | P |
| | - neither clearances nor creepage distances are reduced below the values in clause 29 | | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|---|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Compliance checked by inspection and by the test of subclause 9.6 of IEC 60999-1, the torque applied being equal to two-thirds of the torque specified (Nm) | Nominal diameter of thread: 3,9mm; Screw category:II; Torque: 0,8Nm | P |
| | No deep or sharp indentations of the conductors | | P |
| 26.4 | Terminals for type X attachment, except those having a specially prepared cord and those for the connection of cables of fixed wiring, no special preparation of conductors such as by soldering, use of cable lugs, eyelets or similar, and | | N/A |
| | so constructed or placed that conductors prevented from slipping out when clamping screws or nuts are tightened | | N/A |
| 26.5 | Terminals for type X attachment so located or shielded that if a wire of a stranded conductor escapes, no risk of accidental connection to other parts that result in a hazard | | N/A |
| | Stranded conductor test, 8 mm insulation removed | | N/A |
| | No contact between live parts and accessible metal parts and, | | N/A |
| | for class II constructions, between live parts and metal parts separated from accessible metal parts by supplementary insulation only | | N/A |
| 26.6 | Terminals for type X attachment and for connection of cables of fixed wiring suitable for connection of conductors with cross-sectional area according to table 13; rated current (A); nominal cross-sectional area (mm ²)..... | Stated in the manual | P |
| | If a specially prepared cord is used, terminals need only be suitable for that cord | | N/A |
| 26.7 | Terminals for type X attachment, except in class III appliances not containing live parts, accessible after removal of a cover or part of the enclosure | | N/A |
| 26.8 | Terminals for the connection of fixed wiring, including the earthing terminal, located close to each other | | P |
| 26.9 | Terminals of the pillar type constructed and located as specified | | N/A |
| 26.10 | Terminals with screw clamping and screwless terminals not used for flat twin tinsel cords, unless | | P |
| | conductors ends fitted with means suitable for screw terminals | | N/A |
| | Pull test of 5 N to the connection | | N/A |
| 26.11 | For type Y and Z attachment, soldered, welded, crimped or similar connections may be used | | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | For class II appliances, the conductor so positioned or fixed that reliance is not placed on soldering, welding or crimping alone | | N/A |
| | If soldering, welding or crimping alone used, barriers provided so that clearances and creepage distances between live parts and other metal parts are not reduced below the values for supplementary insulation if the conductor becomes free | | N/A |
| 27 | PROVISION FOR EARTHING | | - |
| 27.1 | Accessible metal parts of class 0I and I appliances permanently and reliably connected to an earthing terminal or earthing contact of the appliance inlet | | P |
| | Earthing terminals and earthing contacts not connected to the neutral terminal | | P |
| | Class 0, II and III appliances have no provision for earthing | | N/A |
| | Safety extra-low voltage circuits not earthed, unless | | N/A |
| | protective extra-low voltage circuits | | N/A |
| 27.2 | Clamping means of earthing terminals adequately secured against accidental loosening | | P |
| | Terminals for the connection of external equipotential bonding conductors allow connection of conductors of 2,5 to 6 mm ² , and | | P |
| | do not provide earthing continuity between different parts of the appliance, and | | N/A |
| | conductors cannot be loosened without the aid of a tool | | P |
| 27.3 | For a detachable part having an earth connection and being plugged into another part of the appliance, the earth connection is made before and separated after current-carrying connections when removing the part | | N/A |
| | For appliances with supply cords, current-carrying conductors become taut before earthing conductor, if the cord slips out of the cord anchorage | | P |
| 27.4 | No risk of corrosion resulting from contact between parts of the earthing terminal and the copper of the earthing conductor or other metal | | P |
| | Parts providing earthing continuity, other than parts of a metal frame or enclosure, have adequate resistance to corrosion | | P |
| | If of steel, these parts provided with an electroplated coating with a thickness at least 5 µm | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Adequate protection against rusting of parts of coated or uncoated steel, only intended to provide or transmit contact pressure | | P |
| | In the body of the earthing terminal is a part of a frame or enclosure of aluminium or aluminium alloys, precautions taken to avoid risk of corrosion | | P |
| 27.5 | Low resistance of connection between earthing terminal and earthed metal parts | | P |
| | This requirement does not apply to connections providing earthing continuity in the protective extra-low voltage circuit, provided the clearances of basic insulation are based on the rated voltage of the appliance | | N/A |
| | Resistance not exceeding 0,1 Ω at the specified low-resistance test ().....: | 0,06 Ω max. | P |
| 27.6 | The printed conductors of printed circuit boards not used to provide earthing continuity in hand-held appliances. | | N/A |
| | They may be used to provide earthing continuity in other appliances if at least two tracks are used with independent soldering points and the appliance complies with 27.5 for each circuit | | N/A |
| 28 | SCREWS AND CONNECTIONS | | - |
| 28.1 | Fixings, electrical connections and connections providing earthing continuity withstand mechanical stresses | | P |
| | Screws not of soft metal liable to creep, such as zinc or aluminium | | P |
| | Diameter of screws of insulating material min. 3 mm | | N/A |
| | Screws of insulating material not used for any electrical connections or connections providing earthing continuity | | P |
| | Screws used for electrical connections or connections providing earthing continuity screwed into metal | | P |
| | Screws not of insulating material if their replacement by a metal screw can impair supplementary or reinforced insulation | | P |
| | For type X attachment, screws to be removed for replacement of supply cord or for user maintenance, not of insulating material if their replacement by a metal screw impairs basic insulation | | N/A |
| | For screws and nuts; torque-test as specified in table 14.....: | (see appended table) | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 28.2 | Electrical connections and connections providing earthing continuity constructed so that contact pressure is not transmitted through non-ceramic insulating material liable to shrink or distort, unless | | P |
| | there is resiliency in the metallic parts to compensate for shrinkage or distortion of the insulating material | | N/A |
| | This requirement does not apply to electrical connections in circuits of appliances for which: | | - |
| | - 30.2.2 is applicable and that carry a current not exceeding 0,5 A | | N/A |
| | - 30.2.3 is applicable and that carry a current not exceeding 0,2 A | | N/A |
| 28.3 | Space-threaded (sheet metal) screws only used for electrical connections if they clamp the parts together | | N/A |
| | Thread-cutting (self-tapping) screws and thread rolling screws only used for electrical connections if they generate a full form standard machine screw thread | | P |
| | Thread-cutting (self-tapping) screws not used if they are likely to be operated by the user or installer | | P |
| | Thread-cutting, thread rolling and space threaded screws may be used in connections providing earthing continuity provided it is not necessary to disturb the connection: | | - |
| | - in normal use, | | P |
| | - during user maintenance, | | P |
| | - when replacing a supply cord having a type X attachment, or | | N/A |
| | - during installation | | P |
| | At least two screws being used for each connection providing earthing continuity, unless | | P |
| | the screw forms a thread having a length of at least half the diameter of the screw | | P |
| 28.4 | Screws and nuts that make mechanical connection secured against loosening if they also make electrical connections or connections providing earthing continuity | | P |
| | This requirement does not apply to screws in the earthing circuit if at least two screws are used, or | | P |
| | if an alternative earthing circuit is provided | | N/A |
| | Rivets for electrical connections or connections providing earthing continuity secured against loosening if the connections are subjected to torsion | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 29 | CLEARANCES, CREEPAGE DISTANCES AND SOLID INSULATION | | - |
| | Clearances, creepage distances and solid insulation withstand electrical stress | | P |
| | For coatings used on printed circuits boards to protect the microenvironment (Type 1) or to provide basic insulation (Type 2), annex J applies.....: | | N/A |
| | The microenvironment is pollution degree 1 under type 1 protection | | N/A |
| | For type 2 protection, the spacing between the conductors before the protection is applied is not less than the values specified in Table 1 of IEC 60664-3 | | N/A |
| | These values apply to functional, basic, supplementary and reinforced insulation.....: | | N/A |
| | For motor-compressor not complying with IEC 60335-2-34, additions and modifications as specified (IEC 60335-2-40) | | N/A |
| 29.1 | Clearances not less than the values specified in table 16, taking into account the rated impulse voltage for the overvoltage categories of table 15, unless | (see appended table) | P |
| | for basic insulation and functional insulation they comply with the impulse voltage test of clause 14 | | N/A |
| | However, if the distances are affected by wear, distortion, movement of the parts or during assembly, the clearances for rated impulse voltages of 1500 V and above are increased by 0,5 mm and the impulse voltage test is not applicable | | N/A |
| | Impulse voltage test is not applicable: | | - |
| | - when the microenvironment is pollution degree 3, or | | P |
| | - for basic insulation of class 0 and class 01 appliances | | N/A |
| | Appliances are in overvoltage category II | | P |
| | A force of 2 N is applied to bare conductors, other than heating elements | | P |
| | A force of 30 N is applied to accessible surfaces | | P |
| 29.1.1 | Clearances of basic insulation withstand the overvoltages, taking into account the rated impulse voltage | | P |
| | The values of table 16 or the impulse voltage test of clause 14 are applicable.....: | (see appended table) | P |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Clearance at the terminals of tubular sheathed heating elements may be reduced to 1,0 mm if the microenvironment is pollution degree 1 | | N/A |
| | Lacquered conductors of windings considered to be bare conductors | | P |
| 29.1.2 | Clearances of supplementary insulation not less than those specified for basic insulation in table 16 | (see appended table) | P |
| 29.1.3 | Clearances of reinforced insulation not less than those specified for basic insulation in table 16, using the next higher step for rated impulse voltage | (see appended table) | P |
| | For double insulation, with no intermediate conductive part between basic and supplementary insulation, clearances are measured between live parts and the accessible surface, and the insulation system is treated as reinforced insulation | | N/A |
| 29.1.4 | Clearances for functional insulation are the largest values determined from: | | - |
| | - table 16 based on the rated impulse voltage.....: | (see appended table) | P |
| | - table F.7a in IEC 60664-1, frequency not exceeding 30 kHz | | P |
| | - clause 4 of IEC 60664-4, frequency exceeding 30 kHz | | N/A |
| | If values of table 16 are largest, the impulse voltage test of clause 14 may be applied instead, unless | | N/A |
| | the microenvironment is pollution degree 3, or | | P |
| | the distances can be affected by wear, distortion, movement of the parts or during assembly | | N/A |
| | However, clearances are not specified if the appliance complies with clause 19 with the functional insulation short-circuited | | N/A |
| | Lacquered conductors of windings considered to be bare conductors | | P |
| | However, clearances at crossover points are not measured | | P |
| | Clearance between surfaces of PTC heating elements may be reduced to 1mm | | N/A |
| 29.1.5 | Appliances having higher working voltages than rated voltage, clearances for basic insulation are the largest values determined from: | | - |
| | - table 16 based on the rated impulse voltage.....: | | P |
| | - table F.7a in IEC 60664-1, frequency not exceeding 30 kHz | | P |
| | - clause 4 of IEC 60664-4, frequency exceeding 30 kHz | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | If clearances for basic insulation are selected from Table F.7a of IEC 60664-1 or clause 4 of IEC 60664-4, the clearances of supplementary insulation are not less than those specified for basic insulation | | N/A |
| | If clearances for basic insulation are selected from Table F.7a of IEC 60664-1, the clearances of reinforced insulation dimensioned as specified in Table F.7a are to withstand 160% of the withstand voltage required for basic insulation | | N/A |
| | If clearances for basic insulation are selected from clause 4 of IEC 60664-4, the clearances of reinforced insulation are twice the value required for basic insulation | | N/A |
| | If the secondary winding of a step-down transformer is earthed, or if there is an earthed screen between the primary and secondary windings, clearances of basic insulation on the secondary side not less than those specified in table 16, but using the next lower step for rated impulse voltage | | N/A |
| | Circuits supplied with a voltage lower than rated voltage, clearances of functional insulation are based on the working voltage used as the rated voltage in table 15 | | P |
| 29.2 | Creepage distances not less than those appropriate for the working voltage, taking into account the material group and the pollution degree | (see appended table) | P |
| | Pollution degree 2 applies, unless | | N/A |
| | - precautions taken to protect the insulation; pollution degree 1 | | N/A |
| | - insulation subjected to conductive pollution; pollution degree 3 | | P |
| | A force of 2 N is applied to bare conductors, other than heating elements | | P |
| | A force of 30 N is applied to accessible surfaces | | P |
| | In a double insulation system, the working voltage for both the basic and supplementary insulation is taken as the working voltage across the complete double insulation system | | P |
| | Insulation located in airflow, pollution degree 3 unless (IEC 60335-2-40) | | P |
| | insulation enclosed or located so that unlikely to be exposed to pollution due to normal use (IEC 60335-2-40) | | P |
| 29.2.1 | Creepage distances of basic insulation not less than specified in table 17 | (see appended table) | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | However, if the working voltage is periodic and has a frequency exceeding 30 kHz, the creepage distances are also determined from table 2 of IEC 60664-4, these values being used if exceeding the values in table 17.....: | | N/A |
| | Except for pollution degree 1, corresponding creepage distance not less than the minimum specified for the clearance in table 16, if the clearance has been checked according to the test of clause 14 | | N/A |
| 29.2.2 | Creepage distances of supplementary insulation at least those specified for basic insulation in table 17, or | (see appended table) | P |
| | Table 2 of IEC 60664-4, as applicable | | N/A |
| 29.2.3 | Creepage distances of reinforced insulation at least double those specified for basic insulation in table 17, or | (see appended table) | P |
| | Table 2 of IEC 60664-4, as applicable | | N/A |
| 29.2.4 | Creepage distances of functional insulation not less than specified in table 18.....: | (see appended table) | P |
| | However, if the working voltage is periodic and has a frequency exceeding 30 kHz, the creepage distances are also determined from table 2 of IEC 60664-4, these values being used if exceeding the values in table 18.....: | | N/A |
| | Creepage distances may be reduced if the appliance complies with clause 19 with the functional insulation short-circuited | | N/A |
| 29.3 | Supplementary and reinforced insulation have adequate thickness, or a sufficient number of layers, to withstand the electrical stresses | | P |
| | Compliance checked: | | - |
| | - by measurement, in accordance with 29.3.1, or | | P |
| | - by an electric strength test in accordance with 29.3.2, or | | N/A |
| | - by an assessment of the thermal quality of the material combined with an electric strength test, in accordance with 29.3.3, and | | N/A |
| | for accessible parts of reinforced insulation consisting of a single layer, by measurement in accordance with 29.3.4, or | | N/A |
| | - as specified in subclause 6.3 of IEC 60664-4 for insulation that is subjected to any periodic voltage having a frequency exceeding 30 kHz | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|----------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 29.3.1 | Supplementary insulation have a thickness of at least 1 mm | | P |
| | Reinforced insulation have a thickness of at least 2 mm | | P |
| 29.3.2 | Each layer of material withstand the electric strength test of 16.3 for supplementary insulation | | N/A |
| | Supplementary insulation consist of at least 2 layers | | N/A |
| | Reinforced insulation consist of at least 3 layers | | N/A |
| 29.3.3 | The insulation is subjected to the dry heat test Bb of IEC 60068-2-2, followed by | | N/A |
| | the electric strength test of 16.3 | | N/A |
| | If the temperature rise during the tests of clause 19 does not exceed the value specified in table 3, the test of IEC 60068-2-2 is not carried out | | N/A |
| 29.3.4 | Thickness of accessible parts of reinforced insulation consisting of a single layer not less than specified in table 19.....: | | N/A |
| 30 | RESISTANCE TO HEAT AND FIRE | | - |
| 30.1 | External parts of non-metallic material, | | P |
| | parts supporting live parts, and | | P |
| | parts of thermoplastic material providing supplementary or reinforced insulation | | P |
| | sufficiently resistant to heat | | P |
| | Ball-pressure test according to IEC 60695-10-2 | | P |
| | External parts tested at 40 °C plus the maximum temperature rise determined during the test of clause 11, or at 75 °C, whichever is the higher; temperature (°C).....: | (see appended table) | P |
| | Parts supporting live parts tested at 40 °C plus the maximum temperature rise determined during the test of clause 11, or at 125 °C, whichever is the higher; temperature (°C).....: | (see appended table) | P |
| | Parts of thermoplastic material providing supplementary or reinforced insulation tested at 25 °C plus the maximum temperature rise determined during clause 19, if higher; temperature (°C) | (see appended table) | P |
| 30.2 | Parts of non-metallic material resistant to ignition and spread of fire | | P |
| | This requirement does not apply to: | | - |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | parts having a mass not exceeding 0,5 g, provided the cumulative effect is unlikely to propagate flames that originate inside the appliance by propagating flames from one part to another, or | | N/A |
| | decorative trims, knobs and other parts unlikely to be ignited or to propagate flames that originate inside the appliance | | N/A |
| | Compliance checked by the test of 30.2.1, and in addition: | | P |
| | - for attended appliances, 30.2.2 applies | | N/A |
| | - for unattended appliances, 30.2.3 applies | | P |
| | For appliances for remote operation, 30.2.3 applies | | N/A |
| | For base material of printed circuit boards, 30.2.4 applies | | P |
| 30.2.1 | Parts of non-metallic material subjected to the glow-wire test of IEC 60695-2-11 at 550 °C | | P |
| | However, test not carried out if the material is classified as having a glow-wire flammability index according to IEC 60695-2-12 of at least 550 °C, or | | N/A |
| | the material is classified at least HB40 according to IEC 60695-11-10 | | N/A |
| | Parts for which the glow-wire test cannot be carried out need to meet the requirements in ISO 9772 for material classified HBF | | N/A |
| 30.2.3 | Appliances operated while unattended, tested as specified in 30.2.3.1 and 30.2.3.2 | | P |
| | The tests are not applicable to conditions as specified | | N/A |
| 30.2.3.1 | Parts of non-metallic material supporting connections carrying a current exceeding 0,2 A during normal operation, and | | P |
| | parts of non-metallic material, other than small parts, within a distance of 3 mm, | | P |
| | subjected to the glow-wire test of IEC 60695-2-11 with a test severity of 850 °C | | P |
| | Glow-wire applied to an interposed shielding material, if relevant | | N/A |
| | The glow-wire test is not carried out on parts of material classified as having a glow-wire flammability index according to IEC 60695-2-12 of at least 850 °C | | N/A |
| 30.2.3.2 | Parts of non-metallic material supporting connections, and | | P |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | parts of non-metallic material within a distance of 3 mm, | | P |
| | subjected to glow-wire test of IEC 60695-2-11 | | P |
| | The test severity is: | | - |
| | - 750 °C, for connections carrying a current exceeding 0,2 A during normal operation | | P |
| | - 650 °C, for other connections | | P |
| | Glow-wire applied to an interposed shielding material, if relevant | | N/A |
| | However, the glow-wire test of 750 °C or 650 °C as appropriate, is not carried out on parts of material fulfilling both or either of the following classifications: | | - |
| | - a glow-wire ignition temperature according to IEC 60695-2-13 of at least: | | N/A |
| | - 775 °C, for connections carrying a current exceeding 0,2 A during normal operation | | N/A |
| | - 675 °C, for other connections | | N/A |
| | - a glow-wire flammability index according to IEC 60695-2-12 of at least: | | N/A |
| | - 750 °C, for connections carrying a current exceeding 0,2 A during normal operation | | N/A |
| | - 650 °C, for other connections | | N/A |
| | The glow-wire test is also not carried out on small parts. These parts are to: | | - |
| | - comprise material having a glow-wire ignition temperature of at least 775 °C or 675 °C as appropriate, or | | N/A |
| | - comprise material having a glow-wire flammability index of at least 750 °C or 650 °C as appropriate, or | | N/A |
| | - comply with the needle-flame test of annex E, or | | N/A |
| | - comprise material classified as V-0 or V-1 according to IEC 60695-11-10 | | N/A |
| | The consequential needle-flame test of annex E applied to non-metallic parts that encroach within the vertical cylinder placed above the centre of the connection zone and on top of the non-metallic parts supporting current-carrying connections, and parts of non-metallic material within a distance of 3 mm of such connections if these parts are those: | | - |
| | - parts that withstood the glow-wire test of IEC 60695-2-11 of 750 °C or 650 °C as appropriate, but produce a flame that persist longer than 2 s, or | | P |
| | - parts that comprised material having a glow-wire flammability index of at least 750 °C or 650 °C as appropriate, or | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - small parts, that comprised material having a glow-wire flammability index of at least 750 °C or 650 °C as appropriate, or | | N/A |
| | - small parts for which the needle-flame test of annex E was applied, or | | N/A |
| | - small parts for which a material classification of V-0 or V-1 was applied | | N/A |
| | However, the consequential needle-flame test is not carried out on non-metallic parts, including small parts, within the cylinder that are: | | - |
| | - parts having a glow-wire ignition temperature of at least 775 °C or 675 °C as appropriate, or | | N/A |
| | - parts comprising material classified as V-0 or V-1 according to IEC 60695-11-10, or | | N/A |
| | - parts shielded by a flame barrier that meets the needle-flame test of annex E or that comprises material classified as V-0 or V-1 according to IEC 60695-11-10 | | N/A |
| 30.2.4 | Base material of printed circuit boards subjected to the needle-flame test of annex E | | P |
| | Test not applicable to conditions as specified | | N/A |
| 31 | RESISTANCE TO RUSTING | | - |
| | Relevant ferrous parts adequately protected against rusting | | P |
| | Tests specified in part 2 when necessary | | P |
| | Salt mist test of IEC 60068-2-52, severity 2 (IEC 60335-2-40) | | P |
| | Before test, coatings are scratched by means of a harden steel pin as specified (IEC 60335-2-40) | | P |
| | Five scratches made at least 5 mm apart and at least 5 mm from the edges (IEC 60335-2-40) | | P |
| | Appliance not deteriorated to such an extent that compliance with clause 8 and 27 is impaired (IEC 60335-2-40) | | P |
| | Coating not be broken and not loosened from the metal surface (IEC 60335-2-40) | | P |
| A | ANNEX A (INFORMATIVE) ROUTINE TESTS | | - |
| | Description of routine tests to be carried out by the manufacturer | | P |
| B | ANNEX B (NORMATIVE) APPLIANCES POWERED BY RECHARGEABLE BATTERIES | | - |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | The following modifications to this standard are applicable for appliances powered by batteries that are recharged in the appliance | | N/A |
| | This annex does not apply to battery chargers | | N/A |
| 3.1.9 | Appliance operated under the following conditions: | | - |
| | - the appliance, supplied by its fully charged battery, operated as specified in relevant part 2 | | N/A |
| | - the battery is charged, the battery being initially discharged to such an extent that the appliance cannot operate | | N/A |
| | - if possible, the appliance is supplied from the supply mains through its battery charger, the battery being initially discharged to such an extent that the appliance cannot operate. The appliance is operated as specified in relevant part 2 | | N/A |
| | - if the appliance incorporates inductive coupling between two parts that are detachable from each other, the appliance is supplied from the supply mains with the detachable part removed | | N/A |
| 3.6.2 | Part to be removed in order to discard the battery is not considered to be detachable | | N/A |
| 5.B.101 | Appliances supplied from the supply mains tested as specified for motor-operated appliances | | N/A |
| 7.1 | Battery compartment for batteries intended to be replaced by the user, marked with battery voltage and polarity of the terminals | | N/A |
| | The positive terminal indicated by symbol IEC 60417-5005 and the negative terminal by symbol IEC 60417-5006 | | N/A |
| 7.6 | Symbols 60417-5005 and IEC 60417-5006 | | N/A |
| 7.12 | The instructions give information regarding charging | | N/A |
| | The instructions for appliances incorporating batteries intended to be replaced by the user includes required information | | N/A |
| | Details about how to remove batteries containing materials hazardous to the environment given | | N/A |
| 7.15 | Markings placed on the part of the appliance connected to the supply mains | | N/A |
| 8.2 | Appliances having batteries that according to the instruction may be replaced by the user need only have basic insulation between live parts and the inner surface of the battery compartment | | N/A |
| | If the appliance can be operated without batteries, double or reinforced insulation required | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 11.7 | The battery is charged for the period stated in the instructions or 24 h | | N/A |
| 19.1 | Appliances subjected to tests of 19.B.101, 19.B.102 and 19.B.103 | | N/A |
| 19.10 | Not applicable | | N/A |
| 19.B.101 | Appliances supplied at rated voltage for 168 h, the battery being continually charged | | N/A |
| 19.B.102 | For appliances having batteries that can be removed without the aid of a tool, short-circuit of the terminals of the battery, the battery being fully charged, | | N/A |
| 19.B.103 | Appliances having batteries replaceable by the user supplied at rated voltage under normal operation with the battery removed or in any position allowed by the construction | | N/A |
| 21.B.101 | Appliances having pins for insertion into socket-outlets have adequate mechanical strength | | N/A |
| | Part of the appliance incorporating the pins subjected to the free fall test, procedure 2, of IEC 60068-2-31, the number of falls being: | | - |
| | - 100, if the mass of the part does not exceed 250 g (g) | | N/A |
| | - 50, if the mass of the part exceeds 250 g | | N/A |
| | After the test, the requirements of 8.1, 15.1.1, 16.3 and clause 29 are met | | N/A |
| 22.3 | Appliances having pins for insertion into socket-outlets tested as fully assembled as possible | | N/A |
| 25.13 | An additional lining or bushing not required for interconnection cords in class III appliances or class III constructions operating at safety extra-low voltage not containing live parts | | N/A |
| 30.2 | For parts of the appliance connected to the supply mains during the charging period, 30.2.3 applies | | N/A |
| | For other parts, 30.2.2 applies | | N/A |
| C | ANNEX C (NORMATIVE) AGEING TEST ON MOTORS | | - |
| | Tests, as described, carried out when doubt with regard to the temperature classification of the insulation of a motor winding | | N/A |
| | Test conditions as specified | | N/A |
| E | ANNEX E (NORMATIVE) NEEDLE-FLAME TEST | | - |
| | Needle-flame test carried out in accordance with IEC 60695-11-5, with the following modifications: | | - |

| IEC 60335-2-40 | | | |
|----------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 7 | Severities | | - |
| | The duration of application of the test flame is 30 s ± 1 s | | P |
| 9 | Test procedure | | - |
| 9.1 | The specimen so arranged that the flame can be applied to a vertical or horizontal edge as shown in the examples of figure 1 | | P |
| 9.2 | The first paragraph does not apply | | P |
| | If possible, the flame is applied at least 10 mm from a corner | | P |
| 9.3 | The test is carried out on one specimen | | P |
| | If the specimen does not withstand the test, the test may be repeated on two additional specimens, both withstanding the test | | N/A |
| 11 | Evaluation of test results | | - |
| | The duration of burning not exceeding 30 s | | N/A |
| | However, for printed circuit boards, the duration of burning not exceeding 15 s | | P |
| F | ANNEX F (NORMATIVE) CAPACITORS | | - |
| | Capacitors likely to be permanently subjected to the supply voltage, and used for radio interference suppression or voltage dividing, comply with the following clauses of IEC 60384-14, with the following modifications: | | - |
| 1.5 | Terms and definitions | | - |
| 1.5.3 | Class X capacitors tested according to subclass X2 | | N/A |
| 1.5.4 | This subclause is applicable | | N/A |
| 1.6 | Marking | | - |
| | Items a) and b) are applicable | | N/A |
| 3.4 | Approval testing | | - |
| 3.4.3.2 | Table 3 is applicable as described | | N/A |
| 4.1 | Visual examination and check of dimensions | | - |
| | This subclause is applicable | | N/A |
| 4.2 | Electrical tests | | - |
| 4.2.1 | This subclause is applicable | | N/A |
| 4.2.5 | This subclause is applicable | | N/A |
| 4.2.5.2 | Only table 11 is applicable | | N/A |
| | Values for test A apply | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | However, for capacitors in heating appliances the values for test B or C apply | | N/A |
| 4.12 | Damp heat, steady state | | - |
| | This subclause is applicable | | N/A |
| | Only insulation resistance and voltage proof are checked | | N/A |
| 4.13 | Impulse voltage | | - |
| | This subclause is applicable | | N/A |
| 4.14 | Endurance | | - |
| | Subclauses 4.14.1, 4.14.3, 4.14.4 and 4.14.7 are applicable | | N/A |
| 4.14.7 | Only insulation resistance and voltage proof are checked | | N/A |
| | No visible damage | | N/A |
| 4.17 | Passive flammability test | | - |
| | This subclause is applicable | | N/A |
| 4.18 | Active flammability test | | - |
| | This subclause is applicable | | N/A |
| G | ANNEX G (NORMATIVE) SAFETY ISOLATING TRANSFORMERS | | - |
| | The following modifications to this standard are applicable for safety isolating transformers: | | - |
| 7 | Marking and instructions | | - |
| 7.1 | Transformers for specific use marked with: | | - |
| | - name, trademark or identification mark of the manufacturer or responsible vendor.....: | | N/A |
| | - model or type reference | | N/A |
| 17 | Overload protection of transformers and associated circuits | | - |
| | Fail-safe transformers comply with subclause 15.5 of IEC 61558-1 | | N/A |
| 22 | Construction | | - |
| | Subclauses 19.1 and 19.1.2 of IEC 61558-2-6 are applicable | | N/A |
| 29 | Clearances, creepage distances and solid insulation | | - |
| 29.1, 29.2, 29.3 | The distances specified in items 2a, 2c and 3 in table 13 of IEC 61558-1 apply | | N/A |
| | For insulated winding wires complying with subclause 19.12.3 of IEC 61558-1 there are no requirements for clearances or creepage distances | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | For windings providing reinforced insulation, the distance specified in item 2c of table 13 of IEC 61558-1 is not assessed | | N/A |
| | For safety isolating transformers subjected to periodic voltages with a frequency exceeding 30 kHz, the clearances, creepage distances and solid insulation values specified in IEC 60664-4 are applicable, if greater than the values specified in items 2a, 2c and 3 in table 13 of IEC 61558-1 | | N/A |
| H | ANNEX H (NORMATIVE) SWITCHES | | - |
| | Switches comply with the following clauses of IEC 61058-1, as modified below: | | - |
| | The tests of IEC 61058-1 carried out under the conditions occurring in the appliance | | N/A |
| | Before being tested, switches are operated 20 times without load | | N/A |
| 8 | Marking and documentation | | - |
| | Switches are not required to be marked | | N/A |
| | However, a switch that can be tested separately from the appliance marked with the manufacturer's name or trade mark and the type reference | | N/A |
| 13 | Mechanism | | - |
| | The tests may be carried out on a separate sample | | N/A |
| 15 | Insulation resistance and dielectric strength | | - |
| 15.1 | Not applicable | | N/A |
| 15.2 | Not applicable | | N/A |
| 15.3 | Applicable for full disconnection and micro-disconnection | | N/A |
| 17 | Endurance | | - |
| | Compliance is checked on three separate appliances or switches | | N/A |
| | For 17.2.4.4, the number of cycles declared according to 7.1.4 is 10 000, unless | | N/A |
| | otherwise specified in 24.1.3 of the relevant part 2 of IEC 60335.....: | | N/A |
| | Switches for operation under no load and which can be operated only by a tool, and | | N/A |
| | switches operated by hand that are interlocked so that they cannot be operated under load, | | N/A |
| | are not subjected to the tests | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | However, switches without this interlock are subjected to the test of 17.2.4.4 for 100 cycles of operation | | N/A |
| | Subclauses 17.2.2 and 17.2.5.2 not applicable | | N/A |
| | The ambient temperature during the test is that occurring in the appliance during the test of clause 11 in IEC 60335-1 | | N/A |
| | The temperature rise of the terminals not more than 30 K above the temperature rise measured in clause 11 of IEC 60335-1 (K) | | N/A |
| 20 | Clearances, creepage distances, solid insulation and coatings of rigid printed board assemblies | | - |
| | This clause is applicable to clearances and creepage distances for functional insulation, across full disconnection and micro-disconnection, as stated in table 24 | | N/A |
| J | ANNEX J (NORMATIVE) COATED PRINTED CIRCUIT BOARDS | | - |
| | Testing of protective coatings of printed circuit boards carried out in accordance with IEC 60664-3 with the following modifications: | | N/A |
| 5.7 | Conditioning of the test specimens | | - |
| | When production samples are used, three samples of the printed circuit board are tested | | N/A |
| 5.7.1 | Cold | | - |
| | The test is carried out at -25 °C | | N/A |
| 5.7.3 | Rapid change of temperature | | - |
| | Severity 1 is specified | | N/A |
| 5.9 | Additional tests | | - |
| | This subclause is not applicable | | N/A |
| K | ANNEX K (NORMATIVE) OVERVOLTAGE CATEGORIES | | - |
| | The information on overvoltage categories is extracted from IEC 60664-1 | | P |
| | Overvoltage category is a numeral defining a transient overvoltage condition | | P |
| | Equipment of overvoltage category IV is for use at the origin of the installation | | N/A |
| | Equipment of overvoltage category III is equipment in fixed installations and for cases where the reliability and the availability of the equipment is subject to special requirements | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | Equipment of overvoltage category II is energy consuming equipment to be supplied from the fixed installation | | P |
| | If such equipment is subjected to special requirements with regard to reliability and availability, overvoltage category III applies | | N/A |
| | Equipment of overvoltage category I is equipment for connection to circuits in which measures are taken to limit transient overvoltages to an appropriate low level | | N/A |
| L | ANNEX L (INFORMATIVE) GUIDANCE FOR THE MEASUREMENT OF CLEARANCES AND CREEPAGE DISTANCES | | - |
| | Information for the determination of clearances and creepage distances | | P |
| M | ANNEX M (NORMATIVE) POLLUTION DEGREE | | - |
| | The information on pollution degrees is extracted from IEC 60664-1 | | P |
| | Pollution | | - |
| | The microenvironment determines the effect of pollution on the insulation, taking into account the macroenvironment | | P |
| | Means may be provided to reduce pollution at the insulation by effective enclosures or similar | | P |
| | Minimum clearances specified where pollution may be present in the microenvironment | | P |
| | Degrees of pollution in the microenvironment | | - |
| | For evaluating creepage distances, the following degrees of pollution in the microenvironment are established: | | - |
| | - pollution degree 1: no pollution or only dry, non-conductive pollution occurs. The pollution has no influence | | N/A |
| | - pollution degree 2: only non-conductive pollution occurs, except that occasionally a temporary conductivity caused by condensation is to be expected | | N/A |
| | - pollution degree 3: conductive pollution occurs or dry non-conductive pollution occurs that becomes conductive due to condensation that is to be expected | | P |
| | - pollution degree 4: the pollution generates persistent conductivity caused by conductive dust or by rain or snow | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| N | ANNEX N (NORMATIVE) PROOF TRACKING TEST | | - |
| | The proof tracking test is carried out in accordance with IEC 60112 with the following modifications: | | - |
| 7 | Test apparatus | | - |
| 7.3 | Test solutions | | - |
| | Test solution A is used | | P |
| 10 | Determination of proof tracking index (PTI) | | - |
| 10.1 | Procedure | | - |
| | The proof voltage is 100 V, 175 V, 400 V or 600 V: | 175V | P |
| | The test is carried out on five specimens | | P |
| | In case of doubt, additional test with proof voltage reduced by 25 V, the number of drops increased to 100 | | N/A |
| 10.2 | Report | | - |
| | The report states if the PTI value was based on a test using 100 drops with a test voltage of (PTI-25) V | | N/A |
| O | ANNEX O (INFORMATIVE) SELECTION AND SEQUENCE OF THE TESTS OF clause 30 | | - |
| | Description of tests for determination of resistance to heat and fire | | P |
| P | ANNEX P (INFORMATIVE) GUIDANCE FOR THE APPLICATION OF THIS STANDARD TO APPLIANCES USED IN WARM DAMP EQUABLE CLIMATES | | - |
| | Modifications applicable for class 0 and 01 appliances having a rated voltage exceeding 150 V, intended to be used in countries having a warm damp equable climate and that are marked WDaE | | - |
| | Modifications may also be applied to class 1 appliances having a rated voltage exceeding 150 V, intended to be used in countries having a warm damp equable climate and that are marked WDaE, if liable to be connected to a supply mains that excludes the protective earthing conductor | | - |
| 5.7 | The ambient temperature for the tests of clauses 11 and 13 is 40 +3/0 °C | | N/A |
| 7.1 | The appliance marked with the letters WDaE | | N/A |
| 7.12 | The instructions state that the appliance is to be supplied through a residual current device (RCD) having a rated residual operating current not exceeding 30 mA | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | The instructions state that the appliance is considered to be suitable for use in countries having a warm damp equable climate, but may also be used in other countries | | N/A |
| 11.8 | The values of Table 3 are reduced by 15 K | | N/A |
| 13.2 | The leakage current for class I appliances not exceeding 0,5 mA | | N/A |
| 15.3 | The value of t is 37 °C | | N/A |
| 16.2 | The leakage current for class I appliances not exceeding 0,5 mA (mA): | | N/A |
| 19.13 | The leakage current test of 16.2 is applied in addition to the electric strength test of 16.3 | | N/A |
| Q | ANNEX Q (INFORMATIVE) SEQUENCE OF TESTS FOR THE EVALUATION OF ELECTRONIC CIRCUITS | | - |
| | Description of tests for appliances incorporating electronic circuits | | - |
| R | ANNEX R (NORMATIVE) SOFTWARE EVALUATION | | - |
| | Programmable electronic circuits requiring software incorporating measures to control the fault/error conditions specified in table R.1 or R.2 validated in accordance with the requirements of this annex | | N/A |
| R.1 | Programmable electronic circuits using software | | - |
| | Programmable electronic circuits requiring software incorporating measures to control the fault/error conditions specified in table R.1 or R.2 constructed so that the software does not impair compliance with the requirements of this standard | | N/A |
| R.2 | Requirements for the architecture | | - |
| | Programmable electronic circuits requiring software incorporating measures to control the fault/error conditions specified in table R.1 or R.2 use measures to control and avoid software-related faults/errors in safety-related data and safety-related segments of the software | | N/A |
| R.2.1.1 | Programmable electronic circuits requiring software incorporating measures to control the fault/error conditions specified in table R.2 have one of the following structures: | | - |
| | - single channel with periodic self-test and monitoring | | N/A |
| | - dual channel (homogenous) with comparison | | N/A |
| | - dual channel (diverse) with comparison | | N/A |
| | Programmable electronic circuits requiring software incorporating measures to control the fault/error conditions specified in table R.1 have one of the following structures: | | - |

| IEC 60335-2-40 | | | |
|-----------------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | - single channel with functional test | | N/A |
| | - single channel with periodic self-test | | N/A |
| | - dual channel without comparison | | N/A |
| R.2.2 | Measures to control faults/errors | | - |
| R.2.2.1 | When redundant memory with comparison is provided on two areas of the same component, the data in one area is stored in a different format from that in the other area | | N/A |
| R.2.2.2 | Programmable electronic circuits with functions requiring software incorporating measures to control the fault/error conditions specified in table R.2 and that use dual channel structures with comparison, have additional fault/error detection means for any fault/errors not detected by the comparison | | N/A |
| R.2.2.3 | For programmable electronic circuits with functions requiring software incorporating measures to control the fault/error conditions specified in table R.1 or R.2, means are provided for the recognition and control of errors in transmissions to external safety-related data paths | | N/A |
| R.2.2.4 | For programmable electronic circuits with functions requiring software incorporating measures to control the fault/error conditions specified in table R.1 or R.2, the programmable electronic circuits incorporate measures to address the fault/errors in safety-related segments and data indicated in table R.1 and R.2 as appropriate | | N/A |
| R.2.2.5 | For programmable electronic circuits with functions requiring software incorporating measures to control the fault/error conditions specified in table R.1 or R.2, detection of a fault/error occur before compliance with clause 19 is impaired | | N/A |
| R.2.2.6 | The software is referenced to relevant parts of the operating sequence and the associated hardware functions | | N/A |
| R.2.2.7 | Labels used for memory locations are unique | | N/A |
| R.2.2.8 | The software is protected from user alteration of safety-related segments and data | | N/A |
| R.2.2.9 | Software and safety-related hardware under its control is initialized and terminates before compliance with clause 19 is impaired | | N/A |
| R.3 | Measures to avoid errors | | - |
| R.3.1 | General | | - |

| IEC 60335-2-40 | | | |
|-----------------------|---|-------------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | For programmable electronic circuits with functions requiring software incorporating measures to control the fault/error conditions specified in table R.1 or R.2, the following measures to avoid systematic fault in the software are applied | | - |
| | Software that incorporates measures used to control the fault/error conditions specified in table R.2 is inherently acceptable for software required to control the fault/error conditions specified in table R.1 | | N/A |
| R.3.2 | Specification | | - |
| R.3.2.1 | Software safety requirements: | Software Id: | N/A |
| | The specification of the software safety requirements includes the descriptions listed | | N/A |
| R.3.2.2 | Software architecture | | - |
| R.3.2.2.1 | The specification of the software architecture includes the aspects listed <ul style="list-style-type: none"> - techniques and measures to control software faults/errors (refer to R.2.2); - interactions between hardware and software; - partitioning into modules and their allocation to the specified safety functions; - hierarchy and call structure of the modules (control flow); - interrupt handling; - data flow and restrictions on data access; - architecture and storage of data; - time-based dependencies of sequences and data | Document ref. No: | N/A |
| R.3.2.2.2 | The architecture specification is validated against the specification of the software safety requirements by static analysis | | N/A |
| R.3.2.3 | Module design and coding | | - |
| R.3.2.3.1 | Based on the architecture design, software is suitably refined into modules | | N/A |
| | Software module design and coding is implemented in a way that is traceable to the software architecture and requirements | | N/A |
| R.3.2.3.2 | Software code is structured | | N/A |
| R.3.2.3.3 | Coded software is validated against the module specification by static analysis | | N/A |
| | The module specification is validated against the architecture specification by static analysis | | N/A |
| R.3.3.3 | Software validation | | - |

| IEC 60335-2-40 | | | |
|----------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| | The software is validated with reference to the requirements of the software safety requirements specification | | N/A |
| | Compliance is checked by simulation of: | | - |
| | - input signals present during normal operation | | N/A |
| | - anticipated occurrences | | N/A |
| | - undesired conditions requiring system action | | N/A |

| TABLE R.1 ^e – GENERAL FAULT/ERROR CONDITIONS | | | | | | |
|---|---|---|--|--|-------------------------------------|---------|
| Component ^a | Fault/error | Acceptable measures ^{b, c} | Definitions | Document reference for applied measure | Document reference for applied test | Verdict |
| 1 CPU | | | | | | N/A |
| 1.1 Registers | Stuck at | Functional test, or periodic self-test using either: - static memory test, or - word protection with single bit redundancy | H.2.16.5 H.2.16.6 H.2.19.6 H.2.19.8.2 | | | N/A |
| 1.2 VOID | | | | | | N/A |
| 1.3 Programme counter | Stuck at | Functional test, or Periodic self-test, or Independent time-slot monitoring, or Logical monitoring of the programme sequence | H.2.16.5 H.2.16.6 H.2.18.10.4 H.2.18.10.2 | | | N/A |
| 2 Interrupt handling and execution | No interrupt or too frequent interrupt | Functional test, or time-slot monitoring | H.2.16.5 H.2.18.10.4 | | | N/A |
| 3 Clock | Wrong frequency (for quartz synchronized clock: harmonics/sub-harmonics only) | Frequency monitoring, or time slot monitoring | H.2.18.10.1 H.2.18.10.4 | | | N/A |

| IEC 60335-2-40 | | | | | | |
|---|-----------------------|--|---|--|--|---------|
| Clause | Requirement + Test | | Result - Remark | | | Verdict |
| 4. Memory | | | | | | N/A |
| 4.1 Invariable memory | All single bit faults | Periodic modified checksum, or multiple checksum, or word protection with single bit redundancy | H.2.19.3.1 H.2.19.3.2 H.2.19.8.2 | | | N/A |
| 4.2 Variable memory | DC fault | Periodic static memory test, or word protection with single bit redundancy | H.2.19.6 H.2.19.8.2 | | | N/A |
| 4.3 Addressing (relevant to variable and invariable memory) | Stuck at | Word protection with single bit redundancy including the address | H.2.19.8.2 | | | N/A |
| 5 Internal data path | Stuck at | Word protection with single bit redundancy | H.2.19.8.2 | | | N/A |
| 5.1 VOID | | | | | | N/A |
| 5.2 Addressing | Wrong address | Word protection with single bit redundancy including the address | H.2.19.8.2 | | | N/A |
| 6 External communication | Hamming distance 3 | Word protection with multi-bit redundancy, or CRC – single work, or Transfer redundancy, or Protocol test | H.2.19.8.1 H.2.19.4.1 H.2.18.2.2 H.2.18.14 | | | N/A |
| 6.1 VOID | | | | | | N/A |
| 6.2 VOID | | | | | | N/A |

| IEC 60335-2-40 | | | | | | |
|---|--|--|---|--|--|---------|
| Clause | Requirement + Test | | Result - Remark | | | Verdict |
| 6.3 Timing | Wrong point in time | Time-slot monitoring, or scheduled transmission | H.2.18.10.4 H.2.18.18 H.2.18.10.3 | | | N/A |
| | Wrong sequence | Time-slot and logical monitoring, or comparison of redundant communication channels by either: - reciprocal comparison - independent hardware comparator | H.2.18.15 H.2.18.3 | | | |
| | | Logical monitoring, or time-slot monitoring, or Scheduled transmission | H.2.18.10.2 H.2.18.10.4 H.2.18.18 | | | |
| 7 Input/output periphery | Fault conditions specified in 19.11.2 | Plausibility check | H.2.18.13 | | | N/A |
| 7.1 VOID | | | | | | N/A |
| 7.2 Analog I/O | | | | | | N/A |
| 7.2.1 A/D and D/A-converter | Fault conditions specified in 19.11.2 | Plausibility check | H.2.18.13 | | | N/A |
| 7.2.2 Analog multiplexer | Wrong addressing | Plausibility check | H.2.18.13 | | | N/A |
| 8 VOID | | | | | | N/A |
| 9 Custom chips ^d e.g. ASIC, GAL, gate array | Any output outside the static and dynamic functional specification | Periodic self-test | H.2.16.6 | | | N/A |
| <p>NOTE A Stuck-at fault model denotes a fault model representing an open circuit or a non-varying signal level. A DC fault model denotes a stuck-at fault model incorporating short circuit between signal lines.</p> <p>a) For fault/error assessment, some components are divided into their sub-functions. b) For each sub-function in the table, the Table R.2 measure will cover the software fault/error. c) Where more than one measure is given for a sub-function, these are alternatives. d) To be divided as necessary by the manufacturer into sub-functions. e) Table R.1 is applied according to the requirements of R.1 to R.2.2.9 inclusive.</p> | | | | | | |

| IEC 60335-2-40 | | | |
|-----------------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| AA | ANNEX AA (INFORMATIVE) (IEC 60335-2-40) EXAMPLES FOR OPERATING TEMPERATURES OF THE APPLIANCE | | - |
| BB | ANNEX BB (NORMATIVE) (IEC 60335-2-40) SELECTED INFORMATION ABOUT REFRIGERANTS | | - |
| CC | ANNEX CC (INFORMATIVE) (IEC/EN 60335-2-40/A1) TRANSPORTATION, MARKING AND STORAGE FOR UNITS THAT EMPLOY FLAMMABLE REFRIGERANTS | | - |
| CC.1 | Transport of equipment containing flammable refrigerants (IEC 60335-2-40/A1) | | N/A |
| CC.2 | Marking of equipment using signs (IEC 60335-2-40/A1) | | N/A |
| CC.3 | Disposal of equipment using flammable refrigerants (IEC 60335-2-40/A1) | | N/A |
| CC.4 | Storage of equipment/appliances (IEC 60335-2-40/A1) | | N/A |
| CC.5 | Storage of packed (unsold) equipment (IEC 60335-2-40/A1) | | N/A |
| DD | ANNEX DD (NORMATIVE) (IEC/EN 60335-2-40/A1) SERVICE OPERATIONS | | - |
| DD.1 | Generals (IEC 60335-2-40/A1) | | N/A |
| DD.2 | Symbols (IEC 60335-2-40/A1) | | N/A |
| DD.3 | Information in manual (IEC 60335-2-40/A1 corr.1) | | N/A |
| DD.4 | Information on servicing (IEC 60335-2-40/A1) | | N/A |
| DD.5 | Repairs to sealed components (IEC 60335-2-40/A1) | | N/A |
| DD.6 | Repair to intrinsically safe components (IEC 60335-2-40/A1) | | N/A |
| DD.7 | Cabling (IEC 60335-2-40/A1) | | N/A |
| DD.8 | Detection of flammable refrigerants (IEC 60335-2-40/A1) | | N/A |
| DD.9 | Leak detection methods (IEC 60335-2-40/A1) | | N/A |
| DD.10 | Removal and evacuation (IEC 60335-2-40/A1) | | N/A |
| DD.11 | Charging procedures (IEC 60335-2-40/A1) | | N/A |
| DD.12 | Decommissioning (IEC 60335-2-40/A1) | | N/A |
| DD.13 | Labelling (IEC 60335-2-40/A1) | | N/A |
| DD.14 | Recovery (IEC 60335-2-40/A1) | | N/A |

| IEC 60335-2-40 | | | |
|-----------------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | |
|-----------|--|--|-----|
| EE | ANNEX EE (NORMATIVE) (IEC/EN 60335-2-40/A1) PRESSURE TESTS | | - |
| EE.1 | General (IEC 60335-2-40/A1) | | P |
| EE.2 | Pressure test value determined under testing carried out in clause 11 (IEC 60335-2-40/A1) | | P |
| EE.3 | Pressure test value determined under testing carried out in clause 19 (IEC 60335-2-40/A1) | | P |
| EE.4 | Pressure test value determined under testing carried out under standstill conditions (IEC 60335-2-40/A1) | | P |
| EE.5 | Fatigue test option for Clauses EE.1 and EE.4.1 (IEC 60335-2-40/A1) | | N/A |

| | | | |
|-----------|--|--|-----|
| FF | ANNEX FF (NORMATIVE) (IEC/EN 60335-2-40/A1) LEAK SIMULATION TESTS | | - |
| FF.1 | General (IEC 60335-2-40/A1) | | N/A |
| FF.2 | Test methods (IEC 60335-2-40/A1 corr.1) | | N/A |

| | | | |
|-----------|--|--|-----|
| GG | ANNEX GG (NORMATIVE) (IEC/EN 60335-2-40/A1) CHARGE LIMITS, VENTILATION REQUIREMENTS AND REQUIREMENTS FOR SECONDARY CIRCUITS | | - |
| GG.1 | Requirements for charge limits in ventilated areas (IEC 60335-2-40/A1 Corr.1) | | N/A |
| GG.2 | Requirements for charge limits in unventilated areas (IEC 60335-2-40/A1 Corr.1) | | N/A |
| GG.3 | Requirements for charge limits in areas with mechanical ventilation (IEC 60335-2-40/A1) | | N/A |
| GG.4 | Requirements for mechanical ventilation within the appliance enclosure (IEC 60335-2-40/A1) | | N/A |
| GG.5 | Requirements for mechanical ventilation for rooms complying with ISO 5149 (IEC 60335-2-40/A1) | | N/A |
| GG.6 | Requirements for refrigeration systems employing secondary heat exchangers (IEC 60335-2-40/A1 Corr.1) | | N/A |
| GG.7 | The appliance shall then be tested with a maximum water flow under the conditions described in g) (IEC 60335-2-40/A1) | | N/A |

| 10.1 | TABLE: Power input deviation | | | | | P |
|--|------------------------------|----------------|------------|---------------------|--------|---|
| Input deviation of/at: | P rated (W) | P measured (W) | ΔP | Required ΔP | Remark | |
| SMK-D140/MN1/230V | 10 | 9,0 | -10,0 % | +20% | - | |
| Supplementary information: Test condition: indoor: 35°C /20°C; Water temperature: inlet: 40,9°C; outlet: 45,0°C; Water flow rate: 2,4 m ³ /h | | | | | | |

| 10.2 | TABLE: Current deviation | | | | | | P | |
|--------------------------------|--------------------------|---------|----------------|---------|---------|---------|-------------|--------|
| Current deviation of/at: 230V~ | I rated (A) | | I measured (A) | | dl | | Required dl | Remark |
| | Cooling | Heating | Cooling | Heating | Cooling | Heating | | |
| MDV-D56T3/N1-B | 0,25 | 0,25 | 0,20 | 0,20 | -20% | -20% | +20% | - |
| MDV-D56Q4/N1-D | 0,41 | 0,41 | 0,341 | 0,299 | -16,8% | -27,1% | +20% | - |
| MDV-D140Q4/N1-D | 0,82 | 0,82 | 0,738 | 0,684 | -10% | -16,6% | +20% | - |
| MDV-D90DL/N1-C | 0,83 | 0,83 | 0,543 | 0,50 | -34,6% | -39,8% | +20% | - |
| MDV-D36G/N1YB | 0,14 | 3,52 | 0,13 | 3,17 | -7% | -9,9% | +20% | - |
| MDV-D36T3/N1-B | 0,16 | 0,18 | 0,137 | 0,14 | -23,9% | -22,2% | +20% | - |
| MDV-D140DL/N1-C | 1,11 | 1,11 | 0,893 | 0,89 | -19,5% | -19,8% | +20% | - |
| MDV-D36Q1/N1-C | 0,23 | 0,23 | 0,238 | 0,288 | 3,5% | -18,3% | +20% | - |
| MDV-D80Q4/N1-D | 0,52 | 0,52 | 0,409 | 0,375 | -21,3% | -27,9% | +20% | - |
| MDV-D112Q4/N1-D | 0,73 | 0,73 | 0,774 | 0,728 | 6,0% | -0,3% | +20% | - |
| MDV-D56G/DN1YB | 0,2 | 4,25 | 0,192 | 3,83 | -4,0% | -9,9% | +20% | - |
| MDV-D36DL/N1-C | 0,23 | 0,23 | 0,14 | 0,144 | -39,1% | -37,4% | +20% | - |
| MDV-D71DL/N1-C | 0,67 | 0,67 | 0,531 | 0,467 | -20,7% | -30,3% | +20% | - |
| MDV-D56Q1/N1-C | 0,41 | 0,41 | 0,481 | 0,36 | 17,3% | -12,2% | +20% | - |
| MDV-D22Z/N1-F1B | 0,18 | 0,18 | 0,18 | 0,18 | 0% | 0% | +20% | - |
| MDV-D71Z/N1-F3B | 0,59 | 0,59 | 0,57 | 0,58 | -3,4% | -1,7% | +20% | - |
| MDV-D45Z/N1-F4 | 0,22 | 0,22 | 0,22 | 0,21 | 0% | -4,5% | +20% | - |
| MDV-D36Z/DN1-B | 0,15 | 0,15 | 0,15 | 0,14 | 0% | -6,7% | +20% | - |
| MDV-D45Q4/N1-A3 | 0,25 | 0,25 | 0,23 | 0,19 | -8% | -24% | +20% | - |
| MDV-D22T2/N1-BA5 | 0,28 | 0,28 | 0,26 | 0,22 | -7,1% | -21,4% | +20% | - |
| MDV-D112T2/N1-BA5 | 1,8 | 1,8 | 1,4 | 1,05 | -22,2% | -41,7% | +15% | - |
| MDV-D22Q2/N1 | 0,4 | 0,4 | 0,28 | 0,25 | -30% | -37,5% | +20% | - |
| MDV-D56T2/N1-BA5 | 0,5 | 0,5 | 0,41 | 0,39 | -18% | -22% | +20% | - |
| MDV-D80T2/N1-BA5 | 1,0 | 1,0 | 0,81 | 0,79 | -19% | -21% | +20% | - |
| MDV-D45Q2/N1 | 0,5 | 0,5 | 0,48 | 0,39 | -4% | -22% | +20% | - |

| | | | | | | | | |
|--|------|---------------|------|------|--------|--------|-------|----|
| MDV-D71Q2/N1 | 0,85 | 0,85 | 0,8 | 0,74 | -5,9% | -12,9% | +20% | - |
| MDV-200T1/N1-B | 8,6 | 8,6 | 8,36 | 8,11 | -2,8% | -5,7% | +15% | - |
| MDV-140T1/N1-FA | 2,4 | 2,4 | 1,82 | 1,74 | -24,2% | -27,5% | +15% | - |
| MDV-280T1/N1-FA | 5,6 | 5,6 | 5,76 | 5,7 | -2,9% | -1,8% | +15% | - |
| MDV-80T1/N1-B | 1,23 | 1,23 | 1,10 | 1,10 | -10,6% | -10,6% | +20% | -- |
| MDV-90T1/N1-B | 1,87 | 1,87 | 1,74 | 1,67 | -7,0% | -7,0% | +15% | - |
| MDV-112T1/N1-B | 2,3 | 2,3 | 2,26 | 2,2 | -1,7% | -4,3% | +15% | - |
| MDV-160T1/N1-B | 4,77 | 4,77 | 3,44 | 3,24 | -27,9% | -32,1% | +15% | - |
| MDV-D36G/DN1YB (with fan motor YDK15-6) | 0,14 | 0,14+3,3 8 | 0,13 | 0,13 | -7,1% | -7,1% | +20 % | - |
| MDV-D56G/DN1YB (with fan motor YDK18-4) | 0,20 | 0,20+4,0 5 | 0,19 | 0,19 | -5,0% | -5,0% | +20 % | - |
| MDV-D56Q4/N1- D(with fan motor YDK60-6F-3) | 0,41 | 0,41 | 0,34 | 0,34 | -17,1% | -17,1% | +20 % | - |
| MDV-D80Q4/N1-D (with fan motor YDK80-6E-2) | 0,52 | 0,52 | 0,42 | 0,42 | -19,2% | -19,2% | +20 % | - |
| MDV-D280T1/N1- B(with fan motor YDK550-4X(Match- well)) | 8,6 | 8,6 | 6,11 | 6,11 | -29,0% | -29,0% | +15 % | - |
| MDV-D280T1/N1- FA(with fan motor YDK250-4X (Match- well)) | 5,6 | 5,6 | 5,72 | 5,6 | +2,1% | -0,0% | +15 % | - |
| MDV-D71T2/N1- CA5(yongan motor) | 0,7 | 0,7 | 0,77 | 0,77 | +10,0% | +10,0% | +20% | - |
| MDV-D71T2/N1- CA5(Welling motor) | 0,7 | 0,7 | 0,68 | 0,68 | -2,9% | -2,9% | +20% | - |
| MDV-D71G- R3/N1Y(Welling motor) | 0,33 | 0,33 | 0,29 | 0,29 | -12,1% | -12,1% | +20% | - |
| MDV-D71G- R3/N1Y(Broad- ocean) | 0,33 | 0,33 | 0,31 | 0,31 | -6,1% | -6,1% | +20% | - |
| MDV-D80G- R3/N1Y(Welling motor) | 0,39 | 0,39 | 0,34 | 0,34 | -12,8% | -12,8% | +20% | - |
| MDV-D80G- R3/N1Y((Broad- ocean) | 0,39 | 0,39 | 0,37 | 0,37 | -5,1% | -5,1% | +20% | - |
| MDV-D560T1/N1 (yongan motor) | 15,5 | 15,5 | 16,9 | 16,6 | +8,4% | +7,1% | +15% | - |

| | | | | | | | | |
|---|------|------|------|------|--------|--------|------|---|
| MDV-D560T1/N1 (Welling motor) | 15,5 | 15,5 | 16,9 | 16,6 | +8,4% | +7,1% | +15% | - |
| MDV-D450T1/N1 (yongan motor) | 12,5 | 12,5 | 10,7 | 10,9 | -14,4% | -12,8% | +15% | - |
| MDV-D450T1/N1 (Match-well motor) | 12,5 | 12,5 | 10,6 | 10,8 | -15,2% | -13,6% | +15% | - |
| MDV-D36T2/N1- DA5(Welling motor: YSK27-4C(B)) | 0,33 | 0,33 | 0,35 | 0,33 | +6,1% | +0,0% | +20% | - |
| MDV-D36T2/N1- DA5(Welling motor: YSK27-4C) | 0,33 | 0,33 | 0,35 | 0,35 | +6,1% | +6,1% | +20% | - |
| MDV-D36T2/N1- DA5(Yong an motor: YSK27-4C) | 0,33 | 0,33 | 0,35 | 0,35 | +6,1% | +6,1% | +20% | - |
| MDV-D36T2/N1- DA5(Welling motor: YSK27-4C) | 0,33 | 0,33 | 0,35 | 0,35 | +6,1% | +6,1% | +20% | - |
| MDV-D36T2/N1- DA5(Tongde motor: YSK27-4C) | 0,33 | 0,33 | 0,35 | 0,34 | +6,1% | +0,3% | +20% | - |
| MDV-D36T2/N1- DA5(Yongan motor: YSK27-4C) | 0,33 | 0,33 | 0,35 | 0,34 | +6,1% | +0,3% | +20% | - |
| MDV-D17Q4/N1-A3 | 0,22 | 0,22 | 0,19 | 0,15 | -13,6% | -31,8% | +20% | - |
| MDV-D17G/N1-S | 0,12 | 0,12 | 0,12 | 0,13 | +0,0% | +8,3% | +20% | - |
| MDV-D36Q1/N1-D | 0,25 | 0,25 | 0,15 | 0,15 | -40,0% | -40,0% | +20% | - |
| MDV-D22G/N1Y- 11D5 | 0,13 | 0,13 | 0,13 | 0,12 | -0,0% | -7,8% | +20% | - |
| MDV-D36G/N1Y- 11D5 | 0,18 | 0,18 | 0,18 | 0,20 | -0,0% | +11,1% | +20% | - |
| MDV-D45G/N1Y- 11D5 | 0,21 | 0,21 | 0,20 | 0,20 | -4,8% | -4,8% | +20% | - |
| MDV-D71G/N1Y- 11D5 | 0,35 | 0,35 | 0,33 | 0,33 | -5,7% | -5,7% | +20% | - |
| MDV-D140Q4/N1-E | 0,75 | 0,75 | 0,67 | 0,68 | -10,7% | -9,3% | +20% | - |
| MDV-D90Q4/N1-E | 0,67 | 0,67 | 0,67 | 0,67 | 0,0% | 0,0% | +20% | - |
| MDV-D80Q4/N1-E | 0,48 | 0,48 | 0,41 | 0,41 | -14,6% | -14,6% | +20% | - |
| MDV-D71Q4/N1-E | 0,41 | 0,41 | 0,37 | 0,38 | -9,8% | -7,3% | +20% | - |
| MDV-D56Q4/N1-E | 0,41 | 0,41 | 0,41 | 0,40 | 0,0% | -2,4% | +20% | - |
| MDV-D71T2/N1- DA5(Welling motor: YSK61-4P(B)) | 0,47 | 0,47 | 0,48 | 0,49 | +2,1% | +4,3% | +20% | - |

| | | | | | | | | |
|---|------|------|------|------|--------|--------|------|---|
| MDV-D71T2/N1-DA5(Welling motor: YSK61-4P) | 0,47 | 0,47 | 0,48 | 0,49 | +2,1% | +4,3% | +20% | - |
| MDV-D71T2/N1-DA5(Match-well motor: YSK61-4P) | 0,47 | 0,47 | 0,48 | 0,47 | +2,1% | 0,0% | +20% | - |
| MDV-D71T2/N1-DA5 (Welling motor: YKSS-61-4-63) | 0,47 | 0,47 | 0,49 | 0,48 | +4,3% | +2,1% | +20% | - |
| MDV-D71T2/N1-DA5 (Tongde motor: YKSS-61-4-63) | 0,47 | 0,47 | 0,50 | 0,48 | +6,4% | +2,1% | +20% | - |
| MDV-D71T2/N1-DA5 (Match-well motor: YKSS-61-4-63) | 0,47 | 0,47 | 0,50 | 0,48 | +6,4% | +2,1% | +20% | - |
| MDV-D56T2/N1-DA5(Welling motor: YSK48-4P(B)) | 0,36 | 0,36 | 0,37 | 0,37 | +2,8% | +2,8% | +20% | - |
| MDV-D56T2/N1-DA5(Welling motor: YSK48-4P) | 0,36 | 0,36 | 0,37 | 0,38 | +2,8% | +5,6% | +20% | - |
| MDV-D56T2/N1-DA5(Yong an motor: YSK48-4P) | 0,36 | 0,36 | 0,37 | 0,37 | +2,8% | +2,8% | +20% | - |
| MDV-D56T2/N1-DA5(Welling motor: YKSS-36-4-65) | 0,36 | 0,36 | 0,35 | 0,35 | -2,8% | -2,8% | +20% | - |
| MDV-D56T2/N1-DA5(Tongde motor: YKSS-36-4-65) | 0,36 | 0,36 | 0,36 | 0,35 | 0,0% | -2,8% | +20% | - |
| MDV-D56T2/N1-DA5 (Yongan motor: YKSS-36-4-65) | 0,36 | 0,36 | 0,36 | 0,35 | -0,0% | -2,8% | +20% | - |
| MDV-D71T3/N1-C | 0,5 | 0,5 | 0,51 | 0,51 | +2,0% | +2,0% | +20% | - |
| MDV-D56T3/N1-C | 0,36 | 0,36 | 0,38 | 0,39 | +5,6% | +8,3% | +20% | - |
| MDV-D36T3/N1-C | 0,33 | 0,33 | 0,33 | 0,33 | 0,0% | 0,0% | +20% | - |
| MI-15G/DHN1-S | 0,25 | 0,25 | 0,21 | 0,20 | -16,0% | -20,0% | +20% | - |
| MI-56G/DHN1-S | 0,41 | 0,41 | 0,28 | 0,40 | -31,7% | -2,4% | +20% | - |
| MI-90G/DHN1-R3 | 0,68 | 0,68 | 0,46 | 0,40 | -32,3% | -41,2% | +20% | - |
| MI-140Q4/DHN1-D | 0,98 | 0,98 | 0,99 | 0,92 | 1,0% | -6,1% | +20% | - |
| MI-112Q4/DHN1-D | 0,82 | 0,82 | 0,82 | 0,74 | 0,0% | -9,8% | +20% | - |
| MI-80Q4/DHN1-D | 0,37 | 0,37 | 0,37 | 0,35 | 0,0% | -5,4% | +20% | - |
| MI-36Q4/DHN1-D | 0,32 | 0,32 | 0,33 | 0,31 | 3,1% | -3,1% | +20% | - |
| MI-45Q4/DHN1-A3 | 0,28 | 0,28 | 0,18 | 0,22 | -35,7% | -21,4% | +20% | - |
| MI-28Q4/DHN1-A3 | 0,26 | 0,26 | 0,22 | 0,29 | -15,4% | 11,5% | +20% | - |

| | | | | | | | | |
|--|------|------|------|------|--------|--------|------|----|
| MDV-D80T2/N1-BA5 (With fan motor YSK74-4E) | 1,00 | 1,00 | 0,57 | 0,52 | -43% | -48% | +20% | - |
| MDV-D56T2/N1-DA5 (With main control board MDV- D36Q4.D.1.1.1-2) | 0,36 | 0,36 | 0,33 | 0,29 | -8,3% | -19,4% | +20% | - |
| MDV-D90T1/N1-B (With main control board MDV- D36Q4.D.1.1.1-2) | 1,87 | 1,87 | 1,80 | 1,70 | -3,7% | -9,1% | +15% | - |
| MDV-D160T1/N1-B (With main control board MDV- D36Q4.D.1.1.1-2) | 4,77 | 4,77 | 3,60 | 3,40 | -24,5% | 28,7% | +15% | - |
| MI-36DL/DHN1-C | 0,32 | 0,32 | 0,10 | 0,10 | -68,8% | -68,8% | +20% | -- |
| MI-71DL/DHN1-C | 0,89 | 0,89 | 0,63 | 0,63 | -29,2% | -29,2% | +20% | -- |
| MI-90DL/DHN1-C | 1,14 | 1,14 | 0,81 | 0,81 | -28,9% | -28,9% | +20% | -- |
| MI-140DL/DHN1-C | 1,25 | 1,25 | 1,07 | 1,07 | -14,4% | -14,4% | +20% | -- |
| MI-56T2/DHN1-DA5 | 0,7 | 0,7 | 0,76 | 0,76 | 8,6% | 8,6% | +20% | -- |
| MI-71T2/DHN1-DA5 | 0,8 | 0,8 | 0,80 | 0,80 | 0,0% | 0,0% | +20% | -- |
| MI-90T2/DHN1-BA5 | 1,2 | 1,2 | 1,17 | 1,17 | -2,5% | -2,5% | +20% | -- |
| MI-112T2/DHN1-BA5 | 2,1 | 2,1 | 2,30 | 2,30 | 9,5% | 9,5% | +15% | -- |
| MI-140T2/DHN1-BA5 | 2,0 | 2,0 | 1,71 | 1,71 | -14,5% | -14,5% | +15% | -- |
| MI-45Z/DHN1-F3B | 0,35 | 0,35 | 0,25 | 0,25 | -28,6% | -28,6% | +20% | -- |
| MI-56Z/DHN1-F3B | 0,55 | 0,55 | 0,56 | 0,56 | 1,8% | 1,8% | +20% | -- |
| MI-80Z/DHN1-F3B | 0,82 | 0,82 | 0,82 | 0,82 | 0,0% | 0,0% | +20% | -- |
| MDV-D56Q1/N1-D | 0,32 | 0,32 | 0,23 | 0,23 | -28,1% | -28,1% | +20% | -- |
| MDV-D71Q1/N1-D | 0,36 | 0,36 | 0,27 | 0,27 | -25,0% | -25,0% | +20% | -- |
| MI-36G/N1-S | 0,14 | 0,14 | 0,13 | 0,13 | -7,1% | -7,1% | +20% | -- |
| MI-56G/N1-S | 0,20 | 0,20 | 0,18 | 0,18 | -10,0% | -10,0% | +20% | -- |
| MI-56Q4/N1-E | 0,48 | 0,48 | 0,40 | 0,40 | -16,7% | -16,7% | +20% | -- |
| MI-71Q4/N1-E | 0,48 | 0,48 | 0,40 | 0,40 | -16,7% | -16,7% | +20% | -- |
| MI-80Q4/N1-E | 0,59 | 0,59 | 0,56 | 0,58 | -5,1% | -1,7% | +20% | -- |
| MI-90Q4/N1-E | 0,98 | 0,98 | 0,62 | 0,62 | -36,7% | -36,7% | +20% | -- |
| MI-140Q4/N1-E | 1,01 | 1,01 | 0,90 | 0,80 | -10,9% | -20,8% | +20% | -- |
| MI-36T2/N1-EA5 | 0,39 | 0,39 | 0,43 | 0,42 | 10,3% | 7,7% | +20% | -- |
| MI-56T2/N1-EA5 | 0,46 | 0,46 | 0,51 | 0,5 | 10,9% | 8,7% | +20% | -- |
| MI-71T2/N1-EA5 | 0,47 | 0,47 | 0,47 | 0,42 | 0,0% | -10,6% | +20% | -- |
| MI-90T2/N1-EA5 | 1,0 | 1,0 | 0,86 | 0,9 | -14,0% | -10,0% | +20% | -- |
| MI-112T2/N1-EA5 | 1,8 | 1,8 | 1,43 | 1,50 | -20,6% | -16,7% | +15% | -- |

| | | | | | | | | |
|-------------------------|------|------|------|------|--------|--------|------|----|
| MI-140T2/N1-EA5 | 1,55 | 1,55 | 1,34 | 1,32 | -13,5% | -14,8% | +15% | -- |
| MI-28Q4/N1-A3 | 0,22 | 0,22 | 0,22 | 0,21 | 0,0% | -4,5% | +20% | -- |
| MI-45Q4/N1-A3 | 0,27 | 0,27 | 0,28 | 0,28 | 3,7% | 3,7% | +20% | -- |
| MI-80T1/DHN1-B | 1,7 | 1,7 | 1,5 | 1,4 | -11,8% | -17,6% | +15% | -- |
| MI-112T1/DHN1-B | 3,6 | 3,6 | 3,0 | 2,8 | -16,7% | -22,2% | +15% | -- |
| MI-160T1/DHN1-B | 4,5 | 4,5 | 3,8 | 3,6 | -15,6% | -20,0% | +15% | -- |
| MI-280T1/DHN1-B | 7,5 | 7,5 | 6,1 | 6,1 | -18,7% | -18,7% | +15% | -- |
| MI-140T1/DHN1-FA | 2,8 | 2,8 | 2,9 | 2,8 | 3,6% | 0,0% | +15% | -- |
| MI-280T1/DHN1-FA | 5 | 5 | 4,0 | 3,9 | -20,0% | -22,0% | +15% | -- |
| MI-22G/DHN1-M | 0,27 | 0,27 | 0,2 | 0,2 | -25,9% | -25,9% | +20% | -- |
| MI-28G/DHN1-M | 0,31 | 0,31 | 0,2 | 0,2 | -35,5% | -35,5% | +20% | -- |
| MI-36G/DHN1-M | 0,43 | 0,43 | 0,4 | 0,4 | -7,0% | -7,0% | +20% | -- |
| MI-45G/DHN1-M | 0,44 | 0,44 | 0,4 | 0,4 | -9,1% | -9,1% | +20% | -- |
| MI-56G/DHN1-M | 0,58 | 0,58 | 0,4 | 0,4 | -31,0% | -31,0% | +20% | -- |
| MI-71G/DHN1-M | 0,6 | 0,6 | 0,4 | 0,4 | -33,3% | -33,3% | +20% | -- |
| MI-80G/DHN1-M | 0,6 | 0,6 | 0,4 | 0,4 | -33,3% | -33,3% | +20% | -- |
| MI-90G/DHN1-M | 0,78 | 0,78 | 0,4 | 0,4 | -48,7% | -48,7% | +20% | -- |
| MI-28T2/DHN1-EA5 | 1,0 | 1,0 | 0,62 | 0,62 | -38,0% | -38,0% | +20% | -- |
| MI-90T2/DHN1-EA5 | 2,5 | 2,5 | 1,53 | 1,53 | -38,8% | -38,8% | +15% | -- |
| MI-140T2/DHN1-EA5 | 3,0 | 3,0 | 2,08 | 2,08 | -30,7% | -30,7% | +15% | -- |
| MI2-112T2DN1 welling | 1,5 | 1,5 | 0,9 | 0,8 | -40,0% | -46,7% | +20% | -- |
| MI2-112T2DN1 match-well | 1,5 | 1,5 | 0,9 | 0,8 | -40,0% | -46,7% | +20% | -- |
| MI2-140T2DN1 welling | 2,6 | 2,6 | 1,3 | 1,2 | -50,0% | -53,8% | +15% | -- |
| MI2-140T2DN1 match-well | 2,6 | 2,6 | 1,4 | 1,4 | -46,2% | -46,2% | +15% | -- |
| MI2-36Q1DN1 | 0,39 | 0,39 | 0,2 | 0,2 | -48,7% | -48,7% | +20% | -- |
| MI2-71Q1DN1 | 0,59 | 0,59 | 0,3 | 0,3 | -49,2% | -49,2% | +20% | -- |
| MI2-45Q2DN1 | 0,59 | 0,59 | 0,4 | 0,3 | -32,2% | -49,2% | +20% | -- |
| MI2-71Q2DN1 | 1,3 | 1,3 | 0,9 | 0,7 | -30,8% | -46,2% | +20% | -- |
| MI2-80Q4DN1 | 0,76 | 0,76 | 0,3 | 0,3 | -60,5% | -60,5% | +20% | -- |
| MI2-140Q4DN1 | 1,2 | 1,2 | 0,4 | 0,4 | -66,7% | -66,7% | +20% | -- |
| MI2-45Q4CDN1 | 0,48 | 0,48 | 0,3 | 0,2 | -37,5% | -58,3% | +20% | -- |
| MI2-36DLDN1 | 0,45 | 0,45 | 0,2 | 0,2 | -55,6% | -55,6% | +20% | -- |
| MI2-90DLDN1 | 1,3 | 1,3 | 0,6 | 0,6 | -53,8% | -53,8% | +20% | -- |
| MI2-140DLDN1 | 1,7 | 1,7 | 0,7 | 0,7 | -58,8% | -58,8% | +15% | -- |
| MI2-45F4DN1 | 0,55 | 0,55 | 0,3 | 0,3 | -45,5% | -45,5% | +20% | -- |

| | | | | | | | | |
|--------------------|------|------|-----|-----|--------|--------|------|----|
| MI2-80F5DN1 | 1,4 | 1,4 | 0,8 | 0,8 | -42,9% | -42,9% | +20% | -- |
| MI2-112T1DN1 | 2,9 | 2,9 | 2,1 | 2,1 | -2,7% | -2,7% | +15% | -- |
| MI2-160T1DN1 | 4,7 | 4,7 | 2,6 | 2,6 | -44,7% | -44,7% | +15% | -- |
| MI2-280T1DN1 | 6,7 | 6,7 | 4,3 | 4,2 | -35,8% | -37,7% | +15% | -- |
| MI2-140FADN1 | 3,5 | 3,5 | 0,9 | 1,0 | -74,3% | -71,4% | +15% | -- |
| MI2-280FADN1 | 5,2 | 5,2 | 5,4 | 5,3 | +3,8% | +1,9% | +15% | -- |
| MI2-28GDN1 welling | 0,32 | 0,32 | 0,2 | 0,1 | -37,5% | -68,8% | +20% | -- |
| MI2-56GDN1 welling | 0,58 | 0,58 | 0,2 | 0,2 | -65,6% | -65,6% | +20% | -- |
| MI2-90GDN1 welling | 1,1 | 1,1 | 0,4 | 0,5 | -63,6% | -54,5% | +20% | -- |
| MI2-80T1DN1 | 2,1 | 2,1 | 1,8 | 1,8 | -14,3% | -14,3% | +15% | -- |
| MI2-28GDN1 NIDEC | 0,32 | 0,32 | 0,1 | 0,1 | -68,8% | -68,8% | +20% | -- |
| MI2-56GDN1 NIDEC | 0,58 | 0,58 | 0,2 | 0,2 | -65,6% | -65,6% | +20% | -- |
| MI2-90GDN1 NIDEC | 1,1 | 1,1 | 0,4 | 0,4 | -63,6% | -63,6% | +20% | -- |
| MI2-28ZDN1 | 0,4 | 0,4 | 0,2 | 0,2 | -50,0% | -50,0% | +20% | -- |
| MI2-45ZDN1 | 0,53 | 0,53 | 0,3 | 0,2 | -43,4% | -62,3% | +20% | -- |

Remark: the test was performed with all alternative components and the severe result is listed

| | | | |
|------------------------|---|----------------------------------|---------------|
| 11.8 | TABLE: Heating test, thermocouples (cooling and heating mode) | | P |
| | Test voltage (V) | 206,8 and 254,4 V, 50 Hz | — |
| | Ambient (°C) | 32/- (Cooling) 27/- (Heating) | — |
| Thermocouple locations | | T(°C) | Max. T (°C) |
| MDV-D56T3/N1-B | | | |
| Fan motor enclosure | | 55,9 | For reference |
| Fan motor capacitor | | 36,4 | T70 |
| Terminal block | | 32,7 | 85 |
| Electric box | | 35,4 | For clause 30 |
| Transformer winding | | 36,7 | 110 |
| PCB | | 34,3 | 145 |
| Relay (ambient) | | 34,2 | T70 |
| X2 capacitor | | 34,0 | T100 |
| Communication terminal | | 33,7 | 85 |
| MDV-D56Q4/N1-D | | | |
| Fan motor enclosure | | 54,2 | For reference |
| MDV-D140Q4/N1-D | | | |
| Fan motor enclosure | | 48,5 | For reference |

| | | |
|---|-------|---------------|
| Fan motor capacitor | 26,1 | T70 |
| Terminal block | 26,2 | 85 |
| Transformer winding | 31,0 | 110 |
| PCB | 26,5 | 145 |
| Relay (ambient) | 27,0 | T70 |
| X2 capacitor | 26,9 | T100 |
| Communication terminal | 26,8 | 85 |
| Water pump | 31,77 | For reference |
| Louver fan motor | 27,4 | For reference |
| MDV-D90DL/N1-C | | |
| Fan motor enclosure | 55,8 | For reference |
| Fan motor capacitor | 32,6 | T70 |
| Terminal block | 31,4 | 85 |
| Transformer winding | 37,4 | 110 |
| PCB | 34,8 | 145 |
| Relay (ambient) | 32,2 | T70 |
| X2 capacitor | 32,4 | T100 |
| Communication terminal | 31,1 | 85 |
| Louver fan motor | 23,8 | For reference |
| MDV-D36G/N1YB | | |
| Fan motor enclosure | 50,0 | For reference |
| Fan motor capacitor | 34,1 | T70 |
| Terminal block | 33,4 | 85 |
| Transformer winding | 42,2 | 110 |
| PCB | 30,7 | 145 |
| Relay (ambient) | 33,3 | T70 |
| X2 capacitor | 31,3 | T100 |
| Communication terminal | 31,1 | 85 |
| Louver fan motor | 26,2 | For reference |
| Air outlet in front of supplementary heater | 20,4 | 90 |
| Protector for supplementary heater | 18,8 | For reference |
| MDV-D36T3/N1-B | | |
| Fan motor enclosure | 67,6 | For reference |
| Fan motor capacitor | 36,2 | T70 |
| Terminal block | 33,4 | 85 |
| Transformer winding | 33,6 | 110 |
| Electric box | 41,2 | For clause 30 |

| | | |
|---|------|---------------|
| PCB | 33,7 | 145 |
| Relay (ambient) | 33,3 | T70 |
| X2 capacitor | 33,0 | T100 |
| Communication terminal | 32,6 | 85 |
| MDV-D112Q4/N1-D | | |
| Fan motor enclosure | 50,6 | For reference |
| Fan motor capacitor | 29,2 | T70 |
| Terminal block | 29,2 | 85 |
| Transformer winding | 34,2 | 110 |
| PCB | 29,1 | 145 |
| Relay (ambient) | 29,4 | T70 |
| X2 capacitor | 29,2 | T100 |
| Communication terminal | 28,6 | 85 |
| Water pump | 39,6 | For reference |
| Louver fan motor | 42,8 | For reference |
| MDV-D80Q4/N1-D | | |
| Fan motor enclosure | 51,3 | For reference |
| MDV-D56G/DN1YB | | |
| Fan motor enclosure | 47,6 | For reference |
| Fan motor capacitor | 36,4 | T70 |
| Terminal block | 32,5 | 85 |
| Transformer winding | 47,8 | 110 |
| PCB | 32,4 | 145 |
| Relay (ambient) | 33,7 | T70 |
| X2 capacitor | 33,2 | T100 |
| Communication terminal | 36,2 | 85 |
| Louver fan motor | 33,2 | For reference |
| Air outlet in front of supplementary heater | 32,1 | 90 |
| Protector for supplementary heater | 32,6 | For reference |
| MDV-D36Q1/N1-C | | |
| Fan motor enclosure | 37,9 | For reference |
| Fan motor capacitor | 30,2 | T70 |
| Terminal | 31,5 | 85 |
| Electric box | 32,5 | For clause 30 |
| Transformer winding | 37,5 | 110 |
| PCB | 33,7 | 145 |
| Fan motor relay (ambient) | 32,5 | T70 |

| | | |
|---------------------------|------|---------------|
| X2 capacitor | 31,9 | T100 |
| MDV-D140DL/N1-C | | |
| Fan motor enclosure | 48,3 | For reference |
| Fan motor capacitor | 32,6 | T70 |
| Terminal block | 31,1 | 85 |
| Transformer winding | 40,0 | 110 |
| PCB | 31,0 | 145 |
| Relay (ambient) | 33,8 | T70 |
| X2 capacitor | 32,0 | T100 |
| Communication terminal | 31,5 | 85 |
| Louver fan motor | 33,6 | For reference |
| MDV-D56Q1/N1-C | | |
| Fan motor enclosure | 56,9 | For reference |
| Fan motor capacitor | 28,6 | T70 |
| Terminal block | 28,6 | 85 |
| Electric box | 29,4 | For clause 30 |
| Transformer winding | 37,0 | 110 |
| PCB | 31,1 | 145 |
| Relay (ambient) | 31,2 | T70 |
| X2 capacitor | 30,7 | T100 |
| Communication terminal | 30,1 | 85 |
| MDV-D56G/N1YB | | |
| Fan motor enclosure | 49,1 | For reference |
| Fan motor capacitor | 34,9 | T70 |
| Terminal | 30,5 | 85 |
| Louver motor | 41,9 | For reference |
| Transformer winding | 40,7 | 110 |
| PCB | 33,0 | 145 |
| Fan motor relay (ambient) | 32,5 | T70 |
| X2 capacitor | 34,2 | T100 |
| MDV-D36G/N1YB | | |
| Fan motor enclosure | 55 | For reference |
| MDV-D36DL/N1-C | | |
| Fan motor enclosure | 47,2 | For reference |
| MDV-D71DL/N1-C | | |
| Fan motor enclosure | 53,3 | For reference |
| MDV-D22Z/N1-F1B | | |

| | | |
|------------------------|-------|---------------|
| Fan motor enclosure | 25,5 | For reference |
| Fan motor capacitor | 28,5 | T70 |
| MDV-D71Z/N1-F3B | | |
| Fan motor enclosure | 47,8 | For reference |
| Fan motor capacitor | 32,4 | T70 |
| Terminal block | 32,7, | 85 |
| Transformer winding | 37,9 | 110 |
| PCB | 32,5 | 145 |
| Relay (ambient) | 32,7 | T70 |
| X2 capacitor | 32,1 | T100 |
| Communication terminal | 31,4 | 85 |
| MDV-D45Z/N1-F4 | | |
| Fan motor enclosure | 34,9 | For reference |
| Fan motor capacitor | 29,4 | T70 |
| MDV-D36Z/DN1-B | | |
| Fan motor enclosure | 24,6 | For reference |
| Terminal block | 27,7 | 85 |
| Transformer winding | 37,0 | 110 |
| PCB | 28,6 | 145 |
| Relay (ambient) | 32,2 | T70 |
| X2 capacitor | 34,5 | T100 |
| Communication terminal | 28,5 | 85 |
| Louver motor | 22,4 | For reference |
| MDV-D45Q4/N1-A3 | | |
| Fan motor enclosure | 37,4 | For reference |
| Fan motor capacitor | 26,8 | T70 |
| Terminal block | 29,4 | 85 |
| Transformer winding | 25,8 | 110 |
| PCB | 32,5 | 145 |
| Relay (ambient) | 32,7 | T70 |
| X2 capacitor | 28,2 | T100 |
| Communication terminal | 31,4 | 85 |
| Louver motor | 33,1 | For reference |
| MDV-D22T2/N1X-BA5 | | |
| Fan motor enclosure | 34,5 | For reference |
| Fan motor capacitor | 31,4 | T70 |
| MDV-D112T2/N1-BA5 | | |

| | | |
|------------------------|------|---------------|
| Fan motor enclosure | 41,4 | For reference |
| Fan motor capacitor | 30,3 | T70 |
| MDV-D22Q2/N1 | | |
| Fan motor enclosure | 42,9 | For reference |
| Fan motor capacitor | 33,6 | T70 |
| MDV-D56T2/N1-BA5 | | |
| Fan motor enclosure | 50,7 | For reference |
| Fan motor capacitor | 32,9 | T70 |
| MDV-D80T2/N1-BA5 | | |
| Fan motor enclosure | 51,8 | For reference |
| Fan motor capacitor | 30,2 | T70 |
| MDV-D45Q2/N1 | | |
| Fan motor enclosure | 40,7 | For reference |
| Fan motor capacitor | 29,6 | T70 |
| MDV-D71Q2/N1 | | |
| Fan motor enclosure | 48,1 | For reference |
| Fan motor capacitor | 34,6 | T70 |
| Terminal block | 31,0 | 85 |
| Transformer winding | 42,6 | 110 |
| PCB | 33,6 | 145 |
| Relay (ambient) | 36,0 | T70 |
| X2 capacitor | 34,9 | T100 |
| Communication terminal | 29,5 | 85 |
| MDV-200T1/N1-B | | |
| Fan motor enclosure | 29,7 | For reference |
| Fan motor capacitor | 29,8 | T70 |
| Terminal block | 32,7 | 85 |
| Transformer winding | 39,0 | 110 |
| PCB | 32,3 | 145 |
| Relay (ambient) | 36,2 | T70 |
| X2 capacitor | 37,8 | T100 |
| Communication terminal | 30,8 | 85 |
| MDV-D140T1/N1-FA | | |
| Fan motor enclosure | 81,9 | For reference |
| Fan motor capacitor | 43,2 | T70 |
| Terminal block | 46,6 | 85 |
| PCB | 47,0 | 145 |

| | | |
|--|------|---------------|
| Relay (ambient) | 44,9 | T70 |
| X2 capacitor | 45,9 | T100 |
| Communication terminal | 44,8 | 85 |
| MDV-D280T1/N1-FA | | |
| Fan motor enclosure | 63,0 | For reference |
| Fan motor capacitor | 59,1 | T70 |
| MDV-D80T1/N1-B | | |
| Fan motor enclosure | 47,9 | For reference |
| Fan motor capacitor | 33,3 | T70 |
| MDV-D90T1/N1-B | | |
| Fan motor enclosure | 44,4 | For reference |
| Fan motor capacitor | 31,0 | T70 |
| MDV-D112T1/N1-B | | |
| Fan motor enclosure | 25,5 | For reference |
| Fan motor capacitor | 31,7 | T70 |
| MDV-D160T1/N1-B | | |
| Fan motor enclosure | 39,9 | For reference |
| Fan motor capacitor | 29,0 | T70 |
| MDV-D36G/DN1YB with fan motor YDK15-6 | | |
| Fan motor enclosure | 48,7 | For reference |
| Fan motor Capacitor (IU) | 34,9 | T70 |
| Fan motor relay (ambient) | 32,1 | T70 |
| MDV-D56G/DN1YB with fan motor YDK18-4 | | |
| Fan motor enclosure | 54,0 | For reference |
| Fan motor Capacitor (IU) | 40,2 | T70 |
| Fan motor relay (ambient) | 36,6 | T70 |
| MDV-D56Q4/N1-D with fan motor YDK60-6F-3 | | |
| Fan motor enclosure | 55,4 | For reference |
| Fan motor Capacitor (IU) | 23,0 | T70 |
| Fan motor relay (ambient) | 26,7 | T70 |
| MDV-D80Q4/N1-D with fan motor YDK80-6E-2 | | |
| Fan motor enclosure | 66,1 | For reference |
| Fan motor Capacitor (IU) | 26,5 | T70 |
| Fan motor relay (ambient) | 24,0 | T70 |
| MDV-D280T1/N1-B with fan motor YDK550-4X(Match-well) | | |
| Fan motor enclosure | 42,0 | For reference |

| | | |
|---|------|---------------|
| Fan motor Capacitor (IU) | 33,5 | T70 |
| Fan motor relay (ambient) | 34,7 | T70 |
| MDV-D280T1/N1-FA with fan motor YDK250-4X(Match-well) | | |
| Fan motor enclosure | 63,0 | For reference |
| Fan motor Capacitor (IU) | 59,1 | T70 |
| MDV-D71T2/N1-CA5 | | |
| Fan motor enclosure | 44,8 | For reference |
| Relay (ambient) | 37,2 | T70 |
| Fan motor capacitor | 33,1 | T70 |
| Terminal block I | 31,4 | 85 |
| Terminal block II | 32,2 | 85 |
| Main PCB | 33,1 | 145 |
| Transformer winding | 39,4 | 110 |
| X2 capacitor | 32,1 | T100 |
| Varistor | 33,1 | T85 |
| Internal wire | 32,6 | 75 |
| MDV-D80G-R3/N1Y | | |
| Fan motor enclosure | 56,1 | For reference |
| Relay I (ambient) | 38,3 | T85 |
| Relay II (ambient) | 38,2 | T70 |
| Fan motor capacitor | 36,8 | T70 |
| Terminal block I | 33,1 | 85 |
| Terminal block II | 32,6 | 85 |
| Main PCB | 32,9 | 145 |
| Fan outlet | 19,3 | 90 |
| Transformer winding | 41,0 | 110 |
| Test corner | 31,4 | 90 |
| X2 capacitor | 36,5 | T100 |
| Varistor | 38,7 | T85 |
| Internal wire | 32,7 | 75 |
| Louver motor | 31,7 | For reference |
| Electric box | 34,1 | For clause 30 |
| MDV-D560T1/N1 | | |
| Fan motor enclosure(yongan) | 68,2 | For reference |
| Fan motor enclosure(Welling) | 64,8 | For reference |
| Relay (ambient) | 43,9 | T70 |

| | | |
|---|------|---------------|
| Fan motor capacitor | 33,6 | T70 |
| Terminal block I | 33,0 | 85 |
| Terminal block II | 35,2 | 85 |
| Main PCB | 39,2 | 145 |
| Fan outlet | 38,8 | 90 |
| Transformer winding | 38,6 | 110 |
| Test corner | 44,1 | 90 |
| X2 capacitor | 28,9 | T100 |
| Varistor | 40,3 | T85 |
| Internal wire | 40,3 | 75 |
| Winding of electromagnetic valve | 42,6 | 110 |
| MDV-D450T1/N1 | | |
| Fan motor enclosure(yongan) | 63,3 | For reference |
| Fan motor enclosure(Welling) | 67,2 | For reference |
| Relay (ambient) | 42,2 | T70 |
| Fan motor capacitor | 32,4 | T70 |
| Terminal block I | 34,6 | 85 |
| Terminal block II | 37,2 | 85 |
| Main PCB | 38,3 | 145 |
| Power cord | 80,4 | 75 |
| Fan outlet | 39,8 | 90 |
| Transformer winding | 43,9 | 110 |
| X2 capacitor | 39,4 | T100 |
| Varistor | 38,7 | T85 |
| Internal wire | 39,1 | 75 |
| Winding of electromagnetic valve | 34,0 | 110 |
| MDV-D36T2/N1-DA5 (With Welling motor: YSK27-4C(B)) | | |
| Fan motor enclosure | 39,7 | For reference |
| Fan motor capacitor | 32,6 | T70 |
| Relay (ambient) | 36,7 | T70 |
| Fan outlet | 40,7 | 90 |
| Transformer winding | 39,3 | 110 |
| Terminal block | 34,1 | 85 |
| X2 capacitor | 37,4 | T100 |
| MDV-D36T2/N1-DA5 (With Welling motor: YSK27-4C) | | |

| | | |
|--|------|---------------|
| Fan motor enclosure | 39,7 | For reference |
| Fan motor capacitor | 32,6 | T70 |
| Relay (ambient) | 36,7 | T70 |
| Fan outlet | 40,7 | 90 |
| Transformer winding | 39,3 | 110 |
| Terminal block | 34,1 | 85 |
| X2 capacitor | 37,4 | T100 |
| MDV-D36T2/N1-DA5 (With Yong an motor: YSK27-4C) | | |
| Fan motor enclosure | 39,7 | For reference |
| Fan motor capacitor | 32,6 | T70 |
| Relay (ambient) | 36,5 | T70 |
| Fan outlet | 27,3 | 90 |
| Transformer winding | 39,3 | 110 |
| Terminal block | 34,1 | 85 |
| X2 capacitor | 37,4 | T100 |
| For model MDV-D36T2/N1-DA5 with fan motor YSK27-4C by welling (Cooling 50Hz) | | |
| Terminal block | 31,2 | 90 |
| Supply cord | 31,9 | 75 |
| Surface | 25,8 | 60 |
| Test corner | 32,1 | 90 |
| For model MDV-D36T2/N1-DA5 with fan motor YSK27-4C by tongde (Cooling 50Hz) | | |
| Terminal block | 31,5 | 90 |
| Supply cord | 31,5 | 75 |
| Surface | 27,5 | 60 |
| Test corner | 31,8 | 90 |
| For model MDV-D36T2/N1-DA5 with fan motor YSK27-4C by yongan (Cooling 50Hz) | | |
| Terminal block | 31,1 | 90 |
| Supply cord | 31,2 | 75 |
| Surface | 25,6 | 60 |
| Test corner | 31,8 | 90 |
| For model MDV-D36T2/N1-DA5 with fan motor YSK27-4C by welling (heating 50Hz) | | |
| Terminal block | 30,7 | 90 |
| Supply cord | 28,9 | 75 |
| Surface | 34,3 | 60 |
| Test corner | 26,7 | 90 |
| For model MDV-D36T2/N1-DA5 with fan motor YSK27-4C by tongde (heating 50Hz) | | |

| | | |
|---|------|---------------|
| Terminal block | 33,7 | 90 |
| Supply cord | 31,3 | 75 |
| Surface | 33,5 | 60 |
| Test corner | 28,8 | 90 |
| For model MDV-D36T2/N1-DA5 with fan motor YSK27-4C by yongan (heating 50Hz) | | |
| Terminal block | 32,8 | 90 |
| Supply cord | 30,8 | 75 |
| Surface | 37,4 | 60 |
| Test corner | 28,0 | 90 |
| MDV-D17Q4/N1-A3 | | |
| Fan motor enclosure | 55,8 | For reference |
| Relay (ambient) | 34,9 | T70 |
| Fan motor capacitor | 33,3 | T70 |
| Terminal block | 32,7 | 85 |
| PCB | 34,3 | 130 |
| Power supply cord | 32,5 | 75 |
| Fan outlet | 40,9 | 90 |
| Transformer winding | 34,5 | 110 |
| X2 capacitor | 35,5 | T100 |
| MDV-D17G/N1-S | | |
| Fan motor enclosure | 54,7 | For reference |
| Relay (ambient) | 36,2 | T70 |
| Fan motor capacitor | 32,6 | T70 |
| Terminal block | 36,3 | 85 |
| PCB | 35,6 | 145 |
| Power supply cord | 34,7 | 75 |
| Fan outlet | 33,7 | 90 |
| Transformer winding | 33,2 | 110 |
| X2 capacitor | 42,6 | T100 |
| MDV-D36Q1/N1-D | | |
| Fan motor enclosure(Welling) | 61,1 | For reference |
| Fan motor enclosure(Broad- ocean) | 63,3 | For reference |
| Relay (ambient) | 50,2 | T70 |
| Stepper motor | 33,2 | For reference |
| Water pump | 30,9 | For reference |
| Fan motor capacitor | 31,5 | T70 |
| Terminal block | 33,5 | 85 |

| | | |
|-----------------------------------|------|---------------|
| X2 capacitor | 36,6 | T100 |
| PCB | 34,9 | 145 |
| Power supply cord | 33,3 | 75 |
| Fan outlet | 49,4 | 90 |
| Transformer winding | 37,8 | 110 |
| MDV-D22G/N1Y-11D5 | | |
| Fan motor enclosure(Welling) | 32,4 | For reference |
| Fan motor enclosure(Broad- ocean) | 33,1 | For reference |
| Relay (ambient) | 46,3 | T70 |
| Fan motor capacitor | 41,7 | T70 |
| Terminal block I | 40,1 | 85 |
| Terminal block II | 40,2 | 85 |
| PCB | 42,5 | 145 |
| Power supply cord | 39,1 | 75 |
| Fan outlet | 43,2 | 90 |
| Transformer winding | 46,4 | 110 |
| Test corner | 45,2 | 90 |
| X2 capacitor | 45,0 | T100 |
| MDV-D71G/N1Y-11D5 | | |
| Fan motor enclosure(Welling) | 32,3 | For reference |
| Fan motor enclosure(Broad- ocean) | 32,8 | For reference |
| Relay (ambient) | 40,8 | T70 |
| Fan motor capacitor | 36,2 | T70 |
| Terminal block I | 40,5 | 85 |
| Terminal block II | 40,7 | 85 |
| PCB | 42,2 | 145 |
| Power supply cord | 40,0 | 75 |
| Fan outlet | 65,3 | 90 |
| Transformer winding | 43,6 | 110 |
| Appliance enclosure | 33,2 | 85 |
| X2 capacitor | 37,7 | T100 |
| Varistor | 36,4 | T85 |
| Internal wire | 36,6 | 75 |
| MDV-D140Q4/N1-E | | |
| Fan motor enclosure(tongde) | 55,0 | For reference |
| Fan motor enclosure(welling) | 53,5 | For reference |
| Fan motor enclosure(broad-ocean) | 53,4 | For reference |

| | | |
|----------------------------------|------|---------------|
| Fan motor capacitor(tongde) | 30,7 | T70 |
| Fan motor capacitor(welling) | 30,5 | T70 |
| Fan motor capacitor(broad-ocean) | 30,2 | T70 |
| Power supply | 32,4 | 75 |
| Terminal block I | 31,8 | 85 |
| Terminal block II | 31,5 | 85 |
| Winding of transformer | 35,0 | 110 |
| Main PCB | 31,4 | 145 |
| Relay (ambient) | 32,2 | T70 |
| X2 capacitor | 32,1 | T100 |
| Varistor | 31,5 | T85 |
| Step motor | 34,6 | For reference |
| Appliance enclosure | 35,1 | 85 |
| Water pump | 48,4 | 110 |
| Air outlet | 48,1 | 90 |
| Internal wire | 31,5 | 90 |
| MDV-D90Q4/N1-E | | |
| Fan motor enclosure(tongde) | 46,7 | For reference |
| Fan motor enclosure(welling) | 46,6 | For reference |
| Fan motor enclosure(broad-ocean) | 46,7 | For reference |
| Fan motor capacitor(tongde) | 31,3 | T70 |
| Fan motor capacitor(welling) | 30,9 | T70 |
| Fan motor capacitor(broad-ocean) | 30,9 | T70 |
| Power supply | 38,8 | 75 |
| Terminal block I | 34,9 | 85 |
| Terminal block II | 32,6 | 85 |
| Winding of transformer | 33,4 | 110 |
| Main PCB | 33,8 | 145 |
| Relay I (ambient) | 31,1 | T70 |
| Relay II (ambient) | 31,7 | T80 |
| X2 capacitor | 31,7 | T100 |
| Varistor | 33,1 | T85 |
| Step motor | 36,1 | For reference |
| Appliance enclosure | 32,6 | 85 |
| Water pump | 44,6 | 110 |
| Air outlet | 36,1 | 90 |
| Internal wire | 35,0 | 75 |

| | | |
|----------------------------------|------|---------------|
| MDV-D80Q4/N1-E | | |
| Fan motor enclosure(tongde) | 39,8 | For reference |
| Fan motor enclosure(welling) | 42,0 | For reference |
| Fan motor enclosure(broad-ocean) | 43,2 | For reference |
| Fan motor capacitor(tongde) | 32,6 | T70 |
| Fan motor capacitor(welling) | 32,9 | T70 |
| Fan motor capacitor(broad-ocean) | 32,9 | T70 |
| Power supply | 36,0 | 75 |
| Terminal block I | 34,2 | 85 |
| Terminal block II | 38,1 | 85 |
| Winding of transformer | 37,3 | 110 |
| Main PCB | 33,8 | 145 |
| Relay I (ambient) | 33,7 | T70 |
| Relay II (ambient) | 33,7 | T80 |
| X2 capacitor | 33,5 | T100 |
| Varistor | 34,5 | T85 |
| Internal wire | 37,4 | 75 |
| Air outlet | 31,8 | 90 |
| Step motor | 36,2 | For reference |
| Enclosure | 30,8 | 85 |
| MDV-D71Q4/N1-E | | |
| Fan motor enclosure(tongde) | 62,0 | For reference |
| Fan motor enclosure(welling) | 58,5 | For reference |
| Fan motor enclosure(broad-ocean) | 61,5 | For reference |
| Fan motor capacitor(tongde) | 35,1 | T70 |
| Fan motor capacitor(welling) | 34,5 | T70 |
| Fan motor capacitor(broad-ocean) | 34,5 | T70 |
| Power supply | 40,8 | 75 |
| Terminal block I | 36,7 | 85 |
| Terminal block II | 34,2 | 85 |
| Winding of transformer | 35,8 | 110 |
| Main PCB | 35,7 | 145 |
| Relay I (ambient) | 33,9 | T70 |
| Relay II (ambient) | 33,6 | T80 |
| X2 capacitor | 34,8 | T100 |
| Varistor | 35,1 | T85 |
| Internal wire | 34,2 | 75 |

| | | |
|--|------|---------------|
| Air out-let | 48,6 | 90 |
| Water pump | 49,7 | 110 |
| Step motor | 31,5 | For reference |
| Enclosure | 32,8 | 85 |
| MDV-D56Q4/N1-E | | |
| Fan motor enclosure(tongde) | 51,7 | For reference |
| Fan motor enclosure(welling) | 50,3 | For reference |
| Fan motor enclosure(broad-ocean) | 52,3 | For reference |
| Fan motor capacitor(tongde) | 34,4 | T70 |
| Fan motor capacitor(welling) | 33,5 | T70 |
| Fan motor capacitor(broad-ocean) | 33,5 | T70 |
| Power supply | 34,4 | 75 |
| Terminal block I | 34,5 | 85 |
| Terminal block II | 34,9 | 85 |
| Winding of transformer | 36,2 | 110 |
| Main PCB | 34,8 | 145 |
| Relay I (ambient) | 36,7 | T70 |
| Relay II (ambient) | 36,2 | T80 |
| X2 capacitor | 36,1 | T85 |
| Varistor | 37,4 | T100 |
| Internal wire | 34,9 | 75 |
| Air outlet | 48,4 | 90 |
| Water pump | 49,2 | 110 |
| Step motor | 38,5 | For reference |
| Appliance enclosure | 32,8 | 85 |
| MDV-D71T2/N1-DA5 | | |
| Fan motor enclosure (tongde: YSK61-4P(B)) | 47,8 | For reference |
| Fan motor enclosure (welling: YSK61-4P(B)) | 49,0 | For reference |
| Fan motor enclosure (welling: YSK61-4P) | 49,0 | For reference |
| Fan motor enclosure (Match-Well: YSK61-4P) | 47,8 | For reference |
| Fan motor capacitor (tongde: YSK61-4P(B)) | 32,2 | T70 |
| Fan motor capacitor (welling: YSK61-4P(B)) | 32,1 | T70 |
| Fan motor capacitor (welling: YSK61-4P) | 32,1 | T70 |
| Fan motor capacitor (Match-Well: YSK61-4P) | 32,2 | T70 |
| Power supply | 32,5 | 75 |
| Terminal block I | 33,1 | 85 |
| Terminal block II | 33,8 | 85 |

| | | |
|---|------|------|
| Main PCB | 34,5 | 145 |
| Relay I (ambient) | 37,0 | T70 |
| Relay II (ambient) | 36,8 | T80 |
| Winding of transformer | 41,0 | 110 |
| X2 capacitor | 36,2 | T100 |
| Varistor | 36,1 | T85 |
| Internal wire | 40,4 | 75 |
| Water pump | 44,1 | 110 |
| For model MDV-D71T2/N1-DA5 with fan motor YKSS-61-4-63 by welling (Cooling 50Hz) | | |
| Terminal block | 31,8 | 90 |
| Supply cord | 31,9 | 75 |
| Surface | 25,7 | 60 |
| Test corner | 32,1 | 90 |
| For model MDV-D71T2/N1-DA5 with fan motor YKSS-61-4-63 by tongde (Cooling 50Hz) | | |
| Terminal block | 31,5 | 90 |
| Supply cord | 31,5 | 75 |
| Surface | 27,5 | 60 |
| Test corner | 31,8 | 90 |
| For model MDV-D71T2/N1-DA5 with fan motor YKSS-61-4-63 by matchwell (Cooling 50Hz) | | |
| Terminal block | 31,1 | 90 |
| Supply cord | 31,2 | 75 |
| Surface | 24,6 | 60 |
| Test corner | 32,1 | 90 |
| For model MDV-D71T2/N1-DA5 with fan motor YKSS-61-4-63 by welling (heating 50Hz) | | |
| Terminal block | 30,7 | 90 |
| Supply cord | 28,4 | 75 |
| Surface | 34,7 | 60 |
| Test corner | 26,7 | 90 |
| For model MDV-D71T2/N1-DA5 with fan motor YKSS-61-4-63 by tongde (heating 50Hz) | | |
| Terminal block | 33,7 | 90 |
| Supply cord | 31,4 | 75 |
| Surface | 33,4 | 60 |
| Test corner | 28,3 | 90 |
| For model MDV-D71T2/N1-DA5 with fan motor YKSS-61-4-63 by match-well (heating 50Hz) | | |
| Terminal block | 32,7 | 90 |
| Supply cord | 30,8 | 75 |
| Surface | 37,2 | 60 |

| | | |
|--|------|---------------|
| Test corner | 28,0 | 90 |
| MDV-D56T2/N1-DA5 | | |
| Fan motor enclosure (tongde: YSK48-4P(B)) | 45,9 | For reference |
| Fan motor enclosure (welling: YSK48-4P(B)) | 45,7 | For reference |
| Fan motor enclosure (welling: YSK48-4P) | 45,7 | For reference |
| Fan motor enclosure (Yong an: YSK48-4P) | 45,9 | For reference |
| Fan motor capacitor (tongde: YSK48-4P(B)) | 32,4 | T70 |
| Fan motor capacitor (welling: YSK48-4P(B)) | 32,3 | T70 |
| Fan motor capacitor (welling: YSK48-4P) | 32,5 | T70 |
| Fan motor capacitor (Yong an: YSK48-4P) | 32,4 | T70 |
| Power supply | 32,5 | 75 |
| Terminal block I | 32,5 | 85 |
| Terminal block II | 33,5 | 85 |
| Winding of transformer | 42,1 | 110 |
| Main PCB | 34,4 | 145 |
| Relay I (ambient) | 39,2 | T70 |
| Relay II (ambient) | 38,2 | T80 |
| X2 capacitor | 35,8 | T100 |
| Varistor | 36,1 | T85 |
| Internal wire | 35,4 | 75 |
| Air out-let | 41,9 | 85 |
| Installation surface | 32,2 | For reference |
| For model MDV-D56T2/N1-DA5 with fan motor YKSS-36-4-65 by welling (Cooling 50Hz) | | |
| Terminal block | 31,9 | 90 |
| Supply cord | 31,3 | 75 |
| Surface | 24,6 | 60 |
| Test corner | 32,1 | 90 |
| For model MDV-D56T2/N1-DA5 with fan motor YKSS-36-4-65 by tongde (Cooling 50Hz) | | |
| Terminal block | 32,5 | 90 |
| Supply cord | 31,2 | 75 |
| Surface | 23,8 | 60 |
| Test corner | 32,1 | 90 |
| For model MDV-D56T2/N1-DA5 with fan motor YKSS-36-4-65 by yongan (Cooling 50Hz) | | |
| Terminal block | 31,5 | 90 |
| Supply cord | 31,4 | 75 |
| Surface | 24,5 | 60 |
| Test corner | 32,1 | 90 |

| | | |
|--|------|---------------|
| For model MDV-D56T2/N1-DA5 with fan motor YKSS-36-4-65 by welling (heating 50Hz) | | |
| Terminal block | 31,0 | 90 |
| Supply cord | 31,1 | 75 |
| Surface | 35,8 | 60 |
| Test corner | 27,3 | 90 |
| For model MDV-D56T2/N1-DA5 with fan motor YKSS-36-4-65 by tongde (heating 50Hz) | | |
| Terminal block | 33,3 | 90 |
| Supply cord | 32,0 | 75 |
| Surface | 37,6 | 60 |
| Test corner | 27,7 | 90 |
| For model MDV-D56T2/N1-DA5 with fan motor YKSS-36-4-65 by yongan (heating 50Hz) | | |
| Terminal block | 32,9 | 90 |
| Supply cord | 31,7 | 75 |
| Surface | 36,0 | 60 |
| Test corner | 27,8 | 90 |
| MDV-D71T3/N1-C | | |
| Fan motor enclosure(tongde) | 64,0 | For reference |
| Fan motor enclosure(welling) | 64,5 | For reference |
| Fan motor capacitor(tongde) | 32,8 | T70 |
| Fan motor capacitor(welling) | 32,6 | T70 |
| Power supply | 34,0 | 75 |
| Terminal block I | 32,7 | 85 |
| Terminal block II | 32,8 | 85 |
| Main PCB | 35,3 | 145 |
| Relay I (ambient) | 35,4 | T70 |
| Relay II (ambient) | 36,1 | T70 |
| Winding of transformer | 39,4 | 110 |
| X2 capacitor | 35,5 | T100 |
| Varistor | 35,7 | T85 |
| Internal wire | 33,1 | 75 |
| MDV-D56T3/N1-C | | |
| Fan motor enclosure(tongde) | 44,8 | For reference |
| Fan motor enclosure(welling) | 45,7 | For reference |
| Fan motor capacitor(tongde) | 31,5 | T70 |
| Fan motor capacitor(welling) | 32,0 | T70 |
| Power supply | 32,4 | 75 |
| Terminal block I | 32,0 | 85 |

| | | |
|------------------------------|------|---------------|
| Terminal block II | 32,1 | 85 |
| Winding of transformer | 36,2 | 110 |
| Main PCB | 32,5 | 145 |
| Relay I (ambient) | 34,3 | T70 |
| Relay II (ambient) | 34,1 | T70 |
| X2 capacitor | 33,4 | T100 |
| Varistor | 33,4 | T85 |
| Internal wire | 32,9 | 75 |
| Air outlet | 45,5 | 90 |
| Appliance enclosure | 32,8 | 85 |
| MDV-D36T3/N1-C | | |
| Fan motor enclosure(tongde) | 46,3 | For reference |
| Fan motor enclosure(welling) | 49,8 | For reference |
| Fan motor capacitor(tongde) | 30,7 | T70 |
| Fan motor capacitor(welling) | 31,3 | T70 |
| Power supply | 32,0 | 75 |
| Terminal block I | 31,3 | 85 |
| Terminal block II | 31,1 | 85 |
| Winding of transformer | 32,4 | 110 |
| Main PCB | 32,1 | 145 |
| Relay I (ambient) | 33,1 | T70 |
| Relay II (ambient) | 31,7 | T70 |
| Winding of transformer | 32,8 | 110 |
| X2 capacitor | 32,5 | T100 |
| Varistor | 41,7 | T85 |
| Internal wire | 31,0 | 75 |
| Appliance enclosure | 47,3 | 85 |
| MI-56G/DHN1-S | | |
| Fan motor winding(NIDEC) | 38,9 | For reference |
| Fan motor enclosure(Welling) | 40,1 | For reference |
| Terminal block I | 33,2 | 85 |
| Terminal block II | 33,1 | 85 |
| Main PCB | 36,2 | 145 |
| Relay (ambient) | 39,4 | T70 |
| X2 capacitor 1 | 38,2 | T100 |
| X2 capacitor 2 | 39,0 | T100 |
| Winding of transformer | 39,7 | 110 |

| | | |
|------------------------------|------|---------------|
| Varistor | 35,1 | T85 |
| Internal wire | 34,8 | 75 |
| Power supply | 34,1 | 75 |
| Swing motor | 32,1 | For reference |
| Display PCB | 28,8 | 145 |
| MI-90G/DHN1-R3 | | |
| Fan motor winding(NIDEC) | 39,4 | 105 |
| Fan motor enclosure(Welling) | 39,4 | 105 |
| Terminal block I | 32,1 | 85 |
| Terminal block II | 32,2 | 85 |
| Main PCB | 32,2 | 145 |
| Relay I (ambient) | 33,3 | T80 |
| Relay II (ambient) | 36,0 | T70 |
| X2 capacitor 1 | 36,4 | T100 |
| X2 capacitor 2 | 40,7 | T100 |
| Winding of transformer | 39,5 | 110 |
| Varistor | 35,6 | T85 |
| Electrolytic capacitor | 39,2 | T85 |
| Internal wire | 34,8 | 75 |
| Power supply | 32,4 | 75 |
| Swing motor | 32,0 | For reference |
| Display PCB | 31,7 | 145 |
| MI-15G/DHN1-S | | |
| Fan motor winding(NIDEC) | 36,5 | 105 |
| Fan motor enclosure(Welling) | 33,2 | 105 |
| Terminal block I | 32,4 | 85 |
| Terminal block II | 32,4 | 85 |
| Main PCB | 34,4 | 145 |
| Relay I (ambient) | 38,6 | T80 |
| Relay II (ambient) | 37,5 | T70 |
| X2 capacitor 1 | 38,1 | T100 |
| X2 capacitor 2 | 39,0 | T100 |
| Winding of transformer | 40,3 | 110 |
| Varistor | 34,1 | T85 |
| Electrolytic capacitor | 37,7 | T85 |
| Internal wire | 37,5 | 75 |
| Power supply | 32,5 | 75 |

| | | |
|-------------------------------|------|---------------|
| Swing motor | 40,6 | For reference |
| Display PCB | 38,3 | 145 |
| MI-140Q4/DHN1-D | | |
| Fan motor winding(NIDEC) | 44,5 | 105 |
| Fan motor winding (Welling) | 44,5 | 105 |
| Fan motor winding (Panasonic) | 44,3 | 105 |
| Terminal block I | 32,6 | 85 |
| Terminal block II | 33,4 | 85 |
| Relay (ambient) | 34,8 | T70 |
| X2 capacitor 1 | 35,8 | T100 |
| X2 capacitor 2 | 35,7 | T100 |
| Main PCB | 37,2 | 145 |
| Power PCB | 44,2 | 145 |
| Winding of transformer | 41,2 | 110 |
| Varistor | 43,1 | T85 |
| Internal wire | 32,8 | 75 |
| Power supply | 41,0 | 75 |
| MI-112Q4/DHN1-D | | |
| Fan motor winding(NIDEC) | 40,1 | 105 |
| Fan motor winding (Welling) | 39,9 | 105 |
| Fan motor winding (Panasonic) | 40,0 | 105 |
| Terminal block I | 31,2 | 85 |
| Terminal block II | 32,4 | 85 |
| Relay (ambient) | 32,9 | T70 |
| X2 capacitor 1 | 31,3 | T100 |
| X2 capacitor 2 | 32,0 | T100 |
| Main PCB | 32,0 | 145 |
| Power PCB | 37,8 | 145 |
| Winding of transformer | 37,5 | 110 |
| Varistor | 32,1 | T85 |
| Internal wire | 34,3 | 75 |
| Power supply | 31,5 | 75 |
| MI-80Q4/DHN1-D | | |
| Fan motor winding(NIDEC) | 40,9 | 105 |
| Fan motor winding (Welling) | 40,8 | 105 |
| Fan motor winding (Panasonic) | 40,8 | 105 |
| Terminal block I | 31,5 | 85 |

| | | |
|-------------------------------|------|------|
| Terminal block II | 32,3 | 85 |
| Relay (ambient) | 31,6 | T70 |
| X2 capacitor 1 | 31,3 | T100 |
| X2 capacitor 2 | 32,0 | T100 |
| Main PCB | 31,8 | 145 |
| Power PCB | 36,0 | 145 |
| Winding of transformer | 38,9 | 110 |
| Varistor | 42,1 | T85 |
| Internal wire | 33,9 | 75 |
| Power supply | 31,9 | 75 |
| MI-36Q4/DHN1-D | | |
| Fan motor winding(NIDEC) | 40,3 | 105 |
| Fan motor winding (Welling) | 40,2 | 105 |
| Fan motor winding (Panasonic) | 44,3 | 105 |
| Terminal block I | 33,6 | 85 |
| Terminal block II | 34,3 | 85 |
| Relay (ambient) | 35,8 | T70 |
| X2 capacitor 1 | 37,4 | 100 |
| X2 capacitor 2 | 36,4 | T100 |
| Main PCB | 30,9 | 145 |
| Power PCB | 45,1 | 145 |
| Winding of transformer | 37,4 | 110 |
| Varistor | 52,0 | T85 |
| Internal wire | 43,2 | 75 |
| Power supply | 33,2 | 75 |
| MI-28Q4/DHN1-A3 | | |
| Fan motor winding(NIDEC) | 33,5 | 105 |
| Fan motor winding (Welling) | 33,5 | 105 |
| Terminal block I | 33,9 | 85 |
| Terminal block II | 33,8 | 85 |
| Main PCB | 32,1 | 145 |
| Relay (ambient) | 33,7 | T70 |
| X2 capacitor 1 | 34,8 | T100 |
| X2 capacitor 2 | 34,6 | T100 |
| Winding of transformer 1 | 34,3 | 110 |
| Winding of transformer 2 | 34,2 | 110 |
| Varistor | 33,6 | T85 |

| | | |
|---|------|---------------|
| Internal wire | 33,4 | 75 |
| Power supply | 33,6 | 75 |
| PCB support | 33,4 | For Clause 30 |
| Pump winding | 32,7 | 105 |
| MI-45Q4/DHN1-A3 | | |
| Fan motor winding(NIDEC) | 32,0 | 105 |
| Fan motor winding (Welling) | 32,3 | 105 |
| Terminal block I | 35,8 | 85 |
| Terminal block II | 35,1 | 85 |
| Relay (ambient) | 35,0 | T70 |
| X2 capacitor 1 | 35,3 | T100 |
| X2 capacitor 2 | 36,7 | T100 |
| Main PCB | 35,8 | 145 |
| Winding of transformer 1 | 36,4 | 110 |
| Winding of transformer 2 | 31,1 | 110 |
| Varistor | 35,2 | T85 |
| Internal wire | 35,0 | 75 |
| Power supply | 35,0 | 75 |
| Appliance enclosure | 32,5 | 85 |
| Air outlet | 45,7 | 90 |
| PCB support | 34,3 | For Clause 30 |
| Pump winding | 46,4 | 105 |
| MDV-D80T2/N1-BA5 (with fan motor YSK74-4E) | | |
| Fan motor enclosure | 50.0 | For reference |
| Terminal block I | 42.0 | 85 |
| Terminal block II | 42.5 | 85 |
| Relay (ambient) | 44.8 | T70 |
| X2 capacitor | 42.3 | T100 |
| Main PCB | 41.4 | 145 |
| Winding of transformer | 47.7 | 110 |
| Varistor | 42.7 | T85 |
| Electrolytic capacitor | 46.2 | T105 |
| Internal wire | 43.4 | 75 |
| Power cord | 41.3 | 75 |
| Appliance enclosure | 37.0 | 85 |
| Fan motor capacitor | 29.6 | T70 |
| MDV-D160T1/N1-B (With main control board MDV-D36Q4.D.1.1.1-2) | | |

| | | |
|--|------|---------------|
| Power terminal on PCB | 32,8 | 85 |
| signal terminal on PCB | 32,7 | 85 |
| Appliance enclosure | 32,8 | 85 |
| Transformer winding | 37,5 | 110 |
| Fan motor enclosure | 61,3 | For reference |
| Relay (ambient) | 42,7 | T70 |
| Varistor | 33,4 | T85 |
| X2 capacitor | 33,8 | T100 |
| Internal wire | 33,3 | 75 |
| Power cord | 33,9 | 75 |
| Electrolytic capacitor | 32,5 | T105 |
| PCB | 34,7 | 145 |
| MDV-D90T1/N1-B (With main control board MDV-D36Q4.D.1.1.1-2) | | |
| Power terminal on PCB | 33,8 | 85 |
| signal terminal on PCB | 31,8 | 85 |
| Appliance enclosure | 33,2 | 85 |
| Transformer winding | 36,1 | 110 |
| Fan motor enclosure | 34,8 | For reference |
| Relay (ambient) | 39,8 | T70 |
| Varistor | 35,8 | T85 |
| X2 capacitor | 38,5 | T100 |
| Internal wire | 34,1 | 75 |
| Power cord | 34,9 | 75 |
| Electrolytic capacitor | 64,1 | T105 |
| PCB | 32,3 | 145 |
| MDV-D90T1/N1-B (With main control board MDV-D36Q4.D.1.1.1-2) | | |
| Power terminal on PCB | 33,3 | 85 |
| signal terminal on PCB | 34,9 | 85 |
| Appliance enclosure | 33,8 | 85 |
| Transformer winding | 39,5 | 110 |
| Fan motor enclosure | 39,9 | For reference |
| Relay (ambient) | 34,9 | T70 |
| Varistor | 35,3 | T85 |
| X2 capacitor | 34,3 | T100 |
| Internal wire | 33,4 | 75 |
| Power cord | 31,2 | 75 |
| Electrolytic capacitor | 32,9 | T105 |

| | | |
|---|------|---------------|
| PCB | 34,4 | 145 |
| MI-36DL/DHN1-C | | |
| Fan motor winding (Panasonic) | 31,5 | 105 |
| Alternative fan motor winding (NIDEC) | 38,0 | 105 |
| Alternative fan motor winding (WELLING) | 32,3 | 105 |
| Terminal 1 | 33,3 | 85 |
| Terminal 2 | 33,3 | 85 |
| Internal wire | 37,8 | 75 |
| Power cord | 33,6 | 75 |
| Louver fan motor enclosure | 41,9 | For reference |
| PCB for main control board | 35,1 | 145 |
| Relay (ambient) for main control board | 35,7 | T70 |
| X2 capacitor for main control board | 39,3 | T100 |
| Varistor for main control board | 38,8 | T85 |
| Inductance for main control board | 38,5 | For reference |
| Electrolytic capacitor for main control board | 36,9 | T105 |
| PCB for power board | 35,5 | 145 |
| Transformer for power board | 44,6 | 110 |
| X2 capacitor for power board | 51,4 | T100 |
| MI-71DL/DHN1-C | | |
| Fan motor winding (Panasonic) | 42,4 | 105 |
| Alternative fan motor winding (NIDEC) | 42,8 | 105 |
| Alternative fan motor winding (WELLING) | 43,0 | 105 |
| Terminal 1 | 33,1 | 85 |
| Terminal 2 | 33,1 | 85 |
| Internal wire | 34,9 | 75 |
| Power cord | 32,9 | 75 |
| Louver fan motor enclosure | 34,9 | For reference |
| PCB for main control board | 34,7 | 145 |
| Relay (ambient) for main control board | 35,1 | T70 |
| X2 capacitor for main control board | 36,5 | T100 |
| Varistor for main control board | 35,1 | T85 |
| Inductance for main control board | 36,3 | For reference |
| Electrolytic capacitor for main control board | 36,3 | T105 |
| PCB for power board | 36,1 | 145 |
| Transformer for power board | 42,8 | 110 |
| X2 capacitor for power board | 40,0 | T100 |

| | | |
|---|------|---------------|
| MI-90DL/DHN1-C | | |
| Fan motor winding (Panasonic) | 47,1 | 105 |
| Alternative fan motor winding (NIDEC) | 46,5 | 105 |
| Alternative fan motor winding (WELLING) | 46,6 | 105 |
| Terminal 1 | 34,5 | 85 |
| Terminal 2 | 34,7 | 85 |
| Internal wire | 44,2 | 75 |
| Power cord | 36,2 | 75 |
| Louver fan motor enclosure | 36,7 | For reference |
| PCB for main control board | 40,1 | 145 |
| Relay (ambient) for main control board | 37,1 | T70 |
| X2 capacitor for main control board | 42,0 | T100 |
| Varistor for main control board | 41,3 | T85 |
| Inductance for main control board | 40,5 | For reference |
| Electrolytic capacitor for main control board | 39,5 | T105 |
| PCB for power board | 37,8 | 145 |
| Transformer winding for power board | 29,2 | 110 |
| MI-140DL/DHN1-C | | |
| Fan motor winding (Panasonic) | 52,8 | 105 |
| Alternative fan motor winding (NIDEC) | 52,5 | 105 |
| Alternative fan motor winding (WELLING) | 52,2 | 105 |
| Terminal 1 | 34,2 | 85 |
| Terminal 2 | 36,0 | 85 |
| Internal wire | 34,3 | 75 |
| Power cord | 34,2 | 75 |
| Louver fan motor enclosure | 43,2 | For reference |
| PCB for main control board | 35,3 | 145 |
| Relay (ambient) for main control board | 40,6 | T70 |
| X2 capacitor for main control board | 39,4 | T100 |
| Varistor for main control board | 41,0 | T85 |
| Inductance for main control board | 36,6 | For reference |
| Electrolytic capacitor for main control board | 37,3 | T105 |
| PCB for power board | 35,4 | 145 |
| Transformer winding for power board | 35,7 | 110 |
| MI-90T2/DHN1-BA5 | | |
| Fan motor winding (Panasonic) | 48,1 | 105 |
| Alternative fan motor winding (NIDEC) | 48,1 | 105 |

| | | |
|---|------|---------------|
| Alternative fan motor winding (WELLING) | 49,0 | 105 |
| Terminal | 32,3 | 85 |
| Internal wire | 31,7 | 75 |
| Power cord | 31,9 | 75 |
| Winding for Pump | 33,1 | 110 |
| PCB | 31,6 | 145 |
| Winding for transformer | 34,7 | 110 |
| Relay | 36,9 | T70 |
| X2 capacitor | 32,2 | T100 |
| Varistor | 31,8 | T85 |
| Reactor | 37,6 | 165 |
| Inductance | 32,4 | For reference |
| Electrolytic capacitor | 32,7 | T105 |
| MI-112T2/DHN1-BA5 | | |
| Fan motor winding (Panasonic) | 75,0 | 105 |
| Alternative fan motor winding (NIDEC) | 71,3 | 105 |
| Alternative fan motor winding (WELLING) | 71,4 | 105 |
| Terminal | 32,6 | 85 |
| Internal wire | 32,3 | 75 |
| Power cord | 32,1 | 75 |
| Winding for Pump | 36,6 | 110 |
| PCB for main control board | 31,9 | 145 |
| Winding for transformer | 34,7 | 110 |
| Relay | 32,5 | T70 |
| X2 capacitor | 32,1 | T100 |
| Varistor | 32,2 | T85 |
| Reactor | 37,9 | 165 |
| Inductance | 35,0 | For reference |
| Electrolytic capacitor | 34,3 | T105 |
| MI-140T2/DHN1-BA5 | | |
| Fan motor winding (Panasonic) | 60,1 | 105 |
| Alternative fan motor winding (NIDEC) | 61,0 | 105 |
| Alternative fan motor winding (WELLING) | 61,4 | 105 |
| Terminal | 33,0 | 85 |
| Internal wire | 33,0 | 75 |
| Power cord | 33,1 | 75 |
| Winding for Pump | 38,1 | 110 |

| | | |
|---|------|---------------|
| PCB for main control board | 34,5 | 145 |
| Winding for transformer | 33,0 | 110 |
| Relay | 33,3 | T70 |
| X2 capacitor | 32,8 | T100 |
| Varistor | 33,1 | T85 |
| Reactor | 39,5 | 165 |
| Inductance | 36,3 | For reference |
| Electrolytic capacitor | 35,7 | T105 |
| MI-56T2/DHN1-DA5 | | |
| Fan motor winding (Panasonic) | 35,4 | 105 |
| Alternative fan motor winding (NIDEC) | 33,4 | 105 |
| Alternative fan motor winding (WELLING) | 33,4 | 105 |
| Terminal | 34,0 | 85 |
| Internal wire | 34,4 | 75 |
| Power cord | 34,2 | 75 |
| Winding for Pump | 37,0 | 110 |
| PCB for main control board | 34,8 | 145 |
| Winding for transformer | 37,2 | 110 |
| Relay | 34,9 | T70 |
| X2 capacitor | 36,0 | T100 |
| Varistor | 34,9 | T85 |
| Inductance | 35,3 | For reference |
| Electrolytic capacitor | 34,0 | T105 |
| MI-71T2/DHN1-DA5 | | |
| Fan motor winding (Panasonic) | 38,3 | 105 |
| Alternative fan motor winding (NIDEC) | 38,0 | 105 |
| Alternative fan motor winding (WELLING) | 36,4 | 105 |
| Terminal | 38,7 | 85 |
| Internal wire | 37,2 | 75 |
| Power cord | 37,7 | 75 |
| Winding for Pump | 38,9 | 110 |
| PCB for main control board | 36,4 | 145 |
| Winding for transformer | 42,6 | 110 |
| Relay | 37,6 | T70 |
| X2 capacitor | 39,2 | T100 |
| Varistor | 39,3 | T85 |
| Inductance | 38,6 | For reference |

| | | |
|---|------|---------------|
| Electrolytic capacitor | 38,6 | T105 |
| MI-45Z/DHN1-F3B | | |
| Fan motor winding (Panasonic) | 33,9 | 105 |
| Alternative fan motor winding (NIDEC) | 32,9 | 105 |
| Alternative fan motor winding (WELLING) | 33,0 | 105 |
| Terminal 1 | 33,5 | 85 |
| Terminal 2 | 33,3 | 85 |
| Internal wire | 34,5 | 75 |
| Power cord | 34,1 | 75 |
| PCB for main control board | 33,3 | 145 |
| Relay for main control board | 64,3 | T70 |
| X2 capacitor for main control board | 34,0 | T100 |
| Varistor for main control board | 61,2 | T85 |
| Inductance for main control board | 34,8 | For reference |
| Electrolytic capacitor for main control board | 36,2 | T105 |
| PCB for power board | 37,2 | 145 |
| Winding for transformer for power board | 50,2 | 110 |
| X2 capacitor for power board | 71,2 | T100 |
| MI-56Z/DHN1-F3B | | |
| Fan motor winding (Panasonic) | 40,5 | 105 |
| Alternative fan motor winding (NIDEC) | 40,5 | 105 |
| Alternative fan motor winding (WELLING) | 40,2 | 105 |
| Terminal 1 | 32,5 | 85 |
| Terminal 2 | 32,8 | 85 |
| Internal wire | 37,4 | 75 |
| Power cord | 34,4 | 75 |
| PCB for main control board | 37,7 | 145 |
| Relay for main control board | 37,6 | T70 |
| X2 capacitor for main control board | 33,4 | T100 |
| Varistor for main control board | 65,8 | T85 |
| Inductance for main control board | 64,5 | For reference |
| Electrolytic capacitor for main control board | 33,9 | T105 |
| PCB for power board | 38,4 | 145 |
| Winding for transformer for power board | 51,2 | 110 |
| X2 capacitor for power board | 64,7 | T100 |
| MI-80Z/DHN1-F3B | | |
| Fan motor winding (Panasonic) | 46,9 | 105 |

| | | |
|---|------|---------------|
| Alternative fan motor winding (NIDEC) | 46,1 | 105 |
| Alternative fan motor winding (WELLING) | 45,9 | 105 |
| Terminal 1 | 33,4 | 85 |
| Terminal 2 | 34,4 | 85 |
| Internal wire | 36,8 | 75 |
| Power cord | 35,5 | 75 |
| PCB for main control board | 36,2 | 145 |
| Relay for main control board | 50,7 | T70 |
| X2 capacitor for main control board | 36,0 | T100 |
| Varistor for main control board | 34,7 | T85 |
| Inductance for main control board | 37,0 | For reference |
| Electrolytic capacitor for main control board | 40,5 | T105 |
| PCB for power board | 41,4 | 145 |
| Winding for transformer for power board | 48,7 | 110 |
| X2 capacitor for power board | 45,4 | T100 |
| MDV-D56Q1/N1-D | | |
| Swing motor enclosure | 33,9 | For reference |
| Fan motor (Welling) enclosure | 49,6 | For reference |
| Alternative Fan motor (Yongan) enclosure | 48,7 | For reference |
| Alternative Fan motor (Tongde) enclosure | 49,2 | For reference |
| Pump winding | 56,8 | 105 |
| Terminal I | 31,9 | 85 |
| Terminal II | 32,1 | 85 |
| Fan motor capacitor | 32,0 | T70 |
| Transformer winding | 37,1 | 110 |
| PCB | 35,8 | 145 |
| Varistor | 33,9 | T85 |
| X2 capacitor | 36,1 | T100 |
| Relay (ambient) | 35,8 | T70 |
| Inductance | 35,7 | For reference |
| Power cord | 32,0 | 75 |
| Internal wire | 34,0 | 75 |
| Test corner | 32,0 | 90 |
| MDV-D71Q1/N1-D | | |
| Swing motor enclosure | 37,3 | For reference |
| Fan motor (Welling) enclosure | 44,0 | For reference |
| Alternative Fan motor (Yongan) enclosure | 43,5 | For reference |

| | | |
|--|------|---------------|
| Alternative Fan motor (Tongde) enclosure | 43,8 | For reference |
| Pump winding | 39,3 | 105 |
| Terminal I | 31,4 | 85 |
| Terminal II | 31,5 | 85 |
| Fan motor capacitor | 31,7 | T70 |
| Transformer winding | 32,9 | 110 |
| PCB | 33,3 | 145 |
| Varistor | 33,8 | T85 |
| X2 capacitor | 34,5 | T100 |
| Relay (ambient) | 37,9 | T70 |
| Inductance | 33,8 | For reference |
| Power cord | 33,5 | 75 |
| Internal wire | 32,4 | 75 |
| Test corner | 31,5 | 90 |
| MI-36G/N1-S | | |
| Fan motor (Welling) enclosure | 61,7 | For reference |
| Alternative Fan motor (Match-Well) enclosure | 61,0 | For reference |
| Alternative Fan motor (Tongde) enclosure | 70,0 | For reference |
| Terminal I | 33,8 | 85 |
| Terminal II | 34,1 | 85 |
| PCB | 37,6 | 145 |
| Relay (ambient) | 38,8 | T85 |
| X2 capacitor | 40,3 | T100 |
| Transformer winding | 44,4 | 110 |
| Varistor | 38,8 | T85 |
| Electrolytic capacitor | 40,6 | T105 |
| Internal wire | 36,4 | 75 |
| Power cord | 34,8 | 75 |
| Fan motor capacitor | 37,2 | T70 |
| Air outlet | 35,5 | 90 |
| Appliance enclosure | 36,7 | 85 |
| Display board | 42,3 | 85 |
| Swing motor enclosure | 35,0 | For reference |
| MI-56G/N1-S | | |
| Fan motor (Welling) enclosure | 74,8 | For reference |
| Alternative Fan motor (Match-Well) enclosure | 69,8 | For reference |
| Alternative Fan motor (Tongde) enclosure | 69,2 | For reference |

| | | |
|--|------|---------------|
| Terminal I | 33,4 | 85 |
| Terminal II | 33,4 | 85 |
| PCB | 39,6 | 145 |
| Relay (ambient) | 39,3 | T85 |
| X2 capacitor | 40,4 | T100 |
| Transformer winding | 44,2 | 110 |
| Varistor | 38,1 | T85 |
| Electrolytic capacitor | 40,8 | T105 |
| Internal wire | 36,0 | 75 |
| Power cord | 36,2 | 75 |
| Fan motor capacitor | 36,8 | T70 |
| Air outlet | 48,6 | 90 |
| Appliance enclosure | 36,3 | 85 |
| Display board enclosure | 35,2 | 85 |
| Swing motor | 48,4 | For reference |
| MI-56Q4/N1-E | | |
| Appliance enclosure | 33,2 | 85 |
| Fan motor capacitor | 32,1 | T70 |
| Internal wire | 34,6 | 75 |
| Power cord | 32,9 | 75 |
| Pump winding | 47,1 | 110 |
| Transformer winding | 40,7 | 110 |
| Fan motor (Welling) enclosure | 46,7 | For reference |
| Alternative Fan motor (Tongde) enclosure | 53,5 | For reference |
| Electrolytic capacitor | 36,0 | T105 |
| PCB | 32,5 | 145 |
| X2 capacitor | 34,6 | T100 |
| Varistor | 33,4 | T85 |
| Terminal | 32,4 | 85 |
| Relay (ambient) | 35,4 | T85 |
| MI-71Q4/N1-E | | |
| Varistor | 35,2 | T85 |
| Relay (ambient) | 38,0 | T85 |
| Terminal | 33,4 | 85 |
| Electrolytic capacitor | 37,6 | T105 |
| X2 capacitor | 36,7 | T100 |
| Appliance enclosure | 33,0 | 85 |

| | | |
|--|------|---------------|
| PCB | 33,3 | 145 |
| Power cord | 33,8 | 75 |
| Fan motor capacitor | 32,6 | T70 |
| Internal wire | 35,1 | 75 |
| Fan motor (Welling) enclosure | 55,5 | For reference |
| Alternative Fan motor (Tongde) enclosure | 62,2 | For reference |
| Transformer winding | 41,7 | 110 |
| Pump winding | 47,0 | 110 |
| MI-80Q4/N1-E | | |
| Power cord | 33,1 | 75 |
| Varistor | 33,9 | T85 |
| X2 capacitor | 36,1 | T100 |
| PCB | 32,4 | 145 |
| Electrolytic capacitor | 36,1 | T105 |
| Relay (ambient) | 36,5 | T85 |
| Internal wire | 34,5 | 75 |
| Transformer winding | 40,9 | 110 |
| Fan motor capacitor | 64,0 | T70 |
| Pump winding | 34,5 | 110 |
| Fan motor (Welling) enclosure | 32,3 | For reference |
| Alternative Fan motor (Tongde) enclosure | 32,5 | For reference |
| Terminal | 32,1 | 85 |
| Appliance enclosure | 32,2 | 85 |
| MI-90Q4/N1-E | | |
| Fan motor capacitor | 32,8 | T70 |
| Pump winding | 46,5 | 110 |
| Fan motor (Welling) enclosure | 33,9 | For reference |
| Alternative Fan motor (Tongde) enclosure | 34,4 | For reference |
| Internal wire | 35,0 | 75 |
| Varistor | 34,7 | T85 |
| PCB | 32,6 | 130 |
| Terminal | 32,4 | 85 |
| Appliance enclosure | 32,5 | 85 |
| Power cord | 33,9 | 75 |
| Transformer winding | 41,8 | 110 |
| Relay (ambient) | 39,8 | T70 |
| Electrolytic capacitor | 36,6 | T105 |

| | | |
|---|------|---------------|
| X2 capacitor | 36,9 | T100 |
| MI-140Q4/N1-E | | |
| Pump winding | 49,9 | 110 |
| Fan motor (Welling) enclosure | 44,4 | For reference |
| Alternative Fan motor (Tongde) enclosure | 63,0 | For reference |
| Transformer winding | 43,5 | 110 |
| Appliance enclosure | 34,2 | 85 |
| Varistor | 34,2 | T85 |
| Power cord | 34,9 | 75 |
| Internal wire | 37,4 | 75 |
| Fan motor capacitor | 35,8 | T70 |
| Electrolytic capacitor | 38,7 | T105 |
| PCB | 36,0 | 145 |
| Terminal | 33,9 | 85 |
| Relay (ambient) | 38,3 | T70 |
| X2 capacitor | 37,0 | T100 |
| MI-36T2/N1-EA5 | | |
| Terminal I | 34,1 | 85 |
| Fan motor (Welling) enclosure | 44,3 | For reference |
| Alternative: Fan motor (Match-Well) enclosure | 39,4 | For reference |
| Alternative: Fan motor (YongAn) enclosure | 42,0 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 45,7 | For reference |
| Terminal II | 33,9 | 85 |
| Transformer winding | 41,2 | 110 |
| X2 capacitor | 37,2 | T100 |
| PCB | 35,8 | 145 |
| Inductance | 38,1 | For reference |
| Varistor | 36,5 | T85 |
| Electrolytic capacitor | 36,6 | T105 |
| Relay I (ambient) | 36,3 | T80 |
| Relay II (ambient) | 36,2 | T80 |
| Internal wire | 35,3 | 75 |
| Pump winding | 48,9 | 105 |
| Power cord | 32,6 | 75 |
| Air outlet | 41,9 | 90 |
| Fan motor capacitor | 33,1 | T70 |
| MI-56T2/N1-EA5 | | |

| | | |
|---|------|---------------|
| Relay I (ambient) | 40,1 | T80 |
| Relay II (ambient) | 37,4 | T80 |
| Fan motor (Welling) enclosure | 47,2 | For reference |
| Alternative: Fan motor (Match-Well) enclosure | 41,2 | For reference |
| Alternative: Fan motor (YongAn) enclosure | 43,9 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 45,7 | For reference |
| Air outlet | 32,7 | 90 |
| Fan motor capacitor | 32,8 | T70 |
| Internal wire | 35,3 | 75 |
| Power cord | 34,2 | 75 |
| Pump winding | 47,0 | 105 |
| Terminal I | 33,6 | 85 |
| Terminal II | 32,8 | 85 |
| PCB | 35,1 | 145 |
| X2 capacitor | 37,3 | T100 |
| Inductance | 37,5 | For reference |
| Varistor | 36,7 | T85 |
| Electrolytic capacitor | 36,3 | T105 |
| Transformer winding | 40,3 | 110 |
| MI-90T2/N1-EA5 | | |
| Transformer winding | 34,2 | 110 |
| Relay I (ambient) | 34,4 | T80 |
| Relay II (ambient) | 34,2 | T80 |
| Pump winding | 43,2 | 105 |
| X2 capacitor | 35,4 | T100 |
| Inductance | 38,6 | For reference |
| Varistor | 35,4 | T85 |
| Electrolytic capacitor | 36,1 | T105 |
| Terminal I | 33,5 | 85 |
| PCB | 36,8 | 145 |
| Fan motor (Welling) enclosure | 44,2 | For reference |
| Alternative: Fan motor (Match-Well) enclosure | 41,1 | For reference |
| Alternative: Fan motor (YongAn) enclosure | 41,1 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 44,4 | For reference |
| Air outlet | 50,8 | 90 |
| Fan motor capacitor | 40,4 | T70 |
| Terminal II | 34,4 | 85 |

| | | |
|---|------|---------------|
| Internal wire | 35,2 | 75 |
| Power cord | 33,7 | 75 |
| MI-112T2/N1-EA5 | | |
| Fan motor (Welling) enclosure | 50,4 | For reference |
| Alternative: Fan motor (Match-Well) enclosure | 47,0 | For reference |
| Alternative: Fan motor (YongAn) enclosure | 50,3 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 55,3 | For reference |
| Terminal II | 33,7 | 85 |
| Relay I (ambient) | 35,0 | T80 |
| Relay II (ambient) | 34,8 | T80 |
| X2 capacitor | 35,8 | T100 |
| PCB | 36,7 | 145 |
| Transformer winding | 41,4 | 110 |
| Inductance | 37,1 | For reference |
| Terminal I | 33,5 | 85 |
| Varistor | 35,9 | T85 |
| Electrolytic capacitor | 35,7 | T105 |
| Internal wire | 34,1 | 75 |
| Power cord | 34,0 | 75 |
| Pump winding | 39,2 | 105 |
| Fan motor capacitor | 34,2 | T70 |
| Air outlet | 52,0 | 90 |
| MI-71T2/N1-EA5 | | |
| Air outlet | 43,7 | 90 |
| Fan motor (Welling) enclosure | 44,4 | For reference |
| Alternative: Fan motor (Match-Well) enclosure | 44,5 | For reference |
| Alternative: Fan motor (YongAn) enclosure | 45,3 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 44,7 | For reference |
| Terminal I | 32,7 | 85 |
| Terminal II | 35,2 | 85 |
| Relay (ambient) | 35,2 | T80 |
| X2 capacitor | 34,2 | T100 |
| PCB | 33,6 | 145 |
| Transformer winding | 38,2 | 110 |
| Inductance | 35,1 | For reference |
| Varistor | 66,8 | T85 |
| Electrolytic capacitor | 34,3 | T105 |

| | | |
|--|------|---------------|
| Internal wire | 33,5 | 75 |
| Power cord | 32,7 | 75 |
| Pump winding | 52,2 | 105 |
| Fan motor capacitor | 33,2 | T70 |
| MI-140T2/N1-EA5 | | |
| Fan motor (Welling) enclosure | 34,4 | For reference |
| Alternative: Fan motor (Match-Well) enclosure | 34,4 | For reference |
| Alternative: Fan motor (YongAn) enclosure | 32,0 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 33,8 | For reference |
| Terminal I | 32,2 | 85 |
| Terminal II | 32,2 | 85 |
| Relay (ambient) | 32,1 | T80 |
| X2 capacitor | 32,2 | T100 |
| PCB | 32,2 | 145 |
| Transformer winding | 36,1 | 110 |
| Inductance | 31,4 | For reference |
| Varistor | 32,3 | T85 |
| Electrolytic capacitor | 32,3 | T105 |
| Internal wire | 32,4 | 75 |
| Power cord | 32,1 | 75 |
| Pump winding | 32,2 | 105 |
| Fan motor capacitor | 47,0 | T70 |
| Air outlet | 52,3 | 90 |
| MI-28Q4/N1-A3 | | |
| Fan motor (Welling) enclosure | 36,0 | For reference |
| Alternative: Fan motor (Broad-Ocean) enclosure | 36,3 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 35,0 | For reference |
| Terminal I | 40,1 | 85 |
| Terminal II | 40,4 | 85 |
| PCB | 37,1 | 145 |
| Relay (ambient) | 37,2 | T80 |
| X2 capacitor | 37,8 | T100 |
| Transformer winding | 43,1 | 110 |
| Varistor | 38,7 | T85 |
| Internal wire | 37,0 | 75 |
| Fan motor capacitor | 34,9 | T70 |
| Electrolytic capacitor | 38,6 | T105 |

| | | |
|--|------|---------------|
| Pump winding | 43,2 | 105 |
| Power cord | 39,5 | 75 |
| Appliance enclosure | 33,5 | 85 |
| MI-45Q4/N1-A3 | | |
| Fan motor (Welling) enclosure | 35,7 | For reference |
| Alternative: Fan motor (Broad-Ocean) enclosure | 36,1 | For reference |
| Alternative: Fan motor (Tongde) enclosure | 35,2 | For reference |
| Terminal I | 35,7 | 85 |
| Terminal II | 36,1 | 85 |
| PCB | 38,2 | 145 |
| Relay I (ambient) | 36,6 | T80 |
| Relay II (ambient) | 37,4 | T80 |
| X2 capacitor | 38,1 | T100 |
| Transformer winding | 44,7 | 110 |
| Varistor | 39,1 | T85 |
| Internal wire | 37,0 | 75 |
| Fan motor capacitor | 35,7 | T70 |
| Electrolytic capacitor | 39,5 | T105 |
| Pump winding | 33,9 | 105 |
| Power cord | 35,0 | 75 |
| Appliance enclosure | 34,2 | 85 |
| MI-80T1/DHN1-B | | |
| Fan motor (NIDEC) winding | 55,9 | 105 |
| Alternative: Fan motor (WEILING) winding | 55,7 | 105 |
| Alternative: Fan motor (Panasonic) winding | 55,5 | 105 |
| Inductance | 39,0 | For reference |
| Relay (ambient) | 45,7 | T70 |
| Electrolytic capacitor | 38,2 | T105 |
| Reactor | 38,8 | 165 |
| Transformer winding | 41,7 | 110 |
| PCB | 32,7 | 145 |
| X2 capacitor | 40,0 | T100 |
| Varistor | 38,4 | T85 |
| Internal wire | 37,3 | 75 |
| Terminal I | 37,6 | 85 |
| Terminal II | 36,3 | 85 |
| Power cord | 38,3 | 75 |

| | | |
|--|------|---------------|
| MI-112T1/DHN1-B | | |
| Fan motor (NIDEC) winding | 54,2 | 105 |
| Alternative: Fan motor (WEILING) winding | 54,6 | 105 |
| Alternative: Fan motor (Panasonic) winding | 50,9 | 105 |
| PCB | 36,7 | 145 |
| X2 capacitor | 36,5 | T100 |
| Varistor | 35,7 | T85 |
| Inductance | 39,9 | For reference |
| Relay (ambient) | 49,8 | T70 |
| Electrolytic capacitor | 41,4 | T105 |
| Transformer winding | 42,3 | 110 |
| PCB | 38,2 | 145 |
| X2 capacitor | 40,2 | T100 |
| Reactor | 41,0 | 165 |
| Internal wire | 38,1 | 75 |
| Terminal I | 33,4 | 85 |
| Terminal II | 31,9 | 85 |
| Power cord | 35,2 | 75 |
| MI-160T1/DHN1-B | | |
| Fan motor (NIDEC) winding | 75,7 | 105 |
| Alternative: Fan motor (WEILING) winding | 77,4 | 105 |
| Alternative: Fan motor (Panasonic) winding | 75,7 | 105 |
| PCB (for main control board I) | 38,1 | 145 |
| X2 capacitor (for main control board I) | 38,4 | T100 |
| Varistor (for main control board I) | 37,4 | T85 |
| Inductance (for main control board I) | 41,7 | For reference |
| Relay (ambient) (for main control board I) | 17,2 | T70 |
| Electrolytic capacitor(for main control board I) | 43,2 | T105 |
| Transformer winding (for main control board I) | 44,4 | 110 |
| PCB (for main control board II) | 48,7 | 145 |
| X2 capacitor (for main control board II) | 45,6 | T100 |
| Reactor | 50,6 | 165 |
| Internal wire | 46,0 | 75 |
| Terminal I | 34,8 | 85 |
| Terminal II | 38,1 | 85 |
| Power cord | 38,4 | 75 |
| MI-280T1/DHN1-B | | |

| | | |
|--|------|---------------|
| Fan motor (NIDEC) winding | 51,2 | 105 |
| Alternative: Fan motor (WEILING) winding | 51,7 | 105 |
| Alternative: Fan motor (Panasonic) winding | 51,8 | 105 |
| PCB (for main control board I) | 41,6 | 145 |
| X2 capacitor (for main control board I) | 40,2 | T100 |
| Varistor (for main control board I) | 40,9 | T85 |
| Inductance (for main control board I) | 55,5 | For reference |
| Relay (ambient) (for main control board I) | 42,7 | T70 |
| Electrolytic capacitor(for main control board I) | 50,1 | T105 |
| Transformer winding (for main control board I) | 44,7 | 110 |
| PCB (for main control board II) | 38,5 | 130 |
| X2 capacitor (for main control board II) | 44,5 | T100 |
| Varistor (for main control board II) | 43,3 | T85 |
| Relay (ambient) (for main control board II) | 42,3 | T70 |
| PCB (for IPM board) | 48,8 | 145 |
| X2 capacitor (for IPM board) | 53,7 | T100 |
| Reactor | 45,6 | 165 |
| Transformer winding | 69,0 | 110 |
| Terminal I | 37,3 | 85 |
| Terminal II | 38,8 | 85 |
| Internal wire | 50,3 | 75 |
| Power cord | 38,3 | 75 |
| MI-140T1/DHN1-FA | | |
| Fan motor (NIDEC) winding | 40,9 | 105 |
| Alternative: Fan motor (WEILING) winding | 41,1 | 105 |
| Alternative: Fan motor (Panasonic) winding | 38,7 | 105 |
| PCB (for main control board I) | 34,2 | 145 |
| Varistor (for main control board I) | 34,2 | T85 |
| Inductance (for main control board I) | 36,9 | For reference |
| Relay (ambient) (for main control board I) | 38,6 | T70 |
| X2 capacitor (for main control board I) | 35,2 | T100 |
| Electrolytic capacitor(for main control board I) | 35,9 | T105 |
| Transformer winding (for main control board I) | 38,5 | 110 |
| PCB (for IPM board) | 39,9 | 145 |
| X2 capacitor (for IPM board) | 35,8 | T100 |
| Reactor | 40,3 | 165 |
| Internal wire | 34,2 | 75 |

| | | |
|--|------|---------------|
| Terminal I | 33,1 | 85 |
| Terminal II | 38,0 | 85 |
| Power cord | 35,2 | 75 |
| MI-280T1/DHN1-FA | | |
| Fan motor (NIDEC) winding | 45,3 | 105 |
| Alternative: Fan motor (WEILING) winding | 61,2 | 105 |
| Alternative: Fan motor (Panasonic) winding | 38,7 | 105 |
| PCB(for main control board I) | 38,4 | 145 |
| X2 capacitor (for main control board I) | 38,2 | T100 |
| Varistor (for main control board I) | 39,0 | T85 |
| Inductance (for main control board I) | 48,5 | For reference |
| Relay (ambient) (for main control board I) | 47,3 | T70 |
| Electrolytic capacitor (for main control board I) | 42,3 | T105 |
| Transformer winding (for main control board I) | 44,3 | 110 |
| PCB (for main control board II) | 38,3 | 145 |
| X2 capacitor (for main control board II) | 43,6 | T100 |
| Varistor (for main control board II) | 43,1 | T85 |
| Relay (ambient) (for main control board II) | 51,5 | T70 |
| PCB (for IPM board II) | 49,3 | 145 |
| X2 capacitor (for IPM board II) | 49,3 | T100 |
| Reactor | 51,5 | 165 |
| Internal wire | 40,1 | 75 |
| Transformer winding | 47,9 | 110 |
| Terminal I | 34,7 | 85 |
| Terminal II | 36,1 | 85 |
| Power cord | 61,9 | 75 |
| MI-28G/DHN1-M | | |
| Fan motor WZDK20-38G enclosure (NIDEC) | 40,5 | For reference |
| (Alternative) fan motor WZDK20-38G enclosure (Welling) | 40,5 | For reference |
| Swing motor enclosure | 32,4 | For reference |
| Terminal | 32,7 | 85 |
| PCB (for connect supply cord) | 34,0 | 145 |
| PCB (for display board) | 32,4 | 145 |
| PCB (for main control board) | 34,0 | 145 |
| Transformer winding | 35,4 | 110 |
| Relay (ambient) | 34,4 | T80 |

| | | |
|--|------|---------------|
| X2 capacitor | 36,6 | T100 |
| Varistor | 36,1 | T85 |
| Supply cord | 32,8 | 75 |
| Internal wire | 34,4 | 75 |
| Appliance enclosure | 32,6 | 85 |
| Air outlet | 44,3 | 90 |
| Test corner | 32,2 | 90 |
| MI-56G/DHN1-M | | |
| Fan motor WZDK20-38G enclosure (NIDEC) | 34,6 | For reference |
| (Alternative) fan motor WZDK20-38G enclosure (Welling) | 34,7 | For reference |
| Swing motor enclosure | 32,6 | For reference |
| Terminal | 33,1 | 85 |
| PCB (for connect supply cord) | 32,6 | 145 |
| PCB (for display board) | 32,3 | 145 |
| PCB (for main control board) | 33,0 | 145 |
| Transformer winding | 43,0 | 110 |
| Relay (ambient) | 34,3 | T80 |
| X2 capacitor | 39,5 | T100 |
| Varistor | 38,6 | T85 |
| Supply cord | 33,0 | 75 |
| Internal wire | 34,0 | 75 |
| Appliance enclosure | 32,6 | 85 |
| Air outlet | 43,1 | 90 |
| Test corner | 32,5 | 90 |
| MI-90G/DHN1-M | | |
| Fan motor WZDK20-38G enclosure (NIDEC) | 50,0 | For reference |
| (Alternative) fan motor WZDK20-38G enclosure (Welling) | 50,0 | For reference |
| Swing motor enclosure | 35,0 | For reference |
| Terminal | 33,1 | 85 |
| PCB (for connect supply cord) | 32,8 | 145 |
| PCB (for display board) | 32,6 | 145 |
| PCB (for main control board) | 32,9 | 145 |
| Transformer winding | 38,1 | 110 |
| Relay | 36,0 | T80 |
| X2 capacitor | 37,4 | T100 |
| Varistor | 36,0 | T85 |

| | | |
|--|------|---------------|
| Supply cord | 33,0 | 75 |
| Internal wire | 34,8 | 75 |
| Appliance enclosure | 32,5 | 85 |
| Air outlet | 38,8 | 90 |
| Test corner | 32,6 | 90 |
| MI-28T2/DHN1-EA5 | | |
| Fan motor WZDK100-38GS-2 enclosure(Panasonic) | 59,2 | For reference |
| (Alternative) fan motor WZDK100-38GS-2 enclosure (Welling) | 51,8 | For reference |
| Water pump motor enclosure | 34,9 | For reference |
| Terminal | 32,7 | 85 |
| PCB (for main control board) | 33,5 | 145 |
| Transformer winding | 38,4 | 110 |
| Relay | 34,1 | T80 |
| X2 capacitor | 34,8 | T100 |
| Varistor | 34,1 | T85 |
| Supply cord | 32,1 | 75 |
| Internal wire | 32,7 | 75 |
| Appliance enclosure | 32,0 | 85 |
| Air outlet | 27,9 | 90 |
| Test corner | 32,6 | 90 |
| MI-90T2/DHN1-EA5 | | |
| Fan motor WZDK150-38GS enclosure(NIDEC) | 45,6 | For reference |
| (Alternative) fan motor WZDK150-38GS enclosure (Welling) | 59,4 | For reference |
| Water pump motor enclosure | 45,8 | For reference |
| Terminal | 32,3 | 85 |
| PCB (for main control board) | 32,9 | 145 |
| Transformer winding | 36,4 | 110 |
| Relay | 35,5 | T80 |
| X2 capacitor | 32,7 | T100 |
| Varistor | 32,8 | T85 |
| Supply cord | 32,2 | 75 |
| Internal wire | 33,8 | 75 |
| Appliance enclosure | 32,5 | 85 |
| Air outlet | 27,4 | 90 |
| Test corner | 33,7 | 90 |

| | | |
|--|------|---------------|
| Reactor | 34,9 | 70 |
| MI-140T2/DHN1-EA5 | | |
| Fan motor WZDK240-38GS enclosure(NIDEC) | 46,6 | For reference |
| (Alternative) fan motor WZDK240-38GS enclosure (Welling) | 52,2 | For reference |
| Water pump motor enclosure | 41,5 | For reference |
| Terminal | 32,8 | 85 |
| PCB (for main control board) | 32,6 | 145 |
| Transformer winding | 37,1 | 110 |
| Relay | 34,9 | T80 |
| X2 capacitor | 32,4 | T100 |
| Varistor | 32,6 | T85 |
| Supply cord | 32,3 | 75 |
| Internal wire | 33,8 | 75 |
| Appliance enclosure | 32,8 | 85 |
| Air outlet | 29,3 | 90 |
| Test corner | 34,7 | 90 |
| Reactor | 37,3 | 70 |
| SMK-D140/MN1: (test conditioner same as clause 10.1) | | |
| X2 capacitor (C1) | 44,9 | T100 |
| Terminal block (for power) | 37,8 | 85 |
| Supply cord | 38,7 | 75 |
| Terminal block (for signal) | 37,4 | 85 |
| AC contactor | 43,4 | 55 |
| Current breaker | 39,4 | 55 |
| X2 capacitor (C2) | 47,2 | T100 |
| Inductance | 48,3 | 90 |
| Varistor | 48,8 | T85 |
| Relay | 43,3 | T85 |
| Transformer winding | 48,9 | Class B: 110 |
| PCB | 45,5 | 145 |
| External enclosure | 34,9 | 85 |
| Test corner | 35,3 | 60 |
| For model MI2-36DLDN1(cooling/50Hz) | | |
| Fan motor WZDK100-38GS-2 enclosure(Panasonic) | 36,5 | For reference |
| PCB (for main control board) | 37,6 | 145 |
| Transformer winding | 39,0 | Class B: 110 |

| | | |
|---|------|---------------|
| Relay | 36,1 | T80 |
| X2 capacitor | 34,7 | T100 |
| Varistor | 34,7 | T85 |
| Supply cord | 34,8 | 75 |
| Internal wire | 34,6 | 75 |
| Appliance enclosure | 33,5 | 85 |
| Air outlet | 31,3 | 90 |
| Test corner | 34,5 | 90 |
| MI2-36DLDN1(Heating/50Hz) | | |
| Fan motor WZDK100-38GS-2 enclosure(Panasonic) | 31,1 | For reference |
| PCB (for main control board) | 30,3 | 145 |
| Transformer winding | 31,7 | Class B: 110 |
| Relay | 29,1 | T80 |
| X2 capacitor | 28,1 | T100 |
| Varistor | 27,9 | T85 |
| Supply cord | 27,8 | 75 |
| Internal wire | 32,2 | 75 |
| Appliance enclosure | 28,3 | 85 |
| Air outlet | 30,2 | 90 |
| Test corner | 30,5 | 90 |
| Reactor | 28,2 | 70 |
| For model MI2-36Q1DN1(cooling 50Hz) | | |
| Fan motor ZKSP-20-8-1 310 enclosure(Panasonic) | 42,0 | For reference |
| (Alternative) fan motor ZKSP-20-8-1 310 enclosure (Welling) | 37,2 | For reference |
| Water pump motor enclosure | 33,7 | For reference |
| PCB (for main control board) | 39,6 | 145 |
| Transformer winding | 37,2 | Class B:110 |
| Relay | 37,0 | T80 |
| X2 capacitor | 33,7 | T100 |
| Varistor | 36,8 | T85 |
| Supply cord | 33,9 | 75 |
| Air outlet | 33,0 | 90 |
| Test corner | 30,7 | 90 |
| Reactor | 34,7 | 70 |
| Terminal block | 34,3 | 90 |
| Electrolytic condenser | 36,3 | 90 |

| | | |
|---|------|---------------|
| For model MI2-36Q1DN1(heating 50Hz) | | |
| Fan motor ZKSP-20-8-1 310 enclosure(Panasonic) | 30,0 | For reference |
| (Alternative) fan motor ZKSP-20-8-1 310 enclosure (Welling) | 33,7 | For reference |
| Water pump motor enclosure | 27,5 | For reference |
| PCB (for main control board) | 34,5 | 145 |
| Transformer winding | 32,8 | Class B: 110 |
| Relay | 30,9 | T80 |
| X2 capacitor | 30,0 | T100 |
| Varistor | 31,3 | T85 |
| Supply cord | 29,4 | 75 |
| Test corner | 31,0 | 90 |
| Reactor | 31,3 | 70 |
| Terminal block | 29,2 | 90 |
| Electrolytic condenser | 31,1 | 90 |
| For model MI2-45Q4CDN1(cooling 50Hz) | | |
| Fan motor WZDK37-38G enclosure(Nidec) | 30,9 | For reference |
| (Alternative) fan motor WZDK37-38G enclosure (Welling) | 30,9 | For reference |
| (Alternative) fan motor WZDK37-38G enclosure (Match-well) | 34,3 | For reference |
| Water pump motor enclosure | 55,3 | For reference |
| PCB (for main control board) | 47,5 | 145 |
| Transformer winding | 43,0 | Class B: 110 |
| Relay | 41,7 | T80 |
| X2 capacitor | 39,0 | T100 |
| Varistor | 36,8 | T85 |
| Supply cord | 31,4 | 75 |
| Test corner | 35,2 | 90 |
| Reactor | 37,8 | 70 |
| Terminal block | 30,7 | 90 |
| Electrolytic condenser | 39,9 | 90 |
| For model MI2-45Q4CDN1(heating 50Hz) | | |
| Fan motor WZDK37-38G enclosure(Nidec) | 40,0 | For reference |
| (Alternative) fan motor WZDK37-38G enclosure (Welling) | 40,0 | For reference |
| (Alternative) fan motor WZDK37-38G enclosure (Match-well) | 40,7 | For reference |
| Water pump motor enclosure | 40,1 | For reference |
| PCB (for main control board) | 47,3 | 145 |

| | | |
|---|------|---------------|
| Transformer winding | 42,8 | Class B: 110 |
| Relay | 37,4 | T80 |
| X2 capacitor | 38,2 | T100 |
| Varistor | 36,5 | T85 |
| Supply cord | 37,7 | 75 |
| Test corner | 31,6 | 90 |
| Reactor | 37,8 | 70 |
| Terminal block | 38,5 | 90 |
| Electrolytic condenser | 39,9 | 90 |
| For model MI2-71Q1DN1(cooling 50Hz) | | |
| Fan motor ZKFP-60-8-1 enclosure(Nidec) | 37,2 | For reference |
| (Alternative) fan motor ZKFP-60-8-1 enclosure (Welling) | 38,1 | For reference |
| PCB (for main control board) | 39,3 | 145 |
| Transformer winding | 37,3 | Class B: 110 |
| Relay | 37,2 | T80 |
| X2 capacitor | 36,6 | T100 |
| Varistor | 39,2 | T85 |
| Supply cord | 35,0 | 75 |
| Test corner | 35,4 | 90 |
| Reactor | 38,3 | 70 |
| Terminal block | 34,8 | 90 |
| Electrolytic condenser | 36,8 | 90 |
| Water pump motor enclosure | 55,8 | For reference |
| For model MI2-71Q1DN1(heating 50Hz) | | |
| Fan motor ZKFP-60-8-1 enclosure(Nidec) | 32,2 | For reference |
| (Alternative) fan motor ZKFP-60-8-1 enclosure (Welling) | 43,2 | For reference |
| PCB (for main control board) | 34,6 | 145 |
| Transformer winding | 33,1 | Class B: 110 |
| Relay | 32,1 | T80 |
| X2 capacitor | 31,0 | T100 |
| Varistor | 32,7 | T85 |
| Supply cord | 28,6 | 75 |
| Test corner | 31,0 | 90 |
| Reactor | 31,9 | 165 |
| Terminal block | 28,2 | 90 |
| Electrolytic condenser | 31,1 | 90 |

| | | |
|---|------|---------------|
| Water pump motor enclosure | 29,4 | For reference |
| For model MI2-71Q2DN1(cooling 50Hz) | | |
| Fan motor WZDK100-38GS-2 enclosure(Panasonic) | 38,7 | For reference |
| (Alternative) fan motor WZDK100-38GS-2 enclosure (Match-well) | 44,4 | For reference |
| PCB (for main control board) | 52,5 | 145 |
| Transformer winding | 39,1 | Class B: 110 |
| Relay | 39,6 | T80 |
| X2 capacitor | 48,7 | T100 |
| Varistor | 38,4 | T85 |
| Supply cord | 34,8 | 75 |
| Test corner | 35,8 | 90 |
| Reactor | 39,3 | 165 |
| Terminal block | 42,1 | 90 |
| Electrolytic condenser | 36,7 | 90 |
| Water pump motor enclosure | 45,7 | For reference |
| For model MI2-71Q2DN1(heating 50Hz) | | |
| Fan motor WZDK100-38GS-2 enclosure(Panasonic) | 36,3 | For reference |
| (Alternative) fan motor WZDK100-38GS-2 enclosure (Match-well) | 41,0 | For reference |
| PCB (for main control board) | 39,0 | 145 |
| Transformer winding | 35,3 | 110 |
| Relay | 32,9 | T80 |
| X2 capacitor | 39,2 | T100 |
| Varistor | 34,3 | T85 |
| Supply cord | 30,0 | 75 |
| Test corner | 30,0 | 90 |
| Reactor | 44,6 | 165 |
| Terminal block | 30,7 | 90 |
| Electrolytic condenser | 35,8 | 90 |
| Water pump motor enclosure | 36,7 | For reference |
| MI2-80F4DN1(cooling 50Hz) | | |
| Fan motor WZDK100-38GS-3 enclosure (Panasonic) | 37,8 | For reference |
| PCB (for main control board) | 38,8 | 145 |
| Transformer winding | 34,8 | Class B: 110 |
| Relay | 36,8 | T80 |
| X2 capacitor | 35,7 | T100 |

| | | |
|---|------|---------------|
| Varistor | 45,0 | T85 |
| Supply cord | 31,2 | 75 |
| Test corner | 33,9 | 90 |
| Reactor | 32,4 | Class H: 165 |
| Terminal block | 31,0 | 90 |
| Electrolytic condenser | 36,5 | 90 |
| For model MI2-80F4DN1(heating 50Hz) | | |
| Fan motor WZDK100-38GS-3 enclosure (Panasonic) | 64,6 | For reference |
| PCB (for main control board) | 46,3 | 145 |
| Transformer winding | 30,0 | Class B: 110 |
| Relay | 41,7 | T80 |
| X2 capacitor | 44,5 | T100 |
| Varistor | 59,3 | T85 |
| Supply cord | 39,9 | 75 |
| Test corner | 30,0 | 90 |
| Reactor | 33,6 | Class H: 165 |
| Terminal block | 39,0 | 90 |
| Electrolytic condenser | 45,3 | 90 |
| For model MI2-80F4DN1(cooling 50Hz) | | |
| Fan motor WZDK100-38GS-3 enclosure(Panasonic) | 28,4 | For reference |
| (Alternative) fan motor WZDK100-38GS-3 enclosure (Match-well) | 45,9 | For reference |
| PCB (for main control board) | 40,1 | 145 |
| Transformer winding | 35,2 | Class B: 110 |
| Relay | 34,1 | T80 |
| X2 capacitor | 33,4 | T100 |
| Varistor | 34,4 | T85 |
| Supply cord | 32,0 | 75 |
| Test corner | 33,9 | 90 |
| Reactor | 33,0 | Class H: 165 |
| Terminal block | 30,6 | 90 |
| Electrolytic condenser | 36,2 | 90 |
| For model MI2-80F4DN1(heating 50Hz) | | |
| Fan motor WZDK100-38GS-3 enclosure(Panasonic) | 44,2 | For reference |
| (Alternative) fan motor WZDK100-38GS-3 enclosure (Match-well) | 44,4 | For reference |

| | | |
|--|------|---------------|
| PCB (for main control board) | 39,0 | 145 |
| Transformer winding | 40,5 | Class B: 110 |
| Relay | 37,1 | T80 |
| X2 capacitor | 44,5 | T100 |
| Varistor | 38,8 | T85 |
| Supply cord | 34,4 | 75 |
| Test corner | 31,3 | 90 |
| Reactor | 36,0 | Class H: 165 |
| Terminal block | 34,5 | 90 |
| Electrolytic condenser | 39,9 | 90 |
| For model MI2-80Q4DN1(cooling 50Hz) | | |
| Fan motor ZKSP-80-8-2 enclosure(Nidec) | 30,7 | For reference |
| (Alternative) fan motor ZKSP-80-8-2enclosure (Welling) | 30,8 | For reference |
| (Alternative) fan motor ZKSP-80-8-2enclosure (Yong an) | 31,0 | For reference |
| PCB (for main control board) | 30,2 | 145 |
| Transformer winding | 37,8 | Class B: 110 |
| Relay | 34,8 | T80 |
| X2 capacitor | 33,0 | T100 |
| Varistor | 31,3 | T85 |
| Supply cord | 30,2 | 75 |
| Test corner | 32,5 | 90 |
| Reactor | 33,4 | Class H: 165 |
| Terminal block | 30,0 | 90 |
| Electrolytic condenser | 34,9 | 90 |
| Water pump motor enclosure | 41,6 | For reference |
| For model MI2-80Q4DN1(heating 50Hz) | | |
| Fan motor ZKSP-80-8-2 enclosure(Nidec) | 30,8 | For reference |
| (Alternative) fan motor ZKSP-80-8-2enclosure (Welling) | 28,8 | For reference |
| (Alternative) fan motor ZKSP-80-8-2enclosure (Yong an) | 37,7 | For reference |
| PCB (for main control board) | 35,5 | 145 |
| Transformer winding | 45,7 | Class B: 110 |
| Relay | 40,7 | T80 |
| X2 capacitor | 38,7 | T100 |
| Varistor | 37,0 | T85 |
| Supply cord | 35,6 | 75 |

| | | |
|---|------|---------------|
| Test corner | 30,8 | 90 |
| Reactor | 39,2 | Class H: 165 |
| Terminal block | 35,7 | 90 |
| Electrolytic condenser | 40,7 | 90 |
| Water pump motor enclosure | 44,9 | For reference |
| For model MI2-90DLDN1(cooling 50Hz) | | |
| Fan motor WZDK100-38GS-1 enclosure(Panasonic) | 41,2 | For reference |
| PCB (for main control board) | 35,8 | 145 |
| Transformer winding | 37,1 | Class B: 110 |
| Relay | 34,9 | T80 |
| X2 capacitor | 34,2 | T100 |
| Varistor | 38,1 | T85 |
| Supply cord | 34,3 | 75 |
| Test corner | 32,7 | 90 |
| Reactor | 35,0 | Class H: 165 |
| Terminal block | 34,0 | 90 |
| Electrolytic condenser | 35,0 | 90 |
| For model MI2-90DLDN1(heating 50Hz) | | |
| Fan motor WZDK100-38GS-1 enclosure(Panasonic) | 34,6 | For reference |
| PCB (for main control board) | 29,8 | 145 |
| Transformer winding | 30,9 | Class B: 110 |
| Relay | 29,1 | T80 |
| X2 capacitor | 33,7 | T100 |
| Varistor | 28,3 | T85 |
| Supply cord | 28,0 | 75 |
| Test corner | 29,5 | 90 |
| Reactor | 28,5 | Class H: 165 |
| Terminal block | 27,9 | 90 |
| Electrolytic condenser | 29,3 | 90 |
| For model MI2-140DLDN1(cooling 50Hz) | | |
| Fan motor WZDK100-38GS-2 enclosure(Panasonic) | 39,7 | For reference |
| (Alternative) fan motor WZDK100-38GS-2 enclosure (Match-well) | 40,7 | For reference |
| PCB (for main control board) | 34,4 | 145 |
| Transformer winding | 34,8 | Class B: 110 |
| Relay | 36,8 | T80 |

| | | |
|---|------|---------------|
| X2 capacitor | 32,5 | T100 |
| Varistor | 32,3 | T85 |
| Supply cord | 32,7 | 75 |
| Test corner | 35,2 | 90 |
| Reactor | 32,9 | Class H: 165 |
| Terminal block | 32,3 | 90 |
| Electrolytic condenser | 34,1 | 90 |
| For model MI2-140DLN1(heating 50Hz) | | |
| Fan motor WZDK100-38GS-2 enclosure(Panasonic) | 36,2 | For reference |
| (Alternative) fan motor WZDK100-38GS-2 enclosure (Match-well) | 38,6 | For reference |
| PCB (for main control board) | 46,7 | 145 |
| Transformer winding | 33,5 | Class B: 110 |
| Relay | 35,4 | T80 |
| X2 capacitor | 30,9 | T100 |
| Varistor | 30,7 | T85 |
| Supply cord | 30,9 | 75 |
| Test corner | 31,0 | 90 |
| Reactor | 31,9 | Class H: 165 |
| Terminal block | 30,9 | 90 |
| Electrolytic condenser | 32,2 | 90 |
| For model MI2-140FADN1(cooling 50Hz) | | |
| Fan motor WZDK750-38GS-W enclosure(Panasonic) | 40,0 | For reference |
| (Alternative) fan motor WZDK750-38GS-W enclosure (Welling) | 45,9 | For reference |
| PCB (for main control board) | 55,1 | 145 |
| Transformer winding | 52,3 | Class B: 110 |
| Relay | 56,2 | T80 |
| X2 capacitor | 45,2 | T100 |
| Varistor | 45,6 | T85 |
| Supply cord | 46,6 | 75 |
| Test corner | 46,1 | 90 |
| Terminal block | 46,1 | 90 |
| Electrolytic condenser | 46,9 | 90 |
| For model MI2-140FADN1(heating 50Hz) | | |
| Fan motor WZDK750-38GS-W enclosure(Panasonic) | 34,0 | For reference |

| | | |
|--|------|---------------|
| (Alternative) fan motor WZDK750-38GS-W enclosure (Welling) | 33,8 | For reference |
| PCB (for main control board) | 32,0 | 145 |
| Transformer winding | 29,5 | Class B: 110 |
| Relay | 32,4 | T80 |
| X2 capacitor | 19,4 | T100 |
| Varistor | 19,5 | T85 |
| Supply cord | 21,3 | 75 |
| Test corner | 16,1 | 90 |
| Terminal block | 20,4 | 90 |
| Electrolytic condenser | 24,8 | 90 |
| For model MI2-140Q4DN1(cooling 50Hz) | | |
| Fan motor ZKSP-170-8-6 enclosure(Nidec) | 31,8 | For reference |
| (Alternative) fan motor ZKSP-170-8-6 enclosure (Welling) | 34,1 | For reference |
| (Alternative) fan motor ZKSP-170-8-6 enclosure (Yong an) | 34,7 | For reference |
| PCB (for main control board) | 31,1 | 145 |
| Transformer winding | 39,1 | Class B: 110 |
| Relay | 33,8 | T80 |
| X2 capacitor | 31,5 | T100 |
| Varistor | 31,3 | T85 |
| Supply cord | 31,1 | 75 |
| Test corner | 32,5 | 90 |
| Reactor | 32,2 | Class H: 165 |
| Terminal block | 31,0 | 90 |
| Electrolytic condenser | 32,7 | 90 |
| Water pump motor enclosure | 39,6 | For reference |
| For model MI2-140Q4DN1(heating 50Hz) | | |
| Fan motor ZKSP-170-8-6 enclosure(Nidec) | 34,0 | For reference |
| (Alternative) fan motor ZKSP-170-8-6 enclosure (Welling) | 36,5 | For reference |
| (Alternative) fan motor ZKSP-170-8-6 enclosure (Yong an) | 36,9 | For reference |
| PCB (for main control board) | 34,3 | 145 |
| Transformer winding | 40,7 | Class B: 110 |
| Relay | 35,8 | T80 |
| X2 capacitor | 34,6 | T100 |
| Varistor | 34,5 | T85 |
| Supply cord | 34,7 | 75 |

| | | |
|--|------|---------------|
| Test corner | 31,0 | 90 |
| Reactor | 35,1 | Class H: 165 |
| Terminal block | 34,4 | 90 |
| Electrolytic condenser | 35,4 | 90 |
| Water pump motor enclosure | 46,2 | For reference |
| For model MI2-160T1DN1(cooling 50Hz) | | |
| Fan motor WZDK750-38GS-W enclosure(Panasonic) | 34,4 | For reference |
| (Alternative) fan motor WZDK750-38GS-W enclosure (Welling) | 58,3 | For reference |
| PCB (for main control board) | 46,4 | 145 |
| Transformer winding | 43,4 | Class B: 110 |
| Relay | 47,9 | T80 |
| X2 capacitor | 36,2 | T100 |
| Varistor | 36,5 | T85 |
| Supply cord | 37,6 | 75 |
| Test corner | 35,4 | 90 |
| Reactor | 44,7 | Class H: 165 |
| Terminal block | 37,0 | 90 |
| Electrolytic condenser | 38,7 | 90 |
| For model MI2-160T1DN1(heating 50Hz) | | |
| Fan motor WZDK750-38GS-W enclosure(Panasonic) | 48,0 | For reference |
| (Alternative) fan motor WZDK750-38GS-W enclosure (Welling) | 76,9 | For reference |
| PCB (for main control board) | 46,7 | 145 |
| Transformer winding | 43,6 | Class B: 110 |
| Relay | 47,0 | T80 |
| X2 capacitor | 34,7 | T100 |
| Varistor | 35,1 | T85 |
| Supply cord | 37,4 | 75 |
| Test corner | 31,0 | 90 |
| Reactor | 47,2 | Class H: 165 |
| Terminal block | 36,6 | 90 |
| Electrolytic condenser | 39,8 | 90 |
| For model MI2-280T1DN1(cooling 50Hz) | | |
| Fan motor ZKSN-920-8-12 enclosure(Nidec) | 32,3 | For reference |
| (Alternative) fan motor ZKSN-920-8-12 enclosure (Yong an) | 30,1 | For reference |
| PCB (for main control board) | 44,4 | 145 |

| | | |
|---|------|---------------|
| Transformer winding | 45,0 | Class B: 110 |
| Relay | 42,4 | T80 |
| X2 capacitor | 39,4 | T100 |
| Varistor | 38,3 | T85 |
| Supply cord | 35,3 | 75 |
| Test corner | 35,2 | 90 |
| Reactor | 50,8 | Class H: 165 |
| Terminal block | 35,8 | 90 |
| Electrolytic condenser | 42,2 | 90 |
| For model MI2-280T1DN1(heating 50Hz) | | |
| Fan motor ZKSN-920-8-12 enclosure(Nidec) | 48,3 | For reference |
| (Alternative) fan motor ZKSN-920-8-12 enclosure (Yong an) | 48,0 | For reference |
| PCB (for main control board) | 37,2 | 145 |
| Transformer winding | 43,7 | Class B: 110 |
| Relay | 37,4 | T80 |
| X2 capacitor | 34,4 | T100 |
| Varistor | 32,5 | T85 |
| Supply cord | 30,7 | 75 |
| Test corner | 30,0 | 90 |
| Reactor | 49,1 | Class H: 165 |
| Terminal block | 31,8 | 90 |
| Electrolytic condenser | 42,5 | 90 |
| For model MI2-80T1DN1(Cooling 50Hz) | | |
| Terminal block | 34,1 | 85 |
| Supply cord | 32,3 | 75 |
| Fan motor ZKSP-240-8-1 enclosure(Nidec) | 62,3 | For reference |
| Surface | 33,2 | 60 |
| Reactor | 45,7 | Class H: 165 |
| Inductance | 40,6 | For reference |
| X2 capacitor | 40,1 | T100 |
| Relay I | 50,3 | T80 |
| Relay II | 39,0 | T80 |
| Electrolytic condenser | 39,4 | 90 |
| Transformer winding | 42,1 | Class B: 110 |
| Varistor | 37,1 | T85 |
| Test corner | 33,0 | 90 |

| | | |
|---|------|---------------|
| For model MI2-80T1DN1(heating 50Hz) | | |
| Terminal block | 35,1 | 85 |
| Supply cord | 32,2 | 75 |
| Fan motor ZKSP-240-8-1 enclosure(Nidec) | 75,1 | For reference |
| Surface | 33,1 | 60 |
| Reactor | 45,3 | Class H: 165 |
| Inductance | 40,6 | For reference |
| X2 capacitor | 40,9 | T100 |
| Relay I | 50,8 | T80 |
| Relay II | 39,3 | T80 |
| Electrolytic condenser | 39,8 | 90 |
| Transformer winding | 42,8 | Class B: 110 |
| Varistor | 37,6 | T85 |
| Test corner | 30,5 | 90 |
| For model MI2-28GDN1(Cooling 50Hz) | | |
| Terminal block | 33,2 | 85 |
| Supply cord | 33,4 | 75 |
| Fan motor WZDK20-38G enclosure(Nidec) | 38,3 | For reference |
| Fan motor WZDK20-38G enclosure(Welling) | 39,9 | For reference |
| Surface | 34,2 | 60 |
| Test corner | 34,9 | 90 |
| PCB | 35,3 | 140 |
| Inductance | 33,8 | For reference |
| X2 capacitor | 39,6 | T100 |
| Relay | 44,3 | T80 |
| Transformer winding | 41,8 | Class B: 110 |
| Varistor | 40,1 | T85 |
| For model MI2-28GDN1(Heating 50Hz) | | |
| Terminal block | 30,1 | 85 |
| Supply cord | 29,5 | 75 |
| Fan motor WZDK20-38G enclosure(Nidec) | 36,1 | For reference |
| Fan motor WZDK20-38G enclosure(Welling) | 38,7 | For reference |
| Surface | 29,0 | 60 |
| Test corner | 28,3 | 90 |
| PCB | 31,3 | 140 |
| Inductance | 29,8 | For reference |
| X2 capacitor | 35,8 | T100 |

| | | |
|--|------|---------------|
| Relay | 38,5 | T80 |
| Transformer winding | 37,6 | Class B: 110 |
| Varistor | 39,6 | T85 |
| For model MI2-56GDN1(Cooling 50Hz) | | |
| Terminal block | 33,0 | 85 |
| Supply cord | 33,4 | 75 |
| Fan motor ZKSP-58-8-1 enclosure(Nidec) | 39,4 | For reference |
| Fan motor ZKSP-58-8-1 enclosure(Welling) | 34,1 | For reference |
| Surface | 34,9 | 60 |
| Test corner | 34,7 | 90 |
| PCB | 42,6 | 140 |
| Inductance | 39,3 | For reference |
| X2 capacitor | 37,2 | T100 |
| Relay | 39,4 | T80 |
| Transformer winding | 44,4 | Class B: 110 |
| Varistor | 36,5 | T85 |
| For model MI2-56GDN1(heating 50Hz) | | |
| Terminal block | 28,8 | 85 |
| Supply cord | 28,6 | 75 |
| Fan motor ZKSP-58-8-1 enclosure(Nidec) | 35,9 | For reference |
| Fan motor ZKSP-58-8-1 enclosure(Welling) | 37,1 | For reference |
| Surface | 28,2 | 60 |
| Test corner | 28,4 | 90 |
| PCB | 37,8 | 140 |
| Inductance | 33,8 | For reference |
| X2 capacitor | 32,2 | T100 |
| Relay | 33,8 | T80 |
| Transformer winding | 38,9 | Class B: 110 |
| Varistor | 31,5 | T85 |
| For model MI2-90GDN1(Cooling 50Hz) | | |
| Terminal block | 32,0 | 90 |
| Supply cord | 32,0 | 75 |
| Fan motor ZKSP-58-8-1 enclosure(Nidec) | 43,4 | For reference |
| Fan motor ZKSP-58-8-1 enclosure(Welling) | 46,3 | For reference |
| Surface | 33,2 | 60 |
| Test corner | 33,9 | 90 |
| PCB | 39,5 | 140 |

| | | |
|--|------|---------------|
| Inductance | 44,5 | For reference |
| X2 capacitor | 41,9 | T100 |
| Relay | 43,4 | T80 |
| Transformer winding | 40,7 | Class B: 110 |
| Varistor | 38,0 | T85 |
| For model MI2-90GDN1(heating 50Hz) | | |
| Terminal block | 28,7 | 85 |
| Supply cord | 31,0 | 75 |
| Fan motor ZKSP-58-8-1 enclosure(Nidec) | 37,3 | For reference |
| Fan motor ZKSP-58-8-1 enclosure(Welling) | 37,8 | For reference |
| Surface | 29,2 | 60 |
| Test corner | 27,7 | 90 |
| PCB | 37,2 | 140 |
| Inductance | 39,8 | For reference |
| X2 capacitor | 38,3 | T100 |
| Relay | 39,4 | T80 |
| Transformer winding | 40,1 | Class B: 110 |
| Varistor | 36,2 | T85 |
| For model MI2-45ZDN1(Cooling 50Hz) | | |
| PCB | 41,7 | 140 |
| X2 capacitor | 36,9 | T100 |
| Relay | 42,2 | T80 |
| Transformer winding | 45,4 | Class B: 110 |
| Terminal block | 33,9 | 85 |
| Surface | 36,7 | 60 |
| Supply cord | 34,9 | 75 |
| Test corner | 33,7 | 90 |
| Varistor | 37,1 | T85 |
| Fan motor RD-280-20-8A enclosure (Panasonic) | 38,9 | For reference |
| Fan motor RD-280-20-8A enclosure (Welling) | 40,1 | For reference |
| For model MI2-45ZDN1(heating 50Hz) | | |
| PCB | 40,4 | 140 |
| X2 capacitor | 36,1 | T100 |
| Relay | 43,4 | T80 |
| Transformer winding | 46,1 | Class B: 110 |
| Terminal block | 38,1 | 90 |
| Surface | 36,8 | 60 |

| | | |
|--|------|---------------|
| Supply cord | 31,3 | 75 |
| Test corner | 31,3 | 90 |
| Varistor | 36,1 | T85 |
| Fan motor RD-280-20-8A enclosure (Panasonic) | 51,4 | For reference |
| Fan motor RD-280-20-8A enclosure (Welling) | 49,7 | For reference |
| Supplementary information: The tests were carried out at both 206,8V and 254,4V, Cooling and Heating mode, The highest temperature result is considered. | | |

| 11.8 | TABLE: Heating test, resistance method (Cooling and Heating mode) | | | | | P |
|-----------------------------|---|--|-----------|-------------|------------------|---|
| | Test voltage (V) | 206,8 and 254,4 V | | | — | |
| | Ambient, t ₁ (°C) | Cooling: 32/- (DB/WB) Heating: 27/- (DB/WB) | | | — | |
| | Ambient, t ₂ (°C) | Cooling: 32/- (DB/WB) Heating: 27/- (DB/WB) | | | — | |
| Temperature of winding | R ₁ (Ω) | R ₂ (Ω) | T (°C) | Max, T (°C) | Insulation class | |
| MDV-D56T3/N1-B | | | | | | |
| Indoor fan motor YDK22-4 | 322,6/270,2 (31,3°C) | 367/302,1 | 67,9/62,7 | 120 | Class B | |
| MDV-D140Q4/N1-D | | | | | | |
| Indoor fan motor YDK60-6F-3 | 228,0/85,4(31,3°C) | 330/98 | 70,1/70,5 | 120 | Class B | |
| MDV-D140Q4/N1-D | | | | | | |
| Indoor fan motor YDK90-6E-1 | 76,6/92,1(31,3°C) | 85,6/103,6 | 62,5/64,5 | 120 | Class B | |
| MDV-D36G/DNYB | | | | | | |
| Indoor fan motor YDK15-6 | 739,0/452(31,3°C) | 870,6/52,4 | 78,6/71,5 | 120 | Class B | |
| MDV-D90DL/N1-C | | | | | | |
| Indoor fan motor YSK59-4D | 92,1/116,3 (31,3°C) | 105,6/132,6 | 70,3/68,6 | 120 | Class B | |
| MDV-36T3/N1-B | | | | | | |
| Indoor fan motor RPS15D | 256,6/264,2 (18,9°C) | 302,1/311,2 | 78,3/77,4 | 115 | Class E | |
| MDV-D80Q4/NA-D | | | | | | |
| Indoor fan motor YDK90-6E-1 | 153,2/131,5 (18,9°C) | 169,6/146,8 | 58,6/61,1 | 120 | Class B | |
| MDV-D112Q4/N1-D | | | | | | |
| Indoor fan motor YSK59-4D | 64/114,2 (18,9°C) | 71,2/126,5 | 60,1/58,8 | 120 | Class B | |
| MDV-D56G/DN1YB | | | | | | |

| | | | | | |
|-----------------------------|-------------------------|-------------|-----------|-----|---------|
| Indoor fan motor YDK18-4 | 90,5/126,7 (18,9°C) | 98,6/138,2 | 69,7/56,4 | 120 | Class B |
| MDV-D36Q1/N1-C | | | | | |
| Indoor fan motor YSK20-4 | 295,6/350,4 (18,9°C) | 313,6/372,5 | 46,4/47,0 | 120 | Class B |
| MDV-D36DL/N1-C | | | | | |
| Indoor fan motor YSK25-6L-1 | 610/343,2 (18,9°C) | 680/378,1 | 60,9/57,4 | 120 | Class B |
| MDV-D71DL/N1-C | | | | | |
| Indoor fan motor YSK55-4L-1 | 92,7/136,8 (18,9°C) | 103,5/152,4 | 61,4/60,7 | 120 | Class B |
| MDV-D140DL/N1-C | | | | | |
| Fan motor YSK59-4D | 90,5/126,7 (18,9°C) | 98,6/138,2 | 54,2/54,6 | 120 | Class B |
| MDV-D36G/N1YB | | | | | |
| Fan motor YDK15-6 | 739,0/450,0 (18,9°C) | 846,0/515,6 | 68,9/69,1 | 120 | Class B |
| MDV-D22Z/N1-F1B | | | | | |
| Indoor fan motor YSK20-4A | 352/411 (22,3°C) | 391/461 | 50,8/53,5 | 120 | Class B |
| MDV-D71Z/N1-F3B | | | | | |
| Indoor fan motor YSK74-4E | 83/124 (22,3°C) | 96/147 | 62,5/69,9 | 120 | Class B |
| MDV-D45Z/N1-F4 | | | | | |
| Indoor fan motor YSK20-6 | 500/339 (22,3°C) | 564/386 | 55,2/57,9 | 120 | Class B |
| MDV-D45Q4/N1-A3 | | | | | |
| Indoor fan motor YDK15-6P | 442/458 (22,3°C) | 496/513 | 53,7/53,1 | 120 | Class B |
| MDV-D22T2/N1-BA5 | | | | | |
| Indoor fan motor YSK27-4C | 320/326 (22,3°C) | 361/368 | 55,2/55,4 | 120 | Class B |
| MDV-D112T2/N1-BA5 | | | | | |
| Indoor fan motor YSK200-4P | 40/49 (22,3°C) | 46/58 | 60,8/69,5 | 120 | Class B |
| MDV-D22Q2/N1 | | | | | |
| Indoor fan motor YSK31-6-1 | 316/187 (22,3°C) | 362/217 | 59,7/63,5 | 120 | Class B |
| MDV-D56T2/N1-BA5 | | | | | |
| Indoor fan motor YSK68-4P | 331,0/172,8 (21,6°C) | 394,4/210,2 | 70,7/77,2 | 120 | Class B |
| MDV-D80T2/N1-BA5 | | | | | |

| | | | | | |
|------------------------------|-------------------------|-------------|------------|-----|---------|
| Indoor fan motor YSK100-4P | 65,0/32,2 (21,6°C) | 79,6/39,3 | 79,10/77,8 | 120 | Class B |
| MDV-D45Q2/N1 | | | | | |
| Indoor fan motor YSK58-4-1 | 143,1/111,0 (21,6°C) | 164,9/127,4 | 60,6/59,4 | 120 | Class B |
| MDV-D71Q2/N1 | | | | | |
| Indoor fan motor YSK91-4 | 75,0/95,4 (21,6°C) | 89,3/113,4 | 70,6/69,8 | 120 | Class B |
| MDV-200T1/N1-B | | | | | |
| Indoor fan motor YDK550-4X | 12,7/16,3 (21,6°C) | 14,5/18,7 | 57,9/59,3 | 140 | Class F |
| MDV-D140T1/N1-FA | | | | | |
| Indoor fan motor YSK300-4C-1 | 6,8/12,2 (16,3°C) | 8,8/15,4 | 90,1/82,1 | 140 | Class F |
| MDV-D280T1/N1-FA | | | | | |
| Indoor fan motor YDK250-4X | 11,5/14,8 (16,3°C) | 14,1/18,2 | 73/73,9 | 140 | Class F |
| MDV-D80T1/N1-B | | | | | |
| Indoor fan motor YDK100-4X-2 | 32,5/21,9 (19,8°C) | 40,1/26,4 | 78,6/71,8 | 120 | Class B |
| MDV-D90T1/N1-B | | | | | |
| Indoor fan motor YDK160-4C | 25,1/28,7 (19,8°C) | 31,6/35,9 | 85,7/83,6 | 120 | Class B |
| MDV-D112T1/N1-B | | | | | |
| Indoor fan motor YDK200-4F-1 | 23,1/15,9 (19,8°C) | 28,2/19,1 | 76,0/71,0 | 140 | Class F |
| MDV-D160T1/N1-B | | | | | |
| Indoor fan motor YDK400-4C-1 | 8,55/11,09 (19,8°C) | 10,2/13,2 | 68,9/68,2 | 140 | Class F |
| MDV-D36G/DN1YB | | | | | |
| Indoor fan motor YDK15-6 | 594,5/268,7 (27,9°C) | 677,5/304,2 | 64,5/62,5 | 120 | Class B |
| MDV-D56G/DN1YB | | | | | |
| Indoor fan motor YDK18-4 | 354,0/288,3 (27,8°C) | 405,7/330,9 | 66,1/66,6 | 120 | Class B |
| MDV-D56Q4/N1-D | | | | | |
| indoor fan motor YDK60-6F-3 | 414,3/299,7 (27,8°C) | 471,3/341,2 | 63,9/64,2 | 120 | Class B |
| MDV-D80Q4/N1-D | | | | | |
| indoor fan motor YDK80-6E-2 | 220,7/184,9 (27,8°C) | 268,4/220,2 | 84,5/77,9 | 120 | Class B |
| MDV-D280T1/N1-B | | | | | |

| | | | | | |
|--|------------------------|------------|-----------|-----|---------|
| Indoor fan motor YDK550-4X(match-well) | 19,6/4,401 (27,4°C) | 23,3/5,202 | 76,8/75,1 | 120 | Class B |
| MDV-D280T1/N1-FA | | | | | |
| Indoor fan motor YDK250-4X(match-well) | 19,9/24,3 (17,5°C) | 24,8/32,7 | 79,6/77,3 | 120 | Class B |
| MDV-D71T2/N1-CA5 | | | | | |
| Primary winding of indoor fan motor YSK70-4P(Welling) | 120,0(23,7°C) | 136,4 | 59,0 | 120 | Class B |
| Secondary winding of indoor fan motor YSK70-4P(Welling) | 103,7(23,7°C) | 117,5 | 58,1 | 120 | Class B |
| Primary winding of indoor fan motor YSK70-4P(Yongan) | 71,2(23,7°C) | 81,1 | 59,6 | 120 | Class B |
| Secondary winding of indoor fan motor YSK70-4P(Yongan) | 111,4(23,7°C) | 124,1 | 53,1 | 120 | Class B |
| Winding of transformer | 140,4(23,7°C) | 154,1 | 48,8 | 120 | Class B |
| MDV-D80G-R3/N1Y | | | | | |
| Primary winding of indoor fan motor YDK50-4E-1 (Welling) | 207,5(27,2°C) | 245,3 | 75,1 | 120 | Class B |
| Secondary winding of indoor fan motor YDK50-4E-1 (Welling) | 130,2(27,2°C) | 153,1 | 73,4 | 120 | Class B |
| Primary winding of indoor fan motor YDK50-4E-1 (Broad ocean) | 242,0(27,2°C) | 291,4 | 80,6 | 120 | Class B |
| Secondary winding of indoor fan motor YDK50-4E-1 (Broad ocean) | 146,5(27,2°C) | 179,0 | 85,4 | 120 | Class B |
| Winding of transformer | 148,4(27,2°C) | 160,2 | 48,1 | 120 | Class B |
| MDV-D560T1/N1 | | | | | |
| Primary winding of indoor fan motor YDK600-4C (yongan) | 8,561(28,5°C) | 9,992 | 72,5 | 140 | Class F |
| Secondary winding of indoor fan YDK600-4C motor (yongan) | 11,53 (28,5°C) | 13,45 | 72,3 | 140 | Class F |
| Primary winding of indoor fan motor YDK600-4C (Welling) | 6,32 (28,5°C) | 7,55 | 79,7 | 140 | Class F |
| Secondary winding of indoor fan YDK600-4C motor (Welling) | 10,85 (28,5°C) | 12,93 | 78,9 | 140 | Class F |
| Winding of transformer(zhanliang) | 159,6(28,5°C) | 166,0 | 39,1 | 120 | Class B |
| Winding of transformer(wanxin) | 152,2(28,5°C) | 167,6 | 55,1 | 120 | Class B |
| Winding of transformer(yingju) | 148,3(28,5°C) | 159,7 | 48,7 | 120 | Class B |
| Winding of transformer(yinli) | 149,6(28,5°C) | 161,1 | 48,7 | 120 | Class B |
| MDV-D450T1/N1 | | | | | |
| Primary winding of indoor fan motor YDK550-4X (yongan) | 7,90(22,5°C) | 9,51 | 74,9 | 140 | Class F |
| Secondary winding of indoor fan motor YDK550-4X (yongan) | 11,80(22,5°C) | 14,12 | 73,0 | 140 | Class F |
| Primary winding of indoor fan motor YDK550-4X (Match-Well) | 9,91(22,5°C) | 11,88 | 73,6 | 120 | Class B |

| | | | | | |
|---|----------------|--------|------|-----|---------|
| Secondary winding of indoor fan motor YDK550-4X (Match-Well) | 20,71 (22,5°C) | 24,91 | 74,6 | 120 | Class B |
| Winding of transformer(zhanliang) | 150,3(22,5°C) | 161,5 | 41,7 | 120 | Class B |
| Winding of transformer(wanxin) | 143,3(22,5°C) | 159,5 | 51,6 | 120 | Class B |
| Winding of transformer(yingju) | 141,6(22,5°C) | 156,3 | 55,8 | 120 | Class B |
| Winding of transformer(yinli) | 142,5(22,5°C) | 157,2 | 55,7 | 120 | Class B |
| MDV-D36T2/N1-DA5 | | | | | |
| Primary winding of indoor fan motor YSK27-4C(B) (broad-ocean) | 344,0(27,1°C) | 369,9 | 46,8 | 120 | Class B |
| Secondary winding of indoor fan motor YSK27-4C(B) (broad-ocean) | 448,0(27,1°C) | 478,8 | 45,1 | 120 | Class B |
| Primary winding of indoor fan motor YSK27-4C(B) (Welling) | 325,0(23,0°C) | 381,5 | 67,8 | 120 | Class B |
| Secondary winding of indoor fan motor YSK27-4C(B) (Welling) | 422,0(23,0°C) | 495,7 | 68,0 | 120 | Class B |
| Primary winding of indoor fan motor YSK27-4C (Welling) | 212,0(27,0°C) | 260,0 | 56,6 | 120 | Class B |
| Secondary winding of indoor fan motor YSK27-4C (Welling) | 310,0(27,0°C) | 366,0 | 55,5 | 120 | Class B |
| Primary winding of indoor fan motor YSK27-4C (Yong an) | 311,0(27,0°C) | 345,0 | 56,5 | 120 | Class B |
| Secondary winding of indoor fan motor YSK27-4C (Yong an) | 338,0(27,0°C) | 371,0 | 55,5 | 120 | Class B |
| Winding of fan motor (YSK27-4C: welling) | 275,02 (26°C) | 309,4 | 58,6 | 120 | Class B |
| Winding of fan motor (YSK27-4C: TongDe) | 280,23(27°C) | 318,5 | 63,0 | 120 | Class B |
| Winding of fan motor (YSK27-4C: YongAn) | 156,42(27°C) | 178 | 63,1 | 120 | Class B |
| Winding of transformer | 140,4(23,7°C) | 154,1 | 48,8 | 120 | Class B |
| MDV-D17Q4/N1-A3 | | | | | |
| Primary winding of indoor fan motor YDK15-6M (broad-ocean) | 769,0(23,0°C) | 904,6 | 68,4 | 120 | Class B |
| Secondary winding of indoor fan motor YDK15-6M (broad-ocean) | 520,0(23,0°C) | 612,9 | 69,0 | 120 | Class B |
| Primary winding of indoor fan motor YDK15-6M (Welling) | 660,0(23,0°C) | 777,9 | 69,0 | 120 | Class B |
| Secondary winding of indoor fan motor YDK15-6M (Welling) | 358,0(23,0°C) | 420,4 | 67,9 | 120 | Class B |
| Winding of transformer | 140,4(23,0°C) | 156,2 | 52,0 | 120 | Class B |
| MDV-D17G/N1-S | | | | | |
| Primary winding of indoor fan motor YDK9-6A (Welling) | 1139,0(23,0°C) | 1353,5 | 71,5 | 120 | Class B |
| Secondary winding of indoor fan motor YDK9-6A (Welling) | 892,0(23,0°C) | 1064,5 | 72,8 | 120 | Class B |
| Winding of transformer | 140,4(23,0°C) | 158,9 | 56,9 | 120 | Class B |
| MDV-D36Q1/N1-D | | | | | |

| | | | | | |
|--|---------------|-------|------|-----|---------|
| Primary winding of indoor fan motor RPS12N (welling) | 623,(25,6°C) | 735,3 | 72,5 | 115 | Class E |
| Secondary winding of indoor fan motor RPS12N (welling) | 753,0(25,6°C) | 890,5 | 73,1 | 115 | Class E |
| Primary winding of indoor fan motor RPS12N (Broad-ocean) | 315,0(25,6°C) | 372,3 | 72,9 | 115 | Class E |
| Secondary winding of indoor fan motor RPS12N (Broad-ocean) | 522,0(25,6°C) | 599,2 | 64,1 | 115 | Class E |
| Winding of transformer | 150,3(25,6°C) | 159,1 | 40,8 | 120 | Class B |
| MDV-D22G/N1Y-11D5 | | | | | |
| Primary winding of indoor fan motor RPS10H (Broad-ocean) | 746,8(21°C) | 883 | 67,6 | 115 | Class E |
| Secondary winding of indoor fan motor RPS10H (Broad-ocean) | 316,0(21°C) | 374,3 | 68,1 | 115 | Class E |
| Primary winding of indoor fan motor RPS10H (welling) | 730,2(21°C) | 865,3 | 68,3 | 115 | Class E |
| Secondary winding of indoor fan motor RPS10H (welling) | 282,5(21°C) | 334,9 | 68,4 | 115 | Class E |
| Winding of transformer | 156,0(21°C) | 174,9 | 52,0 | 120 | Class B |
| MDV-D36G/N1Y-11D5 | | | | | |
| Primary winding of indoor fan motor RPS14D (Broad-ocean) | 516,3(21°C) | 550,2 | 37,8 | 115 | Class E |
| Secondary winding of indoor fan motor RPS14D (Broad-ocean) | 268,3(21°C) | 285,9 | 37,8 | 115 | Class E |
| Primary winding of indoor fan motor RPS14D (welling) | 637,9(21°C) | 683,3 | 39,2 | 115 | Class E |
| Secondary winding of indoor fan motor RPS14D (welling) | 290,2(21°C) | 310,6 | 39,0 | 115 | Class E |
| Winding of transformer | 156,0(21°C) | 169,6 | 43,3 | 120 | Class B |
| MDV-D45G/N1Y-11D5 | | | | | |
| Primary winding of indoor fan motor RPS14 (Broad-ocean) | 576,3(21°C) | 615,3 | 38,3 | 115 | Class E |
| Secondary winding of indoor fan motor RPS14 (Broad-ocean) | 256,7(21°C) | 273,9 | 38,1 | 115 | Class E |
| Primary winding of indoor fan motor RPS14 (welling) | 493,0(21°C) | 524,4 | 37,3 | 115 | Class E |
| Secondary winding of indoor fan motor RPS14 (welling) | 296,1(21°C) | 319,9 | 41,5 | 115 | Class E |
| Winding of transformer | 156,0(21°C) | 171,6 | 46,6 | 120 | Class B |
| MDV-D71G/N1Y-11D5 | | | | | |
| Primary winding of indoor fan motor WZDK60-38G (Broad-ocean) | 265,0(21°C) | 304,8 | 59,4 | 115 | Class E |
| Secondary winding of indoor fan motor WZDK60-38G (Broad-ocean) | 116,1(21°C) | 124,1 | 38,6 | 115 | Class E |
| Primary winding of indoor fan motor WZDK60-38G (welling) | 186,3(21°C) | 200,0 | 39,8 | 115 | Class E |

| | | | | | |
|--|---------------|-------|------|-----|---------|
| Secondary winding of indoor fan motor WZDK60-38G (welling) | 127,0(21°C) | 136,3 | 39,7 | 115 | Class E |
| Winding of transformer | 156,0(21°C) | 173,2 | 49,2 | 120 | Class B |
| MDV-D140Q4/N1-E | | | | | |
| Primary winding of indoor fan motor YDK65-6S (tongde) | 73,1(19,5°C) | 86,3 | 65,4 | 120 | Class B |
| Secondary winding of indoor fan motor YDK65-6S (tongde) | 103,3(19,5°C) | 120,9 | 62,8 | 120 | Class B |
| Primary winding of indoor fan motor YDK65-6S (welling) | 72,3(20,5°C) | 84,6 | 63,9 | 120 | Class B |
| Secondary winding of indoor fan motor YDK65-6S (welling) | 118,4(20,5°C) | 138,7 | 64,2 | 120 | Class B |
| Primary winding of indoor fan motor YDK65-6S (broad-ocean) | 62,2(20,5°C) | 72,1 | 61,1 | 120 | Class B |
| Secondary winding of indoor fan motor YDK65-6S (broad-ocean) | 106,3(20,5°C) | 123,4 | 61,5 | 120 | Class B |
| Winding of transformer | 104,7(19,5°C) | 122,5 | 62,6 | 120 | Class B |
| MDV-D90Q4/N1-E | | | | | |
| Primary winding of indoor fan motor YDK50-6S (tongde) | 90,5(19,5°C) | 103,2 | 55,1 | 120 | Class B |
| Secondary winding of indoor fan motor YDK50-6S (tongde) | 182,8(19,5°C) | 208,6 | 55,3 | 120 | Class B |
| Primary winding of indoor fan motor YDK50-6S (welling) | 81,2(20,5°C) | 93,3 | 58,5 | 120 | Class B |
| Secondary winding of indoor fan motor YDK50-6S (welling) | 165,3(20,5°C) | 189,6 | 58,0 | 120 | Class B |
| Primary winding of indoor fan motor YDK50-6S (broad-ocean) | 83,3(20,5°C) | 94,7 | 55,4 | 120 | Class B |
| Secondary winding of indoor fan motor YDK50-6S (broad-ocean) | 180,5(20,5°C) | 205,3 | 55,5 | 120 | Class B |
| MDV-D80Q4/N1-E | | | | | |
| Primary winding of indoor fan motor YDK37-6S (tongde) | 197,6(20,8°C) | 219 | 48,4 | 120 | Class B |
| Secondary winding of indoor fan motor YDK37-6S (tongde) | 143,9(20,8°C) | 159,6 | 48,7 | 120 | Class B |
| Primary winding of indoor fan motor YDK37-6S (welling) | 187,3(20,6°C) | 209,1 | 50,3 | 120 | Class B |
| Secondary winding of indoor fan motor YDK37-6S (welling) | 126,3(20,6°C) | 140,9 | 50,1 | 120 | Class B |
| Primary winding of indoor fan motor YDK37-6S (broad-ocean) | 187,9(21,2°C) | 210,3 | 51,7 | 120 | Class B |
| Secondary winding of indoor fan motor YDK37-6S (broad-ocean) | 144,3(21,2°C) | 161,3 | 51,3 | 120 | Class B |
| MDV-D71Q4/N1-E | | | | | |
| Primary winding of indoor fan motor YDK30-6S (tongde) | 211,3(19,5°C) | 252,3 | 68,8 | 120 | Class B |
| Secondary winding of indoor fan | 158,9(19,5°C) | 189,9 | 69,1 | 120 | Class B |

| | | | | | |
|--|----------------|-------|------|-----|---------|
| motor YDK30-6S (tongde) | | | | | |
| Primary winding of indoor fan motor YDK30-6S (welling) | 279,2(19,4°C) | 329,6 | 65,2 | 120 | Class B |
| Secondary winding of indoor fan motor YDK30-6S (welling) | 157,2(19,4°C) | 185,3 | 64,8 | 120 | Class B |
| Primary winding of indoor fan motor YDK30-6S (broad-ocean) | 329,3(20,5°C) | 389,7 | 67,3 | 120 | Class B |
| Secondary winding of indoor fan motor YDK30-6S (broad-ocean) | 200,9(20,5°C) | 238,2 | 67,8 | 120 | Class B |
| MDV-D56Q4/N1-E | | | | | |
| Primary winding of indoor fan motor YDK26-6S (tongde) | 241,2(19,5°C) | 279,0 | 59,3 | 120 | Class B |
| Secondary winding of indoor fan motor YDK26-6S (tongde) | 192,5(19,5°C) | 222,5 | 59,1 | 120 | Class B |
| Primary winding of indoor fan motor YDK26-6S (welling) | 276,6(19,4°C) | 316,9 | 56,4 | 120 | Class B |
| Secondary winding of indoor fan motor YDK26-6S (welling) | 148,9(19,4°C) | 170,9 | 56,9 | 120 | Class B |
| Primary winding of indoor fan motor YDK26-6S (broad-ocean) | 328,3(20,5°C) | 376,8 | 58,2 | 120 | Class B |
| Secondary winding of indoor fan motor YDK26-6S (broad-ocean) | 204,5(20,5°C) | 235,0 | 58,5 | 120 | Class B |
| MDV-D71T2/N1-DA5 | | | | | |
| Primary winding of indoor fan motor YSK61-4P(B) (Welling) | 133,1(18°C) | 156,2 | 61,8 | 120 | Class B |
| Secondary winding of indoor fan motor YSK61-4P(B) (Welling) | 175,8(18°C) | 206,5 | 62,1 | 120 | Class B |
| Primary winding of indoor fan motor YSK61-4P(B) (tongde) | 134,1(20°C) | 156,4 | 62,3 | 120 | Class B |
| Secondary winding of indoor fan motor YSK61-4P(B) (tongde) | 177,2(20°C) | 206,5 | 62,1 | 120 | Class B |
| Primary winding of indoor fan motor YSK61-4P (Welling) | 113,5(18°C) | 131,8 | 62,4 | 120 | Class B |
| Secondary winding of indoor fan motor YSK61-4P (Welling) | 94,8(18°C) | 107,5 | 62,4 | 120 | Class B |
| Primary winding of indoor fan motor YSK61-4P (Match-Well) | 119,1(20°C) | 134,2 | 62,3 | 120 | Class B |
| Secondary winding of indoor fan motor YSK61-4P (Match-Well) | 124,0(20°C) | 140,5 | 62,1 | 120 | Class B |
| Winding of fan motor (YKSS-61-4-63: welling) | 163,8(25,7°C) | 182,3 | 55,1 | 120 | Class B |
| Winding of fan motor (YKSS-61-4-63: TongDe) | 167,8 (27,2°C) | 189 | 60,2 | 120 | Class B |
| Winding of fan motor (YKSS-61-4-63: Match-well) | 184,65 (27°C) | 203 | 53,0 | 120 | Class B |
| MDV-D56T2/N1-DA5 | | | | | |
| Primary winding of indoor fan motor YSK48-4P(B) (Welling) | 219,7(20,6°C) | 251,3 | 57,3 | 120 | Class B |

| | | | | | |
|---|----------------|-------|------|-----|---------|
| Secondary winding of indoor fan motor YSK48-4P(B) (Welling) | 162,3(20,6°C) | 185,7 | 57,4 | 120 | Class B |
| Primary winding of indoor fan motor YSK48-4P(B) (tongde) | 206,3(20,8°C) | 233,6 | 54,6 | 120 | Class B |
| Secondary winding of indoor fan motor YSK48-4P(B) (tongde) | 155,2(20,8°C) | 175,7 | 54,5 | 120 | Class B |
| Primary winding of indoor fan motor YSK48-4P (Welling) | 202,0(20,6°C) | 229,0 | 57,6 | 120 | Class B |
| Secondary winding of indoor fan motor YSK48-4P (Welling) | 133,0(20,6°C) | 150,0 | 57,2 | 120 | Class B |
| Primary winding of indoor fan motor YSK48-4P (Yong an) | 179,0(20,8°C) | 216,0 | 54,8 | 120 | Class B |
| Secondary winding of indoor fan motor YSK48-4P (Yong an) | 104,0(20,8°C) | 125,0 | 54,3 | 120 | Class B |
| Winding of fan motor (YKSS-36-4-65: welling) | 236,3 (25,6°C) | 270,5 | 63,2 | 120 | Class B |
| Winding of fan motor (YKSS-36-4-65: TongDe) | 246,24(28°C) | 293 | 77,8 | 120 | Class B |
| Winding of fan motor (YKSS-36-4-65: YongAn) | 186,13(27°C) | 233 | 92,8 | 120 | Class B |
| MDV-D71T3/N1-C | | | | | |
| Primary winding of indoor fan motor YSK61-4P(B) (Welling) | 129,8(18°C) | 160,0 | 76,7 | 120 | Class B |
| Secondary winding of indoor fan motor YSK61-4P(B) (Welling) | 168,7(18°C) | 207,7 | 76,4 | 120 | Class B |
| Primary winding of indoor fan motor YSK61-4P(B) (tongde) | 133,6(20°C) | 161,5 | 73,1 | 120 | Class B |
| Secondary winding of indoor fan motor YSK61-4P(B) (tongde) | 176,5(20°C) | 213,5 | 73,4 | 120 | Class B |
| MDV-D56T3/N1-C | | | | | |
| Primary winding of indoor fan motor YSK48-4P(B) (Welling) | 219,7(21,2°C) | 250,1 | 56,6 | 120 | Class B |
| Secondary winding of indoor fan motor YSK48-4P(B) (Welling) | 163,2(21,2°C) | 185,8 | 56,6 | 120 | Class B |
| Primary winding of indoor fan motor YSK48-4P(B) (tongde) | 206,3(21°C) | 232,8 | 53,8 | 120 | Class B |
| Secondary winding of indoor fan motor YSK48-4P(B) (tongde) | 154,9(21°C) | 175,0 | 54,2 | 120 | Class B |
| MDV-D36T3/N1-C | | | | | |
| Primary winding of indoor fan motor YSK27-4C(B) (Welling) | 308,1(21,2°C) | 355,3 | 60,4 | 120 | Class B |
| Secondary winding of indoor fan motor YSK27-4C(B) (Welling) | 402,3(21,2°C) | 463,1 | 59,8 | 120 | Class B |
| Primary winding of indoor fan motor YSK27-4C(B) (tongde) | 236,7(21°C) | 269,2 | 56,1 | 120 | Class B |
| Secondary winding of indoor fan motor YSK27-4C(B) (tongde) | 243,6(21°C) | 277,5 | 56,6 | 120 | Class B |
| MDV-D80T2/N1-BA5 (alternative fan motor YSK74-4E) | | | | | |

| | | | | | |
|---|---------------|-------|------|-----|---------|
| Main winding of indoor fan motor | 97,3(24,5°C) | 109,9 | 58,0 | 120 | Class B |
| Aux. winding of indoor fan motor | 128,2(21°C) | 144,9 | 58,2 | 120 | Class B |
| MDV-D56Q1/N1-D | | | | | |
| Main winding of fan motor (Welling: YDK38-4) | 211,3(23°C) | 236,0 | 53,1 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK38-4) | 104,9(23°C) | 117,2 | 53,2 | 120 | Class B |
| Main winding of fan motor (Yongan: YDK38-4) | 221,6(23°C) | 252,3 | 58,7 | 120 | Class B |
| Aux. winding of fan motor (Yongan: YDK38-4) | 115,7(23°C) | 131,6 | 58,4 | 120 | Class B |
| Main winding of fan motor (Tongde: YDK38-4) | 210,0(23°C) | 239,2 | 58,8 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK38-4) | 113,6(23°C) | 129,2 | 58,4 | 120 | Class B |
| MDV-D71Q1/N1-D | | | | | |
| Main winding of fan motor (Welling: YDK43-4) | 208,3(23°C) | 227,6 | 46,9 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK43-4) | 110,6(23°C) | 120,6 | 46,3 | 120 | Class B |
| Main winding of fan motor (Yongan: YDK43-4) | 226,9(23°C) | 245,3 | 43,9 | 120 | Class B |
| Aux. winding of fan motor (Yongan: YDK43-4) | 111,2(23°C) | 120,2 | 43,8 | 120 | Class B |
| Main winding of fan motor (Tongde: YDK43-4) | 197,1(23°C) | 214,1 | 45,2 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK43-4) | 110,9(23°C) | 120,5 | 45,3 | 120 | Class B |
| MDV-D36Q1/N1-D | | | | | |
| Main winding of fan motor (Welling: YDK15-6) | 624,9(21,6°C) | 737,6 | 67,8 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK15-6) | 482,5(21,6°C) | 568,6 | 67,3 | 120 | Class B |
| Main winding of fan motor (Match-Well: YDK15-6) | 616,3(23,5°C) | 342,6 | 68,6 | 120 | Class B |
| Aux. winding of fan motor (Match-Well: YDK15-6) | 475,9(23,5°C) | 409,2 | 68,1 | 120 | Class B |
| Main winding of fan motor (Tongde: YDK15-6) | 627,8(23,5°C) | 724,1 | 76,4 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK15-6) | 483,2(23,5°C) | 558,2 | 76,4 | 120 | Class B |
| MDV-D56Q1/N1-D | | | | | |
| Main winding of fan motor (Welling: YDK18-4) | 278,7(21,6°C) | 342,6 | 80,3 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK18-4) | 332,4(21,6°C) | 409,2 | 80,8 | 120 | Class B |
| Main winding of fan motor (Match- | 253,7(23,5°C) | 305,0 | 75,7 | 120 | Class B |

| | | | | | |
|---|---------------|-------|------|-----|---------|
| Well: YDK18-4) | | | | | |
| Aux. winding of fan motor (Match-Well: YDK18-4) | 284,2(23,5°C) | 341,2 | 75,2 | 120 | Class B |
| Main winding of fan motor (Tongde: YDK18-4) | 278,6(23,5°C) | 337,8 | 78,3 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK18-4) | 334,2(23,5°C) | 405,0 | 78,2 | 120 | Class B |
| MI-56Q4/N1-E | | | | | |
| Main winding of fan motor (Tongde: YDK26-6S) | 243,8(23,2°C) | 282,3 | 63,9 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK26-6S) | 193,4(23,2°C) | 223,6 | 57,6 | 120 | Class B |
| Main winding of fan motor (Welling: YDK26-6S) | 278,6(22,5°C) | 315,2 | 56,5 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK26-6S) | 149,8(22,5°C) | 169,6 | 55,9 | 120 | Class B |
| MI-71Q4/N1-E | | | | | |
| Main winding of fan motor (Tongde: YDK30-6S) | 211,4(23,2°C) | 248,7 | 68,7 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK30-6S) | 158,9(23,2°C) | 186,9 | 66,0 | 120 | Class B |
| Main winding of fan motor (Welling: YDK30-6S) | 283,1(22,5°C) | 327,2 | 62,5 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK30-6S) | 159,2(22,5°C) | 183,8 | 61,9 | 120 | Class B |
| MI-80Q4/N1-E | | | | | |
| Main winding of fan motor (Tongde: YDK37-6S) | 197,9(23,2°C) | 217,9 | 49,4 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK37-6S) | 144,6(23,2°C) | 159,3 | 48,2 | 120 | Class B |
| Main winding of fan motor (Welling: YDK37-6S) | 162,9(22,5°C) | 179,5 | 49,1 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK37-6S) | 135,1(22,5°C) | 149,1 | 48,0 | 120 | Class B |
| MI-90Q4/N1-E | | | | | |
| Main winding of fan motor (Tongde: YDK50-6S) | 88,9(23,2°C) | 98,0 | 49,6 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK50-6S) | 180,6(23,2°C) | 199,0 | 48,7 | 120 | Class B |
| Main winding of fan motor (Welling: YDK50-6S) | 82,5(22,5°C) | 91,4 | 50,2 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK50-6S) | 166,3(22,5°C) | 184,2 | 49,9 | 120 | Class B |
| MI-140Q4/N1-E | | | | | |
| Main winding of fan motor (Tongde: YDK65-6S) | 73,2(23,2°C) | 86,9 | 71,6 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK65-6S) | 103,4(23,2°C) | 122,8 | 60,3 | 120 | Class B |

| | | | | | |
|---|---------------|-------|------|-----|---------|
| Main winding of fan motor (Welling: YDK65-6S) | 73,3(22,5°C) | 81,9 | 51,6 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK65-6S) | 119,6(22,5°C) | 133,6 | 52,7 | 120 | Class B |
| MI-36T2/N1-EA5 | | | | | |
| Main winding of fan motor (Welling: YSK27-4C) | 213,5(23,0°C) | 237,8 | 52,3 | 120 | Class B |
| Aux. winding of fan motor (Welling: YSK27-4C) | 311,6(23,0°C) | 346,5 | 51,8 | 120 | Class B |
| Main winding of fan motor (Match-Well: YSK27-4C) | 288,5(22,0°C) | 313,4 | 44,1 | 120 | Class B |
| Aux. winding of fan motor (Match-Well: YSK27-4C) | 413,4(22,0°C) | 448,3 | 43,7 | 120 | Class B |
| Main winding of fan motor (YONGAN: YSK27-4C) | 290,8(22,3°C) | 321,0 | 49,0 | 120 | Class B |
| Aux. winding of fan motor (YONGAN: YSK27-4C) | 415,6(22,3°C) | 458,6 | 48,9 | 120 | Class B |
| Main winding of fan motor (Tongde: YSK27-4C) | 293,2(22,3°C) | 324,7 | 49,9 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YSK27-4C) | 310,8(22,3°C) | 344,7 | 50,3 | 120 | Class B |
| MI-56T2/N1-EA5 | | | | | |
| Main winding of fan motor (Welling: YSK48-4P) | 204,1(23,0°C) | 228,9 | 54,3 | 120 | Class B |
| Aux. winding of fan motor (Welling: YSK48-4P) | 135,7(23,0°C) | 152,0 | 53,9 | 120 | Class B |
| Main winding of fan motor (Match-Well: YSK48-4P) | 181,7(22,0°C) | 199,6 | 47,3 | 120 | Class B |
| Aux. winding of fan motor (Match-Well: YSK48-4P) | 106,9(22,0°C) | 117,4 | 47,2 | 120 | Class B |
| Main winding of fan motor (YONGAN: YSK48-4P) | 182,6(22,3°C) | 203,0 | 51,0 | 120 | Class B |
| Aux. winding of fan motor (YONGAN: YSK48-4P) | 106,9(22,3°C) | 118,7 | 50,6 | 120 | Class B |
| Main winding of fan motor (Tongde: YSK48-4P) | 204,5(22,3°C) | 228,6 | 52,6 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YSK48-4P) | 126,2(22,3°C) | 141,2 | 52,8 | 120 | Class B |
| MI-90T2/N1-EA5 | | | | | |
| Main winding of fan motor (Welling: YSK100-4P) | 53,1(23,0°C) | 59,2 | 52,6 | 120 | Class B |
| Aux. winding of fan motor (Welling: YSK100-4P) | 24,2(23,0°C) | 27,0 | 52,8 | 120 | Class B |
| Main winding of fan motor (Match-Well: YSK100-4P) | 50,3(22,0°C) | 54,9 | 45,5 | 120 | Class B |
| Aux. winding of fan motor (Match-Well: YSK100-4P) | 22,6(22,0°C) | 24,7 | 45,8 | 120 | Class B |
| Main winding of fan motor | 50,3(22,3°C) | 56,2 | 52,4 | 120 | Class B |

| | | | | | |
|---|---------------|-------|------|-----|---------|
| (YONGAN: YSK100-4P) | | | | | |
| Aux. winding of fan motor (YONGAN: YSK100-4P) | 22,3(22,3°C) | 24,9 | 52,2 | 120 | Class B |
| Main winding of fan motor (Tongde: YSK100-4P) | 42,6(22,3°C) | 47,5 | 51,8 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YSK100-4P) | 21,5(22,3°C) | 24,0 | 52,2 | 120 | Class B |
| MI-112T2/N1-EA5 | | | | | |
| Main winding of fan motor (Welling: YSK200-4P) | 33,5(23,0°C) | 37,9 | 56,8 | 120 | Class B |
| Aux. winding of fan motor (Welling: YSK200-4P) | 43,6(23,0°C) | 49,2 | 56,7 | 120 | Class B |
| Main winding of fan motor (Match-Well: YSK200-4P) | 32,4(22,0°C) | 36,3 | 52,9 | 120 | Class B |
| Aux. winding of fan motor (Match-Well: YSK200-4P) | 40,2(22,0°C) | 45,0 | 53,7 | 120 | Class B |
| Main winding of fan motor (YONGAN: YSK200-4P) | 31,2(22,3°C) | 35,3 | 56,0 | 120 | Class B |
| Aux. winding of fan motor (YONGAN: YSK200-4P) | 41,3(22,3°C) | 46,7 | 55,9 | 120 | Class B |
| Main winding of fan motor (Tongde: YSK200-4P) | 33,5(22,3°C) | 38,4 | 59,9 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YSK200-4P) | 43,4(22,3°C) | 49,8 | 34,6 | 120 | Class B |
| MI-71T2/N1-EA5 | | | | | |
| Main winding of fan motor (Welling: YSK61-4P) | 115,1(21,6°C) | 129,6 | 53,9 | 120 | Class B |
| Aux. winding of fan motor (Welling: YSK61-4P) | 96,7(21,6°C) | 109,0 | 54,2 | 120 | Class B |
| Main winding of fan motor (Match-Well: YSK61-4P) | 118,6(23,5°C) | 132,5 | 53,7 | 120 | Class B |
| Aux. winding of fan motor (Match-Well: YSK61-4P) | 123,2(23,5°C) | 137,5 | 53,4 | 120 | Class B |
| Main winding of fan motor (YONGAN: YSK61-4P) | 122,5(22,5°C) | 137,6 | 54,2 | 120 | Class B |
| Aux. winding of fan motor (YONGAN: YSK61-4P) | 126,1(22,5°C) | 141,7 | 54,3 | 120 | Class B |
| Main winding of fan motor (Tongde: YSK61-4P) | 111,3(23,5°C) | 125,8 | 57,1 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YSK61-4P) | 121,5(23,5°C) | 137,4 | 57,3 | 120 | Class B |
| MI-140T2/N1-EA5 | | | | | |
| Main winding of fan motor (Welling: YSK180-4P) | 34,2(21,6°C) | 37,9 | 49,3 | 120 | Class B |
| Aux. winding of fan motor (Welling: YSK180-4P) | 32,4(21,6°C) | 39,5 | 51,4 | 120 | Class B |
| Main winding of fan motor (Match-Well: YSK180-4P) | 30,3(23,5°C) | 33,7 | 52,5 | 120 | Class B |

| | | | | | |
|---|---------------|-------|------|-----|---------|
| Aux. winding of fan motor (Match-Well: YSK180-4P) | 29,5(23,5°C) | 32,9 | 53,2 | 120 | Class B |
| Main winding of fan motor (YONGAN: YSK180-4P) | 31,6(22,5°C) | 35,1 | 51,0 | 120 | Class B |
| Aux. winding of fan motor (YONGAN: YSK180-4P) | 30,8(22,5°C) | 34,2 | 50,9 | 120 | Class B |
| Main winding of fan motor (Tongde: YSK180-4P) | 29,5(23,5°C) | 32,4 | 48,9 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YSK180-4P) | 28,6(23,5°C) | 31,4 | 48,8 | 120 | Class B |
| MI-28Q4/N1-A3 | | | | | |
| Main winding of fan motor (Welling: YDK15-6M) | 675,6(23,8°C) | 732,9 | 45,7 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK15-6M) | 436,3(23,8°C) | 472,8 | 45,4 | 120 | Class B |
| Main winding of fan motor (Broad-Ocean: YDK15-6M) | 756,3(22,8°C) | 831,6 | 48,4 | 120 | Class B |
| Aux. winding of fan motor (Broad-Ocean: YDK15-6M) | 501,2(22,8°C) | 551,2 | 48,5 | 120 | Class B |
| Main winding of fan motor (Tongde: YDK15-6M) | 674,6(23,0°C) | 735,6 | 46,3 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK15-6M) | 433,9(23,0°C) | 473,2 | 46,3 | 120 | Class B |
| MI-45Q4/N1-A3 | | | | | |
| Main winding of fan motor (Welling: YDK15-6P) | 414,2(23,8°C) | 454,3 | 48,8 | 120 | Class B |
| Aux. winding of fan motor (Welling: YDK15-6P) | 403,9(23,8°C) | 443,3 | 49,0 | 120 | Class B |
| Main winding of fan motor (Broad-Ocean: YDK15-6P) | 378,1(22,8°C) | 415,3 | 48,1 | 120 | Class B |
| Aux. winding of fan motor (Broad-Ocean: YDK15-6P) | 425,2(22,8°C) | 467,2 | 48,2 | 120 | Class B |
| Main winding of fan motor (Tongde: YDK15-6P) | 484,2(23,0°C) | 529,1 | 46,9 | 120 | Class B |
| Aux. winding of fan motor (Tongde: YDK15-6P) | 458,9(23,0°C) | 503,3 | 47,9 | 120 | Class B |
| MI-28T2/DHN1-EA5 | | | | | |
| Winding of water pump(PSB-7: LEPUDA) | 388,3(24,8°C) | 424,3 | 48,8 | 120 | Class B |
| MI-90T2/DHN1-EA5 | | | | | |
| Winding of reactor(R05094A: Welling) | 0,310(24,8°C) | 0,330 | 41,5 | 120 | Class B |
| Winding of water pump(PSB-7: LEPUDA) | 388,3(24,8°C) | 431,2 | 53,5 | 120 | Class B |
| MI-140T2/DHN1-EA5 | | | | | |
| Winding of reactor(R05094A: ZHENGLIANG) | 0,310(24,8°C) | 0,341 | 50,7 | 120 | Class B |

| | | | | | |
|---|---------------|-------|------|-----|---------|
| Winding of water pump(PSB-7: LEPUDA) | 388,3(24,8°C) | 417,4 | 50,9 | 120 | Class B |
| MI-36Q1DN1 | | | | | |
| Winding of water pump (PSB-7: LEPUDA) | 407,0(22,9°C) | 488,8 | 74,7 | 120 | Class B |
| MI2-45Q4CDN1 | | | | | |
| Winding of water pump (PSB-7- L950-VHR) | 385,7(23,2°C) | 463,3 | 75,0 | 120 | Class B |
| MI2-71Q1DN1 | | | | | |
| Winding of water pump (PSB-7: LEPUDA) | 405,4(22,9°C) | 467,2 | 62,2 | 120 | Class B |
| MI2-71Q2DN1 | | | | | |
| Winding of water pump (PSB-7: LEPUDA) | 348,7(25,7°C) | 395,8 | 60,9 | 120 | Class B |
| MI2-80Q4DN1 | | | | | |
| Winding of water pump (PLD-12: LEPUDA) | 311,9(26,0°C) | 339,8 | 49,3 | 120 | Class B |
| MI2140Q4DN1 | | | | | |
| Winding of water pump (PLD-12: LEPUDA) | 391,2(25,6°C) | 424,0 | 47,4 | 120 | Class B |
| MI2-112T2DN1 | | | | | |
| Winding of water pump (PLD-12: LEPUDA) | 406,9(23,6°C) | 445,3 | 47,3 | 120 | Class B |
| MI2-140T2DN1 | | | | | |
| Winding of water pump (PLD-12: LEPUDA) | 406,9(23,6°C) | 447,7 | 49,5 | 120 | Class B |
| MI2-80T1DN1 | | | | | |
| Winding of reactor (R05094A: Deya) | 0,310(24,8°C) | 0,330 | 41,5 | 120 | Class B |
| Supplementary information: The tests were carried out at both of 206,8V and 254,4V, Cooling and Heating mode, The highest temperature result is considered. | | | | | |

| | | | |
|---|--|-------------|---------------------|
| 13.2 | TABLE: Leakage current | | P |
| | Heating appliances: 1.15 x rated input (W).....: | - | — |
| | Motor-operated and combined appliances: 1.06 x rated voltage (V).....: | 254,4V~ | — |
| Leakage current between | | I (mA) | Max. allowed I (mA) |
| For all models | | | |
| L/N – earthing metal enclosure | | 1,550/1,525 | 3,5 |
| L/N – plastic cover | | 0,112/0,122 | 0,35(peak) |
| Supplementary information: the test was performed on all models with all alternative components and the high value is listed. | | | |

| | | | |
|--|---------------------------------|-------------|--------------------|
| 13.3 | TABLE: Electric strength | | P |
| Test voltage applied between: | | Voltage (V) | Breakdown (Yes/No) |
| For all models | | | |
| L/N – earthing metal enclosure | | 1000 | No |
| L/N – plastic cover | | 3000 | No |
| Supplementary information: the test was performed on all models with all alternative components and the severe result is listed. | | | |

| | | | | | |
|--------------------|--------------------------------------|------------------|---------------------------|--------------------------|--------------------|
| 14 | TABLE: Transient overvoltages | | | | N/A |
| Clearance between: | CI (mm) | Required CI (mm) | Rated impulse voltage (V) | Impulse test voltage (V) | Flashover (Yes/No) |
| - | - | - | - | - | - |

| | | | |
|---|---|-------------|---------------------|
| 16.2 | TABLE: Leakage current | | P |
| | Single phase appliances: 1.06 x rated voltage (V) | 254,4V~ | — |
| | Three phase appliances 1.06 x rated voltage divided by $\sqrt{3}$ (V) | -- | — |
| Leakage current between | | I (mA) | Max. allowed I (mA) |
| For all models | | | |
| L/N – accessible metal part | | 1,560/1,566 | 3,5 |
| L/N – plastic enclosure | | 0,089/1,021 | 0,25 |
| Supplementary information: the test was performed on all models with all alternative components and the high value is listed. | | | |

| | | | |
|--|---------------------------------|-------------|--------------------|
| 16.3 | TABLE: Electric strength | | P |
| Test voltage applied between: | | Voltage (V) | Breakdown (Yes/No) |
| For all models | | | |
| L/N – earthing metal enclosure | | 1250 | No |
| L/N – plastic cover | | 3000 | No |
| Supplementary information: the test was performed on all models with all alternative components and the severe result is listed. | | | |

| | | | |
|--|--|--------|-------------|
| 17 | TABLE: Overload protection, thermocouple measurements | | P |
| Temperature rise of part/at: | | T (°C) | Max. T (°C) |
| Winding of transformer (E28106, COIN) | | 115,2 | 225 |
| Winding of transformer (E22102, Jyayang) | | 122,7 | 225 |
| Winding of transformer (E22102, COIN) | | 117,5 | 225 |
| Winding of transformer (E22102, JEWEL) | | 99,2 | 225 |

| | | |
|---|-------|-----|
| Winding of transformer (E22102, DAZHONG) | 107,1 | 225 |
| Winding of transformer (E22102, COINER) | 110,4 | 225 |
| Winding of transformer (TT2-B35+ D90 -1F, Zhanliang) | 158,1 | 225 |
| Winding of transformer (TT2-B35+ D90 -1F, Wanxin) | 131,0 | 225 |
| Winding of transformer (TT2-B35+D90-1F , Yingju) | 139,7 | 225 |
| Winding of transformer (TT2-B35+D90-1F, Yinli) | 141,5 | 225 |
| Winding of transformer (Coiner, E28082) | 135,2 | 225 |
| Winding of transformer (TT2-C30D70-2F, Zhanliang) | 146,3 | 225 |
| Winding of transformer (TT2-C30D70-2F, Wanxin) | 141,5 | 225 |
| Winding of transformer (TT2-C30D70-2F, Yingju) | 137,2 | 225 |
| Winding of transformer (E28108, COINER) | 111,6 | 225 |
| Winding of transformer (E28108, Jiayang) | 115,8 | 225 |
| Winding of transformer (E28108, COIN) | 109,0 | 225 |
| Winding of transformer (ECO25(4+6)3/P4-0.35L1, TDK) | 112,6 | 225 |
| Winding of transformer (E28142, Maanshan Coiner) | 112,5 | 225 |
| Winding of transformer (E28142, HuiZhou Jiayang) | 113,2 | 225 |
| Winding of transformer (ECO25(4+6)3/P4-0.35L1, Maanshan Coiner) | 120,1 | 225 |
| Winding of transformer (ECO25(4+6)3/P4-0.35L1, Jingshi Coiner) | 114,0 | 225 |
| Winding of transformer (ECO25(4+6)3/P4-0.35L1, ZhongShan Coin) | 117,6 | 225 |
| Winding of transformer (ECO25(4+6)3/P4-0.35L1, Hui Zhou Jia yang) | 110,7 | 225 |
| Winding of transformer (YJ-57-0153A2, YINGJU) | 119,7 | 225 |
| Winding of transformer (TY, WANXIN) | 121,3 | 225 |
| Winding of transformer (QW-A01-007, ZHANLIANG) | 115,2 | 225 |
| Winding of transformer (E28131, JIA YANG) | 90,2 | 225 |
| Winding of transformer (E28069, JIA YANG) | 87,4 | 225 |
| Winding of transformer (E28069, Ma'anshan Coin) | 85,9 | 225 |
| Winding of transformer (EE28(4+5)1/P4-0.35L1, Jia yang) | 74,6 | 225 |
| Winding of transformer (EE28(4+5)1/P4-0.35L1, JEWEL) | 79,0 | 225 |
| Winding of transformer (ECO25(5+4)1/P4-0.35L, TDK) | 80,3 | 225 |
| Winding of transformer (TT2-B35+D90-5F Shunde Zhanliang) | 128,5 | 225 |
| Winding of transformer (TT2-B35+D90-5F, Wanxin) | 132,3 | 225 |
| Winding of transformer (TT2-B35+D90-5F, Yingju) | 134,1 | 225 |
| Winding of transformer (TT2-B35+D90-5F, Yinli) | 133,6 | 225 |
| Winding of transformer (EI28(8+8)4/P4-3.93L1) | <150 | 175 |
| Winding of transformer (ECO25(5+8)3/P4-1L, TDX) | 110,2 | 225 |
| Winding of transformer (ECO25(5+8)3/P4-1L, TAMURA) | 102,3 | 225 |
| Winding of transformer (ECO25(5+8)3/P4-1L, JY) | 104,1 | 225 |
| Winding of transformer (ECO25(5+8)3/P4-1L, ZETTLER) | 103,6 | 225 |

| | | | | | | |
|----------------------------|--|--------|--------|---------|--------|-------------|
| 17 | TABLE: Overload protection, resistance method | | | | | N/A |
| | Test voltage (V) | | | | | — |
| | Ambient, t1 (°C)..... | | | | | — |
| | Ambient, t2 (°C)..... | | | | | — |
| | Temperature of winding | R1 (Ω) | R2 (Ω) | Δ T (K) | T (°C) | Max. T (°C) |
| | - | - | - | - | - | - |
| Supplementary information: | | | | | | |

| 19 | Abnormal operation conditions | | | | | | P |
|---|--------------------------------------|--------------------------|------------------------|-------------|------------------------|-------------|--------------|
| Operational characteristics | | YES/NO | Operational conditions | | | | |
| Are there electronic circuits to control the appliance operation? | | Yes | - | | | | |
| Are there “off” or “stand-by” position? | | Yes | - | | | | |
| The unintended operation of the appliance results in dangerous malfunction? | | No | - | | | | |
| Sub-clause | Operating conditions description | Test results description | PEC description | EMP 19.11.4 | Software type required | 19.11.3 PEC | Final result |
| 19.2 | P | P | N.A | N.A | N.A | N.A | P |
| 19.3 | N.A | N.A | N.A | N.A | N.A | N.A | N.A |
| 19.4 | N.A | N.A | N.A | N.A | N.A | N.A | N.A |
| 19.5 | P | P | N.A | N.A | N.A | N.A | P |
| 19.6 | N.A | N.A | N.A | N.A | N.A | N.A | N.A |
| 19.7 | P | P | N.A | N.A | N.A | N.A | P |
| 19.8 | P | P | N.A | N.A | N.A | N.A | P |
| 19.9 | N.A | N.A | N.A | N.A | N.A | N.A | N.A |
| 19.10 | P | P | N.A | N.A | N.A | N.A | P |
| 19.11.2 | P | P | N.A | N.A | N.A | N.A | P |
| 19.11.4.8 | N.A | N.A | N.A | N.A | N.A | N.A | N.A |
| 19.101 | P | P | N.A | N.A | N.A | N.A | P |
| Supplementary information: -- | | | | | | | |

| 19.2 | Abnormal operation conditions – locked rotor test other than motor-compressors | | | | P |
|------------------------------------|--|--------------------|-----------------|--------------|------------------|
| | Ambient, t1 (°C): | 25,0°C | | | — |
| | Ambient, t2 (°C): | 25,0°C | | | — |
| | Test voltage (V) : | 240V | | | — |
| Temperature limit T of winding: | R ₁ (Ω) | R ₂ (Ω) | Measured T (°C) | Limit T (°C) | Insulation class |
| Winding(WZDK100-38GS-2: Panasonic) | - | - | 111,6 | 215 | E |
| Winding(WZDK100-38GS-2: NIDEC) | - | - | 114,6 | 215 | E |
| Winding(WZDK100-38GS-2: WELLING) | - | - | 112,0 | 215 | E |
| Winding(WZDK150-38GS: Panasonic) | - | - | 111,2 | 215 | E |
| Winding(WZDK150-38GS: NIDEC) | - | - | 119,6 | 215 | E |
| Winding(WZDK150-38GS: WELLING) | - | - | 118,0 | 215 | E |
| Winding(WZDK240-38GS: Panasonic) | - | - | 118,5 | 215 | E |
| Winding(WZDK240-38GS: NIDEC) | - | - | 115,4 | 215 | E |
| Winding(WZDK240-38GS: WELLING) | - | - | 122,0 | 215 | E |
| Winding(YSK31-6-1:Welling) | - | - | 112,9 | 225 | B |
| Winding(YSK31-6-1:yong'an) | - | - | 123,4 | 225 | B |
| Winding(YSK58-4-1:Welling) | - | - | 136,1 | 200 | E |
| Winding(YSK58-4-1:yong'an) | - | - | 137,6 | 200 | E |
| Winding(YSK91-4:Welling) | - | - | 153,2 | 225 | B |
| Winding(YSK91-4:yong'an) | - | - | 139,4 | 225 | B |
| Winding(YDK15-6M:Welling) | - | - | 137,5 | 225 | B |
| Winding(YDK15-6M:broad-ocean) | - | - | 132,5 | 225 | B |
| Winding(YDK15-6M:Tongde) | - | - | 148,5 | 225 | B |
| Winding(YDK15-6P:Welling) | - | - | 112,5 | 225 | B |
| Winding(YDK15-6P:broad-ocean) | - | - | 140,8 | 225 | B |
| Winding(YDK15-6P:Tongde) | - | - | 143,5 | 225 | B |
| Winding(YSK300-4C-1:yong'an) | - | - | 150,8 | 240 | F |
| Winding(YDK250-4X:yong'an) | - | - | 148,7 | 240 | F |
| Winding(YSK27-4C:Welling) | - | - | 125,6 | 225 | B |
| Winding(YSK27-4C:yong'an) | - | - | 123,6 | 225 | B |
| Winding (YSK27-4C: welling) | - | - | 123,4 | 175 | B |
| Enclosure (YSK27-4C:welling) | - | - | 120,9 | 150 | -- |
| Winding (YSK27-4C: TongDe) | - | - | 143,5 | 225 | B |
| Enclosure (YSK27-4C: TongDe) | - | - | 127,5 | 150 | -- |

| | | | | | |
|----------------------------------|---|---|-------|-----|----|
| Winding (YSK27-4C: YongAn) | - | - | 136,5 | 215 | B |
| Enclosure (YSK27-4C: YongAn) | - | - | 121,6 | 150 | -- |
| Winding(YSK68-4P:Welling) | - | - | 126,3 | 225 | B |
| Winding(YSK74-4P:Welling) | - | - | 128,7 | 225 | B |
| Winding(YSK100-4P:Welling) | - | - | 116,3 | 225 | B |
| Winding(YSK200-4P:Welling) | - | - | 132,1 | 225 | B |
| Winding(YSK180-4P:Welling) | - | - | 148,2 | 225 | B |
| Winding(RD-280-20-8A:Panasonic) | - | - | 126 | 215 | E |
| Winding(YSK20-6:yong'an) | - | - | 84,9 | 225 | B |
| Winding(YSK28-4E:welling) | - | - | 125,0 | 225 | B |
| Winding(YSK74-4E:yong'an) | - | - | 132,4 | 225 | B |
| Winding(YDK100-4X-2:yong'an) | - | - | 139,4 | 225 | B |
| Winding(YDK160-4C:welling) | - | - | 151,7 | 215 | E |
| Winding(YDK200-4F-1:welling) | - | - | 147,6 | 240 | F |
| Winding(YSK400-4C-1:yong'an) | - | - | 164,7 | 240 | F |
| Winding(YDK550-4X:yong'an) | - | - | 152,7 | 225 | B |
| Winding(YSK59-4A:yong'an) | - | - | 152,4 | 225 | B |
| Winding (Match-well:YDK550-4X) | - | - | 150,6 | 225 | B |
| Winding (Match-well:YDK250-4X) | - | - | 150,3 | 225 | B |
| Winding(YSK70-4P:Welling) | - | - | 135,8 | 225 | B |
| Winding(YSK70-4P:yongan) | - | - | 139,3 | 225 | B |
| Winding(YDK50-4E-1:Welling) | - | - | 139,6 | 225 | B |
| Winding(YDK50-4E-1:BROAD-OCEAN) | - | - | 118,1 | 225 | B |
| Winding(YSK27-4C(B):broad-ocean) | - | - | 118,2 | 225 | B |
| Winding(YSK27-4C(B):Welling) | - | - | 122,6 | 225 | B |
| Winding(YDK9-6A:Welling) | - | - | 120,5 | 225 | B |
| Winding(RPS12N:broad-ocean) | - | - | 138,5 | 225 | B |
| Winding(RPS12N:Welling) | - | - | 137,5 | 225 | B |
| Winding(RPS10H:Broad-ocean) | - | - | 141,5 | 225 | B |
| Winding(RPS14:Broad-ocean) | - | - | 141,7 | 225 | B |
| Winding(RPS14D:Broad-ocean) | - | - | 145,9 | 225 | B |
| Winding(YDK45-4C:Broad-ocean) | - | - | 132,0 | 225 | B |
| Winding(RPS10H:Welling) | - | - | 117,2 | 225 | B |
| Winding(RPS14:Welling) | - | - | 133,0 | 225 | B |
| Winding(RPS14D:Welling) | - | - | 117,6 | 225 | B |
| Winding(YDK45-4C:Welling) | - | - | 130,4 | 225 | B |

| | | | | | |
|-----------------------------------|---|---|-------|-----|----|
| Winding(YDK65-6S:Welling) | - | - | 138,2 | 225 | B |
| Winding(YDK65-6S:Tongde) | - | - | 158,9 | 225 | B |
| Winding(YDK65-6S:Broad-ocean) | - | - | 134,9 | 225 | B |
| Winding(YDK50-6S:Tongde) | - | - | 153,7 | 225 | B |
| Winding(YDK50-6S:Broad-ocean) | - | - | 142,1 | 225 | B |
| Winding(YDK37-6S:Welling) | - | - | 130,8 | 225 | B |
| Winding(YDK37-6S:Tongde) | - | - | 153,7 | 225 | B |
| Winding(YDK37-6S:Broad-ocean) | - | - | 140,5 | 225 | B |
| Winding(YDK30-6S:Welling) | - | - | 143,1 | 225 | B |
| Winding(YDK30-6S:Tongde) | - | - | 155,4 | 225 | B |
| Winding(YDK30-6S:Broad-ocean) | - | - | 145,4 | 225 | B |
| Winding(YDK26-6S:Welling) | - | - | 135,1 | 225 | B |
| Winding(YDK26-6S:Tongde) | - | - | 157,9 | 225 | B |
| Winding(YDK26-6S:Broad-ocean) | - | - | 146,3 | 225 | B |
| Winding(YSK61-4P(B):Welling) | - | - | 158,3 | 225 | B |
| Winding(YSK61-4P(B):Tongde) | - | - | 152,6 | 225 | B |
| Winding(YSK48-4P(B):Welling) | - | - | 131,0 | 225 | B |
| Winding(YSK48-4P(B):Tongde) | - | - | 160,0 | 225 | B |
| Winding (YKSS-36-4-65: Welling) | - | - | 137,3 | 225 | B |
| Enclosure (YKSS-36-4-65: Welling) | - | - | 122,5 | 150 | -- |
| Winding (YKSS-36-4-65: Tongde) | - | - | 123,9 | 225 | B |
| Enclosure (YKSS-36-4-65: Tongde) | - | - | 108,2 | 150 | -- |
| Winding (YKSS-36-4-65: Yongan) | - | - | 132,6 | 225 | B |
| Enclosure (YKSS-36-4-65: Yongan) | - | - | 119,3 | 150 | -- |
| Winding(YSK27-4C (B):Tongde) | - | - | 157,9 | 225 | B |
| Winding(WZDK20-38G:NIDEC) | - | - | 104,6 | 215 | E |
| Winding(WZDK20-38G:Welling) | - | - | 103,0 | 215 | E |
| Winding(WZDK60-38G:NIDEC) | - | - | 104,7 | 215 | E |
| Winding(WZDK60-38G:Welling) | - | - | 114,0 | 215 | E |
| Winding(WZDK37-38G:NIDEC) | - | - | 104,6 | 215 | E |
| Winding(WZDK37-38G:Welling) | - | - | 102,0 | 215 | E |
| Winding(WZDK80-38G:NIDEC) | - | - | 118,6 | 215 | E |
| Winding(WZDK80-38G:Welling) | - | - | 104,0 | 215 | E |
| Winding(WZDK80-38G:Panasonic) | - | - | 111,6 | 215 | E |
| Winding (YSK74-4E:Match-Well) | - | - | 122,6 | 225 | B |
| Winding(YDK38-4:Welling) | - | - | 147,7 | 225 | B |

| | | | | | |
|--------------------------------------|---|---|-------|-----|----|
| Winding(YDK38-4:Tongde) | - | - | 155,0 | 225 | B |
| Winding(YDK38-4:YONGAN) | - | - | 123,6 | 225 | B |
| Winding(YDK43-4:Welling) | - | - | 126,3 | 225 | B |
| Winding(YDK43-4:Tongde) | - | - | 149,0 | 225 | B |
| Winding(YDK43-4:YONGAN) | - | - | 138,4 | 225 | B |
| Winding (YDK15-6:Welling) | - | - | 139,5 | 225 | B |
| Winding (YDK15-6:Match-Well) | - | - | 137,7 | 225 | B |
| Winding (YDK15-6:Tongde) | - | - | 148,5 | 225 | B |
| Winding (Welling: YDK18-4) | - | - | 140,1 | 225 | B |
| Winding (Match-Well: YDK18-4) | - | - | 136,8 | 225 | B |
| Winding (YDK18-4:Tongde) | - | - | 144,5 | 225 | B |
| Winding (YSK48-4P:Welling) | - | - | 127,7 | 225 | B |
| Winding (YSK61-4P:Welling) | - | - | 125,7 | 225 | B |
| Winding (YKSS-61-4-63: Welling) | - | - | 111,2 | 215 | B |
| Enclosure (YKSS-61-4-63: Welling) | - | - | 95,2 | 150 | -- |
| Winding (YKSS-61-4-63: Tongde) | - | - | 113,2 | 215 | B |
| Enclosure (YKSS-61-4-63: Tongde) | - | - | 102,8 | 150 | -- |
| Winding (YKSS-61-4-63: Match-Well) | - | - | 93,8 | 215 | B |
| Enclosure (YKSS-61-4-63: Match-Well) | - | - | 91,4 | 150 | -- |
| Winding (YSK27-4C:Match-Well) | - | - | 137,5 | 225 | B |
| Winding (YSK48-4P:Match-Well) | - | - | 139,8 | 225 | B |
| Winding (YSK61-4P:Match-Well) | - | - | 140,2 | 225 | B |
| Winding (YSK100-4P:Match-Well) | - | - | 141,5 | 225 | B |
| Winding (YSK200-4P:Match-Well) | - | - | 148,2 | 225 | B |
| Winding (YSK180-4P:Match-Well) | - | - | 152,6 | 225 | B |
| Winding (YSK48-4P:YONGAN) | - | - | 138,4 | 225 | B |
| Winding (YSK61-4P:YONGAN) | - | - | 148,8 | 225 | B |
| Winding (YSK100-4P:YONGAN) | - | - | 139,4 | 225 | B |
| Winding (YSK200-4P:YONGAN) | - | - | 149,7 | 225 | B |
| Winding (YSK180-4P:YONGAN) | - | - | 150,7 | 225 | B |
| Winding (YSK27-4C:Tongde) | - | - | 143,5 | 225 | B |
| Winding (YSK48-4P:Tongde) | - | - | 169,0 | 225 | B |
| Winding (YSK61-4P:Tongde) | - | - | 145,5 | 225 | B |
| Winding (YSK100-4P:Tongde) | - | - | 148,0 | 225 | B |
| Winding (YSK200-4P:Tongde) | - | - | 148,0 | 225 | B |
| Winding (YSK180-4P:Tongde) | - | - | 157,0 | 225 | B |

| | | | | | |
|------------------------------------|---|---|-------|-----|----|
| Winding(WZDK750-38GS-W)(NIDEC) | - | - | 126,3 | 215 | E |
| Winding(WZDK750-38GS-W)(Welling) | - | - | 127,2 | 215 | E |
| Winding(WZDK750-38GS-W)(Panasonic) | - | - | 125,8 | 215 | E |
| Winding(ZKSP-58-8-1:NIDEC) | - | - | 104,7 | 215 | E |
| Winding(ZKSP-58-8-1:Welling) | - | - | 113,0 | 215 | E |
| Winding(ZKSP-60-8-3:NIDEC) | - | - | 104,7 | 215 | E |
| Winding(ZKSP-60-8-3:Welling) | - | - | 115,0 | 215 | E |
| Winding (YSK27-4C: Welling) | - | - | 154,1 | 225 | B |
| Winding (YSK27-4C: Yong an) | - | - | 114,5 | 225 | B |
| Winding (YSK48-4P: Welling) | - | - | 127,7 | 225 | B |
| Winding (YSK48-4P: Yong an) | - | - | 138,1 | 225 | B |
| Winding (YSK61-4P: Welling) | - | - | 125,7 | 225 | B |
| Winding (YSK61-4P: Match-Well) | - | - | 137,8 | 225 | B |
| Enclosure (YSK31-6-1:Welling) | - | - | 78,5 | 150 | -- |
| Enclosure (YSK31-6-1:yong'an) | - | - | 119,3 | 150 | -- |
| Enclosure (YSK58-4-1:Welling) | - | - | 111,3 | 150 | -- |
| Enclosure (YSK58-4-1:yong'an) | - | - | 122,2 | 150 | -- |
| Enclosure (YSK91-4:Welling) | - | - | 96,9 | 150 | -- |
| Enclosure (YSK91-4:yong'an) | - | - | 123,4 | 150 | -- |
| Enclosure (YDK15-6M:Welling) | - | - | 122,8 | 150 | -- |
| Enclosure (YDK15-6M:broad-ocean) | - | - | 68,2 | 150 | -- |
| Enclosure (YDK15-6M:Tongde) | - | - | 130,5 | 150 | -- |
| Enclosure (YDK15-6P:Welling) | - | - | 136,7 | 150 | -- |
| Enclosure (YDK15-6P:broad-ocean) | - | - | 140,8 | 150 | -- |
| Enclosure (YDK15-6P:Tongde) | - | - | 127,5 | 150 | -- |
| Enclosure (YSK300-4C-1:yongan) | - | - | 132,8 | 150 | -- |
| Enclosure (YDK250-4X:yong'an) | - | - | 93,2 | 150 | -- |
| Enclosure (YSK27-4C:Welling) | - | - | 121,0 | 150 | -- |
| Enclosure (YSK27-4C:yong'an) | - | - | 107,7 | 150 | -- |
| Enclosure (YSK68-4P:Welling) | - | - | 126,1 | 150 | -- |
| Enclosure (YSK74-4P:Welling) | - | - | 97,4 | 150 | -- |
| Enclosure (YSK100-4P:Welling) | - | - | 116,7 | 150 | -- |
| Enclosure (YSK200-4P:Welling) | - | - | 102,0 | 150 | -- |
| Enclosure (YSK180-4P:Welling) | - | - | 110,0 | 150 | -- |
| Enclosure (RD-280-20-8A:Panasonic) | - | - | 72,6 | 150 | -- |
| Enclosure (YSK20-6:yong'an) | - | - | 121,0 | 150 | -- |

| | | | | | |
|-------------------------------------|---|---|-------|-----|----|
| Enclosure (YSK28-4E:welling) | - | - | 110,7 | 150 | -- |
| Enclosure (YSK74-4E:yong'an) | - | - | 123,1 | 150 | -- |
| Enclosure (YDK100-4X-2:yong'an) | - | - | 136,5 | 150 | -- |
| Enclosure (YDK160-4C:welling) | - | - | 136,6 | 150 | -- |
| Enclosure (YDK200-4F-1:welling) | - | - | 123,7 | 150 | -- |
| Enclosure (YSK400-4C-1:yong'an) | - | - | 139,5 | 150 | -- |
| Enclosure (YDK550-4X: yong'an) | - | - | 139,5 | 150 | -- |
| Enclosure (YSK59-4A: yong'an) | - | - | 139,2 | 150 | -- |
| Enclosure (Match-well: YDK550-4X) | - | - | 93,1 | 150 | -- |
| Enclosure (Match-well: YDK250-4X) | - | - | 103,3 | 150 | -- |
| Enclosure (YSK70-4P:Welling) | - | - | 99,3 | 150 | -- |
| Enclosure (YSK70-4P:yongan) | - | - | 123,5 | 150 | -- |
| Enclosure (YDK50-4E-1:Welling) | - | - | 105,2 | 150 | -- |
| Enclosure (YDK50-4E-1: BROAD-OCEAN) | - | - | 98,3 | 150 | -- |
| Enclosure(YSK27-4C(B): broad-ocean) | - | - | 73,6 | 150 | -- |
| Enclosure(YSK27-4C(B): Welling) | - | - | 76,1 | 150 | -- |
| Enclosure(YDK9-6A:Welling) | - | - | 71,6 | 150 | -- |
| Enclosure (WZDK20-38G:NIDEC) | - | - | 80,8 | 150 | -- |
| Enclosure (WZDK20-38G:Welling) | - | - | 95,0 | 150 | -- |
| Enclosure (WZDK60-38G:NIDEC) | - | - | 81,8 | 150 | -- |
| Enclosure (WZDK60-38G:Welling) | - | - | 109,0 | 150 | -- |
| Enclosure (WZDK37-38G:NIDEC) | - | - | 80,8 | 150 | -- |
| Enclosure (WZDK37-38G:Welling) | - | - | 94,5 | 150 | -- |
| Enclosure (WZDK80-38G:NIDEC) | - | - | 80,8 | 150 | -- |
| Enclosure (WZDK80-38G:Welling) | - | - | 92,0 | 150 | -- |
| Enclosure (WZDK80-38G:Panasonic) | - | - | 97,8 | 150 | -- |
| Enclosure (YSK74-4E: Match-Well) | - | - | 73,6 | 150 | -- |
| Enclosure(RPS12N:broad-ocean) | - | - | 119,7 | 150 | -- |
| Enclosure(RPS12N:Welling) | - | - | 120,4 | 150 | -- |
| Enclosure(RPS10H:Broad-ocean) | - | - | 120,7 | 150 | -- |
| Enclosure (RPS14:Broad-ocean) | - | - | 121,6 | 150 | -- |
| Enclosure (RPS14D:Broad-ocean) | - | - | 120,3 | 150 | -- |
| Enclosure (YDK45-4C: Broad-ocean) | - | - | 116,3 | 150 | -- |
| Enclosure (RPS10H:Welling) | - | - | 102,3 | 150 | -- |
| Enclosure (RPS14:Welling) | - | - | 114,6 | 150 | -- |
| Enclosure (RPS14D:Welling) | - | - | 100,7 | 150 | -- |

| | | | | | |
|--------------------------------------|---|---|-------|-----|----|
| Enclosure (YDK45-4C:Welling) | - | - | 115,6 | 150 | -- |
| Enclosure (YDK65-6S:Welling) | - | - | 109,8 | 150 | -- |
| Enclosure (YDK65-6S:Tongde) | - | - | 135,2 | 150 | -- |
| Enclosure (YDK65-6S: Broad-ocean) | - | - | 124,3 | 150 | -- |
| Enclosure (YDK50-6S:Tongde) | - | - | 130,9 | 150 | -- |
| Enclosure (YDK50-6S:Broad-ocean) | - | - | 129,2 | 150 | -- |
| Enclosure (YDK37-6S:Welling) | - | - | 128,7 | 150 | -- |
| Enclosure (YDK37-6S:Tongde) | - | - | 130,9 | 150 | -- |
| Enclosure (YDK37-6S:Broad-ocean) | - | - | 123,4 | 150 | -- |
| Enclosure (YDK30-6S:Welling) | - | - | 137,4 | 150 | -- |
| Enclosure (YDK30-6S:Tongde) | - | - | 131,0 | 150 | -- |
| Enclosure (YDK30-6S:Broad-ocean) | - | - | 127,6 | 150 | -- |
| Enclosure (YDK26-6S:Welling) | - | - | 126,0 | 150 | -- |
| Enclosure (YDK26-6S:Tongde) | - | - | 130,0 | 150 | -- |
| Enclosure (YDK26-6S:Broad-ocean) | - | - | 115,2 | 150 | -- |
| Enclosure (YSK61-4P(B):Welling) | - | - | 131,8 | 150 | -- |
| Enclosure (YSK61-4P(B):Tongde) | - | - | 130,4 | 150 | -- |
| Enclosure (YSK48-4P(B):Welling) | - | - | 111,6 | 150 | -- |
| Enclosure (YSK48-4P(B):Tongde) | - | - | 134,4 | 150 | -- |
| Enclosure (YSK27-4C(B):Tongde) | - | - | 130,0 | 150 | -- |
| Enclosure (WZDK100-38GS-2:Panasonic) | - | - | 97,8 | 150 | -- |
| Enclosure (WZDK100-38GS-2:NIDEC) | - | - | 80,8 | 150 | -- |
| Enclosure (WZDK100-38GS-2:WELLING) | - | - | 107,5 | 150 | -- |
| Enclosure (WZDK150-38GS:Panasonic) | - | - | 101,0 | 150 | -- |
| Enclosure (WZDK150-38GS:NIDEC) | - | - | 80,8 | 150 | -- |
| Enclosure (WZDK150-38GS:WELLING) | - | - | 109,8 | 150 | -- |
| Enclosure (WZDK240-38GS:Panasonic) | - | - | 106,0 | 150 | -- |
| Enclosure (WZDK240-38GS:NIDEC) | - | - | 90,0 | 150 | -- |
| Enclosure (WZDK240-38GS:WELLING) | - | - | 108,0 | 150 | -- |
| Enclosure (YDK38-4:Welling) | - | - | 91,5 | 150 | -- |
| Enclosure (YDK38-4:Tongde) | - | - | 130,0 | 150 | -- |
| Enclosure (YDK38-4:YONGAN) | - | - | 121,0 | 150 | -- |
| Enclosure (YDK43-4:Welling) | - | - | 107,7 | 150 | -- |
| Enclosure (YDK43-4:Tongde) | - | - | 134,0 | 150 | -- |
| Enclosure (YDK43-4:YONGAN) | - | - | 122,5 | 150 | -- |
| Enclosure (YDK15-6:Welling) | - | - | 97,6 | 150 | -- |

| | | | | | |
|--------------------------------------|---|---|-------|-----|----|
| Enclosure (YDK15-6:Match-Well) | - | - | 96,3 | 150 | -- |
| Enclosure (YDK15-6:Tongde) | - | - | 125,5 | 150 | -- |
| Enclosure (YDK18-4:Welling) | - | - | 100,4 | 150 | -- |
| Enclosure (YDK18-4:Match-Well) | - | - | 96,6 | 150 | -- |
| Enclosure (YDK18-4:Tongde) | - | - | 126,5 | 150 | -- |
| Enclosure (YSK48-4P:Welling) | - | - | 94,5 | 150 | -- |
| Enclosure (YSK61-4P:Welling) | - | - | 95,4 | 150 | -- |
| Enclosure (YSK27-4C:Match-Well) | - | - | 96,5 | 150 | -- |
| Enclosure (YSK48-4P:Match-Well) | - | - | 98,0 | 150 | -- |
| Enclosure (YSK61-4P:Match-Well) | - | - | 99,6 | 150 | -- |
| Enclosure (YSK100-4P:Match-Well) | - | - | 103,8 | 150 | -- |
| Enclosure (YSK200-4P:Match-Well) | - | - | 102,0 | 150 | -- |
| Enclosure (YSK180-4P:Match-Well) | - | - | 109,6 | 150 | -- |
| Enclosure (YSK48-4P:YONGAN) | - | - | 122,5 | 150 | -- |
| Enclosure (YSK61-4P:YONGAN) | - | - | 117,2 | 150 | -- |
| Enclosure (YSK100-4P:YONGAN) | - | - | 123,4 | 150 | -- |
| Enclosure (YSK200-4P:YONGAN) | - | - | 137,7 | 150 | -- |
| Enclosure (YSK180-4P:YONGAN) | - | - | 137,3 | 150 | -- |
| Enclosure (YSK27-4C:Tongde) | - | - | 127,5 | 150 | -- |
| Enclosure (YSK48-4P:Tongde) | - | - | 138,0 | 150 | -- |
| Enclosure (YSK61-4P:Tongde) | - | - | 132,5 | 150 | -- |
| Enclosure (YSK100-4P:Tongde) | - | - | 132,0 | 150 | -- |
| Enclosure (YSK200-4P:Tongde) | - | - | 132,0 | 150 | -- |
| Enclosure (YSK180-4P:Tongde) | - | - | 128,0 | 150 | -- |
| Enclosure (WZDK750-38GS-W:NIDEC) | - | - | 112,5 | 150 | -- |
| Enclosure (WZDK750-38GS-W:Welling) | - | - | 116,8 | 150 | -- |
| Enclosure (WZDK750-38GS-W:Panasonic) | - | - | 108,5 | 150 | -- |
| Enclosure (ZKSP-58-8-1:NIDEC) | - | - | 81,8 | 150 | -- |
| Enclosure (ZKSP-58-8-1:Welling) | - | - | 106,8 | 150 | -- |
| Enclosure (ZKSP-60-8-3:NIDEC) | - | - | 81,8 | 150 | -- |
| Enclosure (ZKSP-60-8-3:Welling) | - | - | 105,3 | 150 | -- |
| Enclosure (YSK27-4C: Welling) | - | - | 118,2 | 150 | - |
| Enclosure (YSK27-4C: Yong an) | - | - | 110,1 | 150 | - |
| Enclosure (YSK48-4P: Welling) | - | - | 94,5 | 150 | - |
| Enclosure (YSK48-4P: Yong an) | - | - | 122,6 | 150 | - |
| Enclosure (YSK61-4P: Welling) | - | - | 95,4 | 150 | - |

| | | | | | |
|--------------------------------------|---|---|-------|-----|----|
| Enclosure (YSK61-4P: Match-Well) | - | - | 97,0 | 150 | - |
| Winding (ZKSP-30-8-3L: Match-Well) | - | - | 90,1 | 215 | E |
| Enclosure (ZKSP-30-8-3L: Match-Well) | - | - | 78,5 | 150 | -- |
| Winding (ZKSP-30-8-3L: NIDEC) | - | - | 110,2 | 215 | E |
| Enclosure (ZKSP-30-8-3L: NIDEC) | - | - | 72,9 | 150 | -- |
| Winding (ZKSP-30-8-3L: Welling) | - | - | 102,3 | 225 | B |
| Enclosure (ZKSP-30-8-3L: Welling) | - | - | 82,9 | 150 | -- |
| Winding (ZKSP-30-8-3L: Tongde) | - | - | 129,3 | 215 | E |
| Enclosure (ZKSP-30-8-3L: Tongde) | - | - | 88,3 | 150 | -- |
| Winding (ZKSP-30-8-3L: YongAn) | - | - | 117,2 | 225 | B |
| Enclosure (ZKSP-30-8-3L: YongAn) | - | - | 85,2 | 150 | -- |
| Winding (ZKSP-60-8-2: Match-Well) | - | - | 112,4 | 215 | E |
| Enclosure (ZKSP-60-8-2: Match-Well) | - | - | 83,5 | 150 | -- |
| Winding (ZKSP-60-8-2: NIDEC) | - | - | 121,8 | 215 | E |
| Enclosure (ZKSP-60-8-2: NIDEC) | - | - | 69,9 | 150 | -- |
| Winding (ZKSP-60-8-2: Welling) | - | - | 110,2 | 225 | B |
| Enclosure (ZKSP-60-8-2: Welling) | - | - | 72,3 | 150 | -- |
| Winding (ZKSP-60-8-2: Tongde) | - | - | 108,9 | 215 | E |
| Enclosure (ZKSP-60-8-2: Tongde) | - | - | 76,3 | 150 | -- |
| Winding (ZKSP-60-8-2: YongAn) | - | - | 120,8 | 225 | B |
| Enclosure (ZKSP-60-8-2: YongAn) | - | - | 79,9 | 150 | -- |
| Winding (WZDK150-38GS: Match-Well) | - | - | 117,8 | 215 | E |
| Enclosure (WZDK150-38GS: Match-Well) | - | - | 78,1 | 150 | -- |
| Winding (WZDK150-38GS: NIDEC) | - | - | 121,8 | 215 | E |
| Enclosure (WZDK150-38GS: NIDEC) | - | - | 74,8 | 150 | -- |
| Winding (WZDK150-38GS: Welling) | - | - | 100,2 | 225 | E |
| Enclosure (WZDK150-38GS: Welling) | - | - | 73,4 | 150 | -- |
| Winding (ZKSP-20-8-1-1: Panasonic) | - | - | 119,3 | 215 | E |
| Enclosure (ZKSP-20-8-1-1: Panasonic) | - | - | 80,2 | 150 | -- |
| Winding (ZKSP-20-8-1-1: Welling) | - | - | 119,3 | 215 | E |
| Enclosure (ZKSP-20-8-1-1: Welling) | - | - | 82,0 | 150 | -- |
| Winding (WZDK60-38GS: NIDEC) | - | - | 120,4 | 215 | E |
| Enclosure (WZDK60-38GS: NIDEC) | - | - | 84,9 | 150 | -- |
| Winding (WZDK60-38GS: Welling) | - | - | 120,3 | 215 | E |
| Enclosure (WZDK60-38GS: Welling) | - | - | 72,5 | 150 | -- |
| Winding (WZDK100-38GS-2: Panasonic) | - | - | 111,8 | 215 | E |

| | | | | | |
|--|---|---|-------|-----|----|
| Enclosure (WZDK100-38GS-2: Panasonic) | - | - | 78,2 | 150 | -- |
| Winding (WZDK100-38GS-2: Match-well) | - | - | 106,8 | 225 | E |
| Enclosure (WZDK100-38GS-2: Match-well) | - | - | 81,1 | 150 | -- |
| Winding (ZKSP-80-8-2: NIDEC) | - | - | 111,1 | 215 | E |
| Enclosure (ZKSP-80-8-2: NIDEC) | - | - | 78,5 | 150 | -- |
| Winding (ZKSP-80-8-2: Welling) | - | - | 107,8 | 215 | E |
| Enclosure (ZKSP-80-8-2: Welling) | - | - | 72,1 | 150 | -- |
| Winding (ZKSP-80-8-2: YongAn) | - | - | 122,3 | 225 | B |
| Enclosure (ZKSP-80-8-2: YongAn) | - | - | 83,6 | 150 | -- |
| Winding (ZKSP-170-8-6: NIDEC) | - | - | 111,9 | 215 | E |
| Enclosure (ZKSP-170-8-6: NIDEC) | - | - | 79,6 | 150 | -- |
| Winding (ZKSP-170-8-6: Welling) | - | - | 110,0 | 225 | E |
| Enclosure (ZKSP-170-8-6: Welling) | - | - | 68,2 | 150 | -- |
| Winding (ZKSP-170-8-6: YongAn) | - | - | 120,9 | 225 | B |
| Enclosure (ZKSP-170-8-6: YongAn) | - | - | 90,1 | 150 | -- |
| Winding (WZDK37-38G: NIDEC) | - | - | 126,8 | 215 | E |
| Enclosure (WZDK37-38G: NIDEC) | - | - | 88,5 | 150 | -- |
| Winding (WZDK37-38G: Welling) | - | - | 130,8 | 225 | E |
| Enclosure (WZDK37-38G: Welling) | - | - | 98,5 | 150 | -- |
| Winding (WZDK37-38G: Match-well) | - | - | 127,3 | 215 | E |
| Enclosure (WZDK37-38G: Match-well) | - | - | 90,1 | 150 | -- |
| Winding (WZDK100-38GS-1: Welling) | - | - | 122,8 | 215 | E |
| Enclosure (WZDK100-38GS-1: Welling) | - | - | 88,5 | 150 | -- |
| Winding (WZDK100-38GS-1: Panasonic) | - | - | 125,2 | 215 | E |
| Enclosure (WZDK100-38GS-1: Panasonic) | - | - | 90,2 | 150 | -- |
| Winding (WZDK100-38GS-3: Panasonic) | - | - | 122,8 | 215 | E |
| Enclosure (WZDK100-38GS-3: Panasonic) | - | - | 89,0 | 150 | -- |
| Winding (WZDK100-38GS-3: Match-well) | - | - | 122,4 | 215 | E |
| Enclosure (WZDK100-38GS-3: Match-well) | - | - | 87,3 | 150 | -- |
| Winding (WZDK750-38G-W: Welling) | - | - | 132,8 | 225 | E |
| Enclosure (WZDK750-38G-W: Welling) | - | - | 90,2 | 150 | -- |
| Winding (WZDK750-38G-W: Panasonic) | - | - | 133,8 | 215 | E |
| Enclosure (WZDK750-38G-W: Panasonic) | - | - | 98,5 | 150 | -- |
| Winding (WZDK750-38GS-W: Welling) | - | - | 132,1 | 225 | E |
| Enclosure (WZDK750-38GS-W: Welling) | - | - | 93,5 | 150 | -- |
| Winding (WZDK750-38GS-W: Panasonic) | - | - | 134,1 | 215 | E |

| | | | | | |
|---------------------------------------|---|---|-------|-----|----|
| Enclosure (WZDK750-38GS-W: Panasonic) | - | - | 87,1 | 150 | -- |
| Winding (ZKSN-920-8-12: NIDEC) | - | - | 128,3 | 215 | E |
| Enclosure (ZKSN-920-8-12: NIDEC) | - | - | 90,2 | 150 | -- |
| Winding (ZKSN-920-8-12: YongAn) | - | - | 126,3 | 225 | B |
| Enclosure (ZKSN-920-8-12: YongAn) | - | - | 88,5 | 150 | -- |
| Winding (WZDK240-38GS: Match-Well) | - | - | 114,4 | 215 | E |
| Enclosure (WZDK240-38GS: Match-Well) | - | - | 83,5 | 150 | -- |
| Winding (WZDK240-38GS: NIDEC) | - | - | 112,9 | 215 | E |
| Enclosure (WZDK240-38GS: NIDEC) | - | - | 85,6 | 150 | -- |
| Winding (WZDK240-38GS: Welling) | - | - | 118,6 | 215 | E |
| Enclosure (WZDK240-38GS: Welling) | - | - | 85,4 | 150 | -- |
| Winding (WZDK20-38G: NIDEC) | - | - | 107,6 | 215 | E |
| Enclosure (WZDK20-38G:NIDEC) | - | - | 80,2 | 150 | -- |
| Winding (WZDK20-38G: Welling) | - | - | 102,0 | 215 | E |
| Enclosure (WZDK20-38G:Welling) | - | - | 91,4 | 150 | -- |
| Winding (ZKSP-58-8-1: NIDEC) | - | - | 102,3 | 215 | E |
| Enclosure (ZKSP-58-8-1: NIDEC) | - | - | 88,3 | 150 | -- |
| Winding (ZKSP-58-8-1: Welling) | - | - | 107,2 | 215 | E |
| Enclosure (ZKSP-58-8-1: Welling) | - | - | 88,5 | 150 | -- |
| Winding (ZKSP-60-8-3: NIDEC) | - | - | 104,3 | 215 | E |
| Enclosure (ZKSP-60-8-3: NIDEC) | - | - | 87,4 | 150 | -- |
| Winding (ZKSP-60-8-3: Welling) | - | - | 103,2 | 215 | E |
| Enclosure (ZKSP-60-8-3: Welling) | - | - | 84,8 | 150 | -- |
| Winding (ZKSP-240-8-1: NIDEC) | - | - | 111,2 | 215 | E |
| Enclosure (ZKSP-240-8-1: NIDEC) | - | - | 95,2 | 150 | -- |
| Winding(RD-280-20-8A: Panasonic) | - | - | 113,2 | 215 | E |
| Enclosure (RD-280-20-8A: Panasonic) | - | - | 102,8 | 150 | -- |
| Winding(RD-280-20-8A: Welling) | - | - | 93,8 | 215 | E |
| Enclosure (RD-280-20-8A: Welling) | - | - | 91,4 | 150 | -- |
| PUMP | | | | | |
| Winding(PLD-F12230MISZ-1:Fujikoki) | - | - | 55,0 | 215 | E |
| Winding(PSB-7:zhongbao) | - | - | 92,6 | 215 | E |
| Winding(PSB-7HY:Huayang) | - | - | 89,3 | 215 | E |
| Winding(PSB-7A:Junle) | - | - | 91,0 | 215 | E |
| Winding(PSB12:zhongbao) | - | - | 84,6 | 215 | E |
| Winding(PSB12: Junle) | - | - | 81,7 | 215 | E |

| | | | | | |
|--------------------------------------|---|---|------|-----|----|
| Winding(PLD-12:Lepuda) | - | - | 82,9 | 215 | E |
| Winding(PSB-12A:Sanhua) | - | - | 83,4 | 215 | E |
| Winding(PSB-7A: Fujikoki) | - | - | 92,0 | 215 | E |
| Winding (PSB-7:Lepuda) | - | - | 79,5 | 215 | E |
| Enclosure(PLD-F12230MISZ-1:Fujikoki) | - | - | 48,0 | 150 | -- |
| Enclosure(PSB-7:zhongbao) | - | - | 89,3 | 150 | -- |
| Enclosure(PSB-7A:Fujikoki) | - | - | 88,0 | 150 | -- |
| Enclosure (PSB-7HY:Huayang) | - | - | 82,5 | 150 | -- |
| Enclosure (PSB-7A:Junle) | - | - | 80,6 | 150 | -- |
| Enclosure (PSB12:zhongbao) | - | - | 77,3 | 150 | -- |
| Enclosure (PSB12:Junle) | - | - | 72,0 | 150 | -- |
| Enclosure (PLD-12:Lepuda) | - | - | 73,3 | 150 | -- |
| Enclosure (PSB-12A:Sanhua) | - | - | 77,8 | 150 | -- |
| Enclosure (PSB-7:Lepuda) | - | - | 74,5 | 150 | -- |

Remark:

1. The fan motor WZDK100-38GS-3, WZDK100-38GS-2, WZDK100-38GS-1 and WZDK100-38GS are the same except the length of fan motor shaft and wire, So the fan motor WZDK100-38GS-2 is selected as representative;
2. The fan motor WZDK240-38G and WZDK240-38GS are the same except fan motor shaft, So the fan motor WZDK240-38GS is selected as representative;
3. The fan motor WZDK750-38G-W and WZDK750-38GS-W are the same except fan motor shaft, So the fan motor WZDK750-38GS-W is selected as representative;
4. Only the thermocouples method is used in this test.

| | | | |
|-------------------------------|---|------------------|-----------------------|
| 19.2 | TABLE: electric strength measurements after 72 hours | | P |
| Test voltage applied between: | | Test voltage (V) | Breakdown Yes / No |
| For all fan motors | | | |
| L/N-enclosure of fan motor | | 1250 | No |

| | | | |
|--|---|--------|-----------------|
| 19.2 | TABLE: leakage current measurements after 72 hours | | P |
| A voltage equal to twice the rated voltage (V) : | | 480V | — |
| Leakage current I between : | | I (mA) | Required I (mA) |
| YSK31-6-1 (Welling) | | 0,32 | 2.0 |
| YSK31-6-1 (yong'an) | | 0,09 | 2.0 |
| YSK58-4-1 (Welling) | | 0,56 | 2.0 |
| YSK58-4-1 (yong'an) | | 0,10 | 2.0 |

| | | |
|--------------------------|------|-----|
| YSK91-4 (Welling) | 0,62 | 2.0 |
| YSK91-4 (yong'an) | 0,09 | 2.0 |
| YDK15-6M (Welling) | 0,20 | 2.0 |
| YDK15-6M (broad-ocean) | 0,22 | 2.0 |
| YDK15-6M (Tongde) | 0,16 | 2.0 |
| YDK15-6P (Welling) | 0,05 | 2.0 |
| YDK15-6P (broad-ocean) | 0,23 | 2.0 |
| YDK15-6P (Tongde) | 0,16 | 2.0 |
| YSK300-4C-1 (yong'an) | 0,15 | 2.0 |
| YDK250-4X (yong'an) | 0,23 | 2.0 |
| YSK27-4C (Welling) | 0,26 | 2.0 |
| YSK27-4C (yong'an) | 0,09 | 2.0 |
| YSK27-4C: welling | 0,71 | 2,0 |
| YSK27-4C: Tongde | 0,52 | 2,0 |
| YSK27-4C: Yongan | 0,54 | 2,0 |
| YSK68-4P (Welling) | 0,04 | 2.0 |
| YSK74-4P (Welling) | 0,05 | 2.0 |
| YSK100-4P (Welling) | 0,06 | 2.0 |
| YSK200-4P (Welling) | 0,09 | 2.0 |
| YSK180-4P (Welling) | 0,10 | 2.0 |
| RD-280-20-8A (Panasonic) | 0,19 | 2.0 |
| YSK20-6 (yong'an) | 0,13 | 2.0 |
| YSK28-4E (welling) | 0,16 | 2.0 |
| YSK74-4E (yong'an) | 0,18 | 2.0 |
| YDK100-4X-2 (yong'an) | 0,12 | 2.0 |
| YDK160-4C (welling) | 0,20 | 2.0 |
| YDK200-4F-1 (welling) | 0,23 | 2.0 |
| YSK400-4C-1 (yong'an) | 0,43 | 2.0 |
| YDK550-4X (yong'an) | 0,10 | 2.0 |
| YSK59-4A (yong'an) | 0,14 | 2.0 |
| YDK550-4X (Match-Well) | 0,17 | 2,0 |
| YDK250-4X (Match-Well) | 0,18 | 2,0 |
| YSK70-4P (Welling) | 0,07 | 2.0 |
| YSK70-4P (yong'an) | 0,43 | 2.0 |
| YDK50-4E-1 (Welling) | 0,05 | 2.0 |
| YDK50-4E-1 (BROAD-OCEAN) | 0,07 | 2.0 |

| | | |
|---------------------------|------|-----|
| YSK27-4C(B) (broad-ocean) | 0,06 | 2,0 |
| YSK27-4C(B) (Welling) | 0,06 | 2,0 |
| YDK9-6A (Welling) | 0,07 | 2,0 |
| RPS12N (broad-ocean) | 0,25 | 2,0 |
| RPS12N (Welling) | 0,01 | 2,0 |
| RPS10H (Broad-ocean) | 0,27 | 2,0 |
| RPS14 (Broad-ocean) | 0,26 | 2,0 |
| RPS14D (Broad-ocean) | 0,25 | 2,0 |
| YDK45-4C (Broad-ocean) | 0,26 | 2,0 |
| RPS10H (Welling) | 0,01 | 2,0 |
| RPS14 (Welling) | 0,01 | 2,0 |
| RPS14D (Welling) | 0,01 | 2,0 |
| YDK45-4C (Welling) | 0,01 | 2,0 |
| YDK65-6S (Welling) | 0,15 | 2,0 |
| YDK65-6S (Tongde) | 0,17 | 2,0 |
| YDK65-6S (Broad-ocean) | 0,18 | 2,0 |
| YDK50-6S (Tongde) | 0,14 | 2,0 |
| YDK50-6S (Broad-ocean) | 0,22 | 2,0 |
| YDK37-6S (Welling) | 0,13 | 2,0 |
| YDK37-6S (Tongde) | 0,13 | 2,0 |
| YDK37-6S (Broad-ocean) | 0,16 | 2,0 |
| YDK30-6S (Welling) | 0,12 | 2,0 |
| YDK30-6S (Tongde) | 0,18 | 2,0 |
| YDK30-6S (Broad-ocean) | 0,19 | 2,0 |
| YDK26-6S (Welling) | 0,12 | 2,0 |
| YDK26-6S (Tongde) | 0,15 | 2,0 |
| YDK26-6S (Broad-ocean) | 0,18 | 2,0 |
| YSK61-4P(B) (Welling) | 0,10 | 2,0 |
| YSK61-4P(B) (Tongde) | 0,16 | 2,0 |
| YKSS-61-4-63: Welling | 0,54 | 2,0 |
| YKSS-61-4-63: tongde | 0,31 | 2,0 |
| YKSS-61-4-63: Match-Well | 0,22 | 2,0 |
| YSK48-4P(B) (Welling) | 0,05 | 2,0 |
| YSK48-4P(B) (Tongde) | 0,15 | 2,0 |
| YKSS-36-4-65: Welling | 0,55 | 2,0 |
| YKSS-36-4-65: Tongde | 0,53 | 2,0 |

| | | |
|----------------------------|------|-----|
| YKSS-36-4-65: Yongan | 0,60 | 2,0 |
| YSK27-4C(B) (Tongde) | 0,15 | 2,0 |
| WZDK20-38G (NIDEC) | 0,03 | 2,0 |
| WZDK20-38G (Welling) | 0,09 | 2,0 |
| WZDK60-38G (NIDEC) | 0,03 | 2,0 |
| WZDK60-38G (Welling) | 0,07 | 2,0 |
| WZDK37-38G (NIDEC) | 0,11 | 2,0 |
| WZDK37-38G (Welling) | 0,04 | 2,0 |
| WZDK80-38G (NIDEC) | 0,05 | 2,0 |
| WZDK80-38G (Welling) | 0,06 | 2,0 |
| WZDK80-38G (Panasonic) | 0,08 | 2,0 |
| YSK74-4E (Match-Well) | 0,06 | 2,0 |
| WZDK100-38GS-2 (Panasonic) | 0,32 | 2,0 |
| WZDK100-38GS-2 (NIDEC) | 0,09 | 2,0 |
| WZDK100-38GS-2 (Welling) | 0,07 | 2,0 |
| WZDK150-38GS (Panasonic) | 0,27 | 2,0 |
| WZDK150-38GS (NIDEC) | 0,10 | 2,0 |
| WZDK150-38GS (Welling) | 0,08 | 2,0 |
| WZDK240-38GS (Panasonic) | 0,25 | 2,0 |
| WZDK240-38GS (NIDEC) | 0,09 | 2,0 |
| WZDK240-38GS (Welling) | 0,08 | 2,0 |
| YDK38-4 (Welling) | 0,08 | 2,0 |
| YDK38-4 (Tongde) | 0,16 | 2,0 |
| YDK38-4 (YONGAN) | 0,09 | 2,0 |
| YDK43-4 (Welling) | 0,04 | 2,0 |
| YDK43-4 (Tongde) | 0,13 | 2,0 |
| YDK43-4 (YONGAN) | 0,41 | 2,0 |
| YDK15-6 (Welling) | 0,21 | 2,0 |
| YDK15-6 (Match-Well) | 0,17 | 2,0 |
| YDK15-6 (Tongde) | 0,14 | 2,0 |
| YDK18-4 (Welling) | 0,19 | 2,0 |
| YDK18-4 (Match-Well) | 0,17 | 2,0 |
| YDK18-4 (Tongde) | 0,14 | 2,0 |
| YSK48-4P (Welling) | 0,05 | 2,0 |
| YSK61-4P (Welling) | 0,06 | 2,0 |
| YSK27-4C (Match-Well) | 0,15 | 2,0 |

| | | |
|-----------------------------|------|-----|
| YSK48-4P (Match-Well) | 0,15 | 2,0 |
| YSK61-4P (Match-Well) | 0,16 | 2,0 |
| YSK100-4P (Match-Well) | 0,17 | 2,0 |
| YSK200-4P (Match-Well) | 0,18 | 2,0 |
| YSK180-4P (Match-Well) | 0,18 | 2,0 |
| YSK48-4P (YONGAN) | 0,41 | 2,0 |
| YSK61-4P (YONGAN) | 0,10 | 2,0 |
| YSK100-4P (YONGAN) | 0,65 | 2,0 |
| YSK200-4P (YONGAN) | 0,91 | 2,0 |
| YSK180-4P (YONGAN) | 0,82 | 2,0 |
| YSK27-4C (Tongde) | 0,16 | 2,0 |
| YSK48-4P (Tongde) | 0,18 | 2,0 |
| YSK61-4P (Tongde) | 0,15 | 2,0 |
| YSK100-4P (Tongde) | 0,16 | 2,0 |
| YSK200-4P (Tongde) | 0,15 | 2,0 |
| YSK180-4P (Tongde) | 0,17 | 2,0 |
| WZDK750-38GS-W (NIDEC) | 0,28 | 2,0 |
| WZDK750-38GS-W (Welling) | 0,23 | 2,0 |
| WZDK750-38GS-W (Panasonic) | 0,25 | 2,0 |
| ZKSP-58-8-1 (NIDEC) | 0,07 | 2,0 |
| ZKSP-58-8-1 (Welling) | 0,05 | 2,0 |
| ZKSP-60-8-3 (NIDEC) | 0,10 | 2,0 |
| ZKSP-60-8-3 (Welling) | 0,06 | 2,0 |
| PLD-F12230MISZ-1 (Fujikoki) | 0,07 | 2,0 |
| PSB-7 (zhongbao) | 0,13 | 2,0 |
| PSB-7HY (Huayang) | 0,02 | 2,0 |
| PSB-7A (Junle) | 0,05 | 2,0 |
| PSB12 (zhongbao) | 0,10 | 2,0 |
| PSB12 (Junle) | 0,07 | 2,0 |
| PLD-12 (Lepuda) | 0,03 | 2,0 |
| PSB-7 (Lepuda) | 0,08 | 2,0 |
| PSB-12A (Sanhua) | 0,02 | 2,0 |
| PSB-7A (Fujikoki) | 0,03 | 2,0 |
| YSK27-4C (Welling) | 0,05 | 2,0 |
| YSK27-4C (Yong an) | 0,36 | 2,0 |
| YSK48-4P (Welling) | 0,05 | 2,0 |

| | | |
|--------------------------------------|------|-----|
| YSK48-4P (Yong an) | 0,39 | 2,0 |
| YSK61-4P (Welling) | 0,06 | 2,0 |
| YSK61-4P (Match-Well) | 0,17 | 2,0 |
| Winding (ZKSP-30-8-3L: Match-Well) | 1,10 | 2,0 |
| Winding (ZKSP-30-8-3L: NIDEC) | 1,10 | 2,0 |
| Winding (ZKSP-30-8-3L: Welling) | 0,55 | 2,0 |
| Winding (ZKSP-30-8-3L: Tongde) | 0,56 | 2,0 |
| Winding (ZKSP-30-8-3L: YongAn) | 1,56 | 2,0 |
| Winding (ZKSP-60-8-2: Match-Well) | 1,10 | 2,0 |
| Winding (ZKSP-60-8-2: NIDEC) | 0,40 | 2,0 |
| Winding (ZKSP-60-8-2: Welling) | 1,12 | 2,0 |
| Winding (ZKSP-60-8-2: Tongde) | 1,00 | 2,0 |
| Winding (ZKSP-60-8-2: YongAn) | 0,56 | 2,0 |
| Winding (WZDK150-38GS: Match-Well) | 0,45 | 2,0 |
| Winding (WZDK150-38GS: NIDEC) | 0,45 | 2,0 |
| Winding (WZDK150-38GS: Welling) | 0,64 | 2,0 |
| Winding (WZDK240-38GS: Match-Well) | 0,70 | 2,0 |
| Winding (WZDK240-38GS: NIDEC) | 0,52 | 2,0 |
| Winding (WZDK240-38GS: Welling) | 0,51 | 2,0 |
| Winding (ZKSP-20-8-1-1: Panasonic) | 0,50 | 2,0 |
| Winding (ZKSP-20-8-1-1: Welling) | 0,82 | 2,0 |
| Winding (WZDK60-38GS: NIDEC) | 0,61 | 2,0 |
| Winding (WZDK60-38GS: Welling) | 0,55 | 2,0 |
| Winding (WZDK100-38GS-2: Panasonic) | 0,64 | 2,0 |
| Winding (WZDK100-38GS-2: Match-well) | 0,58 | 2,0 |
| Winding (ZKSP-80-8-2: NIDEC) | 0,71 | 2,0 |
| Winding (ZKSP-80-8-2: Welling) | 0,65 | 2,0 |
| Winding (ZKSP-80-8-2: YongAn) | 0,78 | 2,0 |
| Winding (ZKSP-170-8-6: NIDEC) | 0,56 | 2,0 |
| Winding (ZKSP-170-8-6: Welling) | 1,00 | 2,0 |
| Winding (ZKSP-170-8-6: YongAn) | 0,55 | 2,0 |
| Winding (WZDK37-38G: NIDEC) | 0,59 | 2,0 |
| Winding (WZDK37-38G: Welling) | 0,58 | 2,0 |
| Winding (WZDK37-38G: Match-well) | 0,45 | 2,0 |
| Winding (WZDK100-38GS-1: Welling) | 0,62 | 2,0 |
| Winding (WZDK100-38GS-1: Panasonic) | 0,67 | 2,0 |

| | | |
|--------------------------------------|------|-----|
| Winding (WZDK100-38GS-3: Panasonic) | 0,48 | 2,0 |
| Winding (WZDK100-38GS-3: Match-well) | 0,60 | 2,0 |
| Winding (WZDK750-38G-W: Welling) | 0,58 | 2,0 |
| Winding (WZDK750-38G-W: Panasonic) | 0,50 | 2,0 |
| Winding (WZDK750-38GS-W: Welling) | 0,51 | 2,0 |
| Winding (WZDK20-38G: NIDEC) | 0,78 | 2,0 |
| Winding (WZDK20-38G: Welling) | 0,56 | 2,0 |
| Winding (ZKSP-58-8-1: NIDEC) | 1,00 | 2,0 |
| Winding (ZKSP-58-8-1: Welling) | 0,55 | 2,0 |
| Winding (ZKSP-60-8-3: NIDEC) | 0,59 | 2,0 |
| Winding (ZKSP-60-8-3: Welling) | 0,65 | 2,0 |
| Winding (ZKSP-240-8-1: NIDEC) | 0,54 | 2,0 |
| Winding (RD-280-20-8A: Panasonic) | 0,32 | 2,0 |
| Winding (RD-280-20-8A: Welling) | 0,12 | 2,0 |

| | | | | | |
|------------------------------------|---|----------------------|-------------|-------------|-----------------|
| 19.3 | Abnormal operation conditions – Locked rotor test motor-compressor | | | | N/A |
| | Motor-compressor | -- | | | |
| | Start device | -- | | | |
| | Protector | -- | | | |
| | Start capacitor | -- | | | |
| | Run capacitor..... | -- | | | |
| | Cooling; (static); (fan-m ³ /h); (oil); | Static | | | |
| | Thermal motor-protection system | Self-resetting reset | | | |
| | | Self-resetting | | | Manually reset |
| Rated voltage | Vn max (V) | | | Vn min (V) | Vn max (V) |
| | After 72 h | After 288 h | After 360 h | After 363 h | After 50 cycles |
| High-voltage test (see 16.3) | - | - | - | - | - |
| Leakage current (mA) (see 16.2) | - | - | - | - | - |
| Electric strength (see 13.3) | - | - | - | - | - |
| Room temperature (°C) (20 ± 5°C) | - | - | - | - | - |
| Number of cycles (≥ 2000 or 50) | - | - | - | - | - |
| Housing temperature (°C) (≤ 150°C) | - | - | - | - | - |
| supplementary information: -- | | | | | |

| 19.5-19.9 | Abnormal operation conditions | P |
|----------------------------|-------------------------------|---------|
| Subclause | Effect | Verdict |
| 19.5 | See below table 19,5 | P |
| 19.6 | Normal operation, no hazards | P |
| 19.7 | See the clause 19,7 | P |
| 19.8 | See the clause 19,8 | P |
| 19.9 | - | N/A |
| Supplementary information: | | |

| 19.5 | TABLE: restrict heat exchangers test | | P |
|--|--|--------|--------|
| | t1 (°C) | : 23,0 | — |
| | t2 (°C) | : 23,0 | — |
| Procedure | 240 V | | — |
| Duration | Until steady conditions are obtained or the protective device operates | | — |
| Restrict heat exchanger | phenomenon | | hazard |
| For all models | | | |
| Restrict evaporator at cooling mode | Operated normally. | | No |
| Restrict evaporator at heating mode | Operated normally. | | No |
| Restrict condenser at cooling mode | Operated normally. | | No |
| Restrict condenser at heating mode | Operated normally. | | No |
| Remark: the test was performed on all models and only the severe result is listed. | | | |

| 19.7 | TABLE: low and high temperature test | | P |
|--|--|---------------------------|--------|
| Low temperature | t (°C) | Indoor unit: 10/--(DB/WB) | — |
| High temperature | t (°C) | Indoor unit: 42/--(DB/WB) | — |
| Procedure | 240 V | | — |
| Duration | Until steady conditions are obtained or the protective device operates | | — |
| | phenomenon | | hazard |
| For all models | | | |
| Dry-bulb temperature reduced a value 5 K below the minimum value | Operated normally. | | No |
| Dry-bulb temperature increased a value 10 K above the maximum value | Operated normally. | | No |
| Remark: the test was performed on all models and only the severe result is listed. | | | |

| 19.10 | | Abnormal operation conditions | P |
|--|--|--|---------|
| Failure description | | Effect | Verdict |
| The programmed controller, if any, stopping in any position | | Normal operation. | P |
| Disconnection and reconnection of one or more phases of the supply | | -- | N/A |
| Open-circuiting or short-circuiting of components | | Protection occurred and the appliance stopped. | P |
| Supplementary information: only the unfavourable result is listed | | | |

| 19.11.2 | | Abnormal Operation | | | P |
|-----------------|---------------|--------------------|--------------------------------|---------|---|
| Fault condition | Short circuit | Open circuit | Effect | Verdict | |
| Transformer | Yes | No | The appliance stops running | P | |
| PC817 | Yes | No | The appliance stops running | P | |
| PC817 | No | Yes | The appliance stops running | P | |
| ZR1 | Yes | No | The appliance stops running | P | |
| ZR1 | No | Yes | The appliance running normally | P | |
| BR1 | Yes | No | The appliance stops running | P | |
| BR1 | No | Yes | The appliance stops running | P | |
| E1 | Yes | No | The appliance stops running | P | |
| E1 | No | Yes | The appliance stops running | P | |
| IC1 | Yes | No | The appliance stops running | P | |
| IC1 | No | Yes | The appliance stops running | P | |
| Q2 | Yes | No | The appliance running normally | P | |
| D8 | Yes | No | The appliance stops running | P | |
| D8 | No | Yes | The appliance stops running | P | |

| 19.14 | | TABLE: Abnormal operation, temperature rises | | P |
|--|--|--|-------------|---|
| Thermocouple locations | | T (°C) | Max. T (°C) | |
| Insulation of supply cord | | 55,2 | 175 | |
| Walls, ceiling and floor of the test casing | | 52,8 | 175 | |
| Supplementary information: only the highest value is listed on this table according to the test result of clause 19. | | | | |

| 21.1 | TABLE: Impact resistance | | | P |
|----------------------------|---------------------------------|--------------------|------------|----------|
| Impacts per surface | Surface tested | Impact energy (Nm) | Comments | |
| 3 | Enclosure of indoor unit | 0,5J | No damaged | |
| Supplementary information: | | | | |

| 24.1 | TABLE: Critical components information (see CDF) | | | | P |
|---|---|--------------|----------------|----------|--|
| Object / part No. | Manufacturer/ trademark | Type / model | Technical data | Standard | Mark(s) of conformity ¹⁾ |
| - | - | - | - | - | - |
| Supplementary information: | | | | | |
| 1) Provided evidence ensures the agreed level of compliance. See OD-CB2039. | | | | | |

| 28.1 | TABLE: Threaded part torque test | | | P |
|--------------------------------------|---|----------------------------------|---------------------|----------|
| Threaded part identification | Diameter of thread (mm) | Column number (I, II, or III) | Applied torque (Nm) | |
| Screw for enclosure of unit | 4 | II | 1,2 | |
| Screw fixing earthing connections | 4 | II | 1,2 | |
| Supplementary information: -- | | | | |

| 29.1 | | TABLE: Clearances | | | | | P |
|----------------------------|----------------------|----------------------------|--------------------|-----------------|-----------------|------------------|---|
| | | Overvoltage category | | | II | | — |
| | | Type of insulation: | | | | | |
| Rated impulse voltage (V): | Min. cl (mm) | Basic (mm) | Supplementary (mm) | Reinforced (mm) | Functional (mm) | Verdict / Remark | |
| 330 | 0,2* / 0,5 / 0,8** | -- | -- | -- | -- | N/A | |
| 500 | 0,2* / 0,5 / 0,8** | -- | -- | -- | -- | N/A | |
| 800 | 0,2* / 0,5 / 0,8** | -- | -- | -- | -- | N/A | |
| 1 500 | 0,5 / 0,8** / 1,0*** | -- | -- | -- | -- | N/A | |
| 2 500 | 1,5 / 2,0*** | 3,0 | 4,6 | -- | 3,6 | P | |
| 4 000 | 3,0 / 3,5*** | -- | -- | 8,0 | -- | P | |
| 6 000 | 5,5 / 6,0*** | -- | -- | -- | -- | N/A | |
| 8 000 | 8,0 / 8,5*** | -- | -- | -- | -- | N/A | |
| 10 000 | 11,0 / 11,5*** | -- | -- | -- | -- | N/A | |

Supplementary information:

*) For tracks on printed circuit boards if pollution degree 1 and 2
 **) For pollution degree 3
 ***) If the construction is affected by wear, distortion, movement of the parts or during assembly

1. The clearance for basic insulation between winding and metal enclosure for fan motor is 3,0 mm.
2. The clearance for function insulation between polarity on the PCB is 3,6 mm.
3. The clearance for supplementary insulation between high voltage circuit and low voltage circuit is 4,6 mm.
4. The clearance for reinforce insulation between inner live part and accessible surface is 8,0 mm.

| 29.2 | TABLE: Creepage distances, basic, supplementary and reinforced insulation | | | | | | | | | | P |
|---------------------|---|----------------|------|-----------|----------------|------|------------|--------------------|-----|-----|---------|
| Working voltage (V) | Creepage distance (mm) Pollution degree | | | | | | | Type of insulation | | | Verdict |
| | 1 | 2 | | | 3 | | | | | | |
| | | Material group | | | Material group | | | | | | |
| | | I | II | IIIa/IIIb | I | II | IIIa/IIIb* | B** | S** | R** | |
| ≤50 | 0,18 | 0,6 | 0,85 | 1,2 | 1,5 | 1,7 | 1,9 | | — | — | N/A |
| ≤50 | 0,18 | 0,6 | 0,85 | 1,2 | 1,5 | 1,7 | 1,9 | — | | — | N/A |
| ≤50 | 0,36 | 1,2 | 1,7 | 2,4 | 3,0 | 3,4 | 3,8 | — | — | | N/A |
| 125 | 0,28 | 0,75 | 1,05 | 1,5 | 1,9 | 2,1 | 2,4 | | — | — | N/A |
| 125 | 0,28 | 0,75 | 1,05 | 1,5 | 1,9 | 2,1 | 2,4 | — | | — | N/A |
| 125 | 0,56 | 1,5 | 2,1 | 3,0 | 3,8 | 4,2 | 4,8 | — | — | | N/A |
| 250 | 0,56 | 1,25 | 1,8 | 2,5 | 3,2 | 3,6 | 4,0 | 4,0 | — | — | P |
| 250 | 0,56 | 1,25 | 1,8 | 2,5 | 3,2 | 3,6 | 4,0 | — | 4,6 | — | P |
| 250 | 1,12 | 2,5 | 3,6 | 5,0 | 6,4 | 7,2 | 8,0 | — | — | 8,0 | P |
| 400 | 1,0 | 2,0 | 2,8 | 4,0 | 5,0 | 5,6 | 6,3 | | — | — | N/A |
| 400 | 1,0 | 2,0 | 2,8 | 4,0 | 5,0 | 5,6 | 6,3 | — | | — | N/A |
| 400 | 2,0 | 4,0 | 5,6 | 8,0 | 10,0 | 11,2 | 12,6 | — | — | | N/A |
| 500 | 1,3 | 2,5 | 3,6 | 5,0 | 6,3 | 7,1 | 8,0 | | — | — | N/A |
| 500 | 1,3 | 2,5 | 3,6 | 5,0 | 6,3 | 7,1 | 8,0 | — | | — | N/A |
| 500 | 2,6 | 5,0 | 7,2 | 10,0 | 12,6 | 14,2 | 16,0 | — | — | | N/A |
| >630 and ≤800 | 1,8 | 3,2 | 4,5 | 6,3 | 8,0 | 9,0 | 10,0 | | — | — | N/A |
| >630 and ≤800 | 1,8 | 3,2 | 4,5 | 6,3 | 8,0 | 9,0 | 10,0 | — | | — | N/A |
| >630 and ≤800 | 3,6 | 6,4 | 9,0 | 12,6 | 16,0 | 18,0 | 20,0 | — | — | | N/A |
| >800 and ≤1000 | 2,4 | 4,0 | 5,6 | 8,0 | 10,0 | 11,0 | 12,5 | | — | — | N/A |
| >800 and ≤1000 | 2,4 | 4,0 | 5,6 | 8,0 | 10,0 | 11,0 | 12,5 | — | | — | N/A |
| >800 and ≤1000 | 4,8 | 8,0 | 11,2 | 16,0 | 20,0 | 22,0 | 25,0 | — | — | | N/A |
| >1000 and ≤1250 | 3,2 | 5,0 | 7,1 | 10,0 | 12,5 | 14,0 | 16,0 | | — | — | N/A |
| >1000 and ≤1250 | 3,2 | 5,0 | 7,1 | 10,0 | 12,5 | 14,0 | 16,0 | — | | — | N/A |
| >1000 and ≤1250 | 6,4 | 10,0 | 14,2 | 20,0 | 25,0 | 28,0 | 32,0 | — | — | | N/A |
| >1250 and ≤1600 | 4,2 | 6,3 | 9,0 | 12,5 | 16,0 | 18,0 | 20,0 | | — | — | N/A |
| >1250 and ≤1600 | 4,2 | 6,3 | 9,0 | 12,5 | 16,0 | 18,0 | 20,0 | — | | — | N/A |
| >1250 and ≤1600 | 8,4 | 12,6 | 18,0 | 25,0 | 32,0 | 36,0 | 40,0 | — | — | | N/A |
| >1600 and ≤2000 | 5,6 | 8,0 | 11,0 | 16,0 | 20,0 | 22,0 | 25,0 | | — | — | N/A |
| >1600 and ≤2000 | 5,6 | 8,0 | 11,0 | 16,0 | 20,0 | 22,0 | 25,0 | — | | — | N/A |

| 29.2 | TABLE: Creepage distances, basic, supplementary and reinforced insulation | | | | | | | | | | P |
|---------------------|---|----------------|-------|-----------|----------------|-------|------------|--------------------|-----|-----|---------|
| Working voltage (V) | Creepage distance (mm) Pollution degree | | | | | | | Type of insulation | | | Verdict |
| | 1 | 2 | | | 3 | | | | | | |
| | | Material group | | | Material group | | | | | | |
| | | I | II | IIIa/IIIb | I | II | IIIa/IIIb* | B** | S** | R** | |
| >1600 and ≤2000 | 11,2 | 16,0 | 22,0 | 32,0 | 40,0 | 44,0 | 50,0 | — | — | | N/A |
| >2000 and ≤2500 | 7,5 | 10,0 | 14,0 | 20,0 | 25,0 | 28,0 | 32,0 | | — | — | N/A |
| >2000 and ≤2500 | 7,5 | 10,0 | 14,0 | 20,0 | 25,0 | 28,0 | 32,0 | — | | — | N/A |
| >2000 and ≤2500 | 15,0 | 20,0 | 28,0 | 40,0 | 50,0 | 56,0 | 64,0 | — | — | | N/A |
| >2500 and ≤3200 | 10,0 | 12,5 | 18,0 | 25,0 | 32,0 | 36,0 | 40,0 | | — | — | N/A |
| >2500 and ≤3200 | 10,0 | 12,5 | 18,0 | 25,0 | 32,0 | 36,0 | 40,0 | — | | — | N/A |
| >2500 and ≤3200 | 20,0 | 25,0 | 36,0 | 50,0 | 64,0 | 72,0 | 80,0 | — | — | | N/A |
| >3200 and ≤4000 | 12,5 | 16,0 | 22,0 | 32,0 | 40,0 | 45,0 | 50,0 | | — | — | N/A |
| >3200 and ≤4000 | 12,5 | 16,0 | 22,0 | 32,0 | 40,0 | 45,0 | 50,0 | — | | — | N/A |
| >3200 and ≤4000 | 25,0 | 32,0 | 44,0 | 64,0 | 80,0 | 90,0 | 100,0 | — | — | | N/A |
| >4000 and ≤5000 | 16,0 | 20,0 | 28,0 | 40,0 | 50,0 | 56,0 | 63,0 | | — | — | N/A |
| >4000 and ≤5000 | 16,0 | 20,0 | 28,0 | 40,0 | 50,0 | 56,0 | 63,0 | — | | — | N/A |
| >4000 and ≤5000 | 32,0 | 40,0 | 56,0 | 80,0 | 100,0 | 112,0 | 126,0 | — | — | | N/A |
| >5000 and ≤6300 | 20,0 | 25,0 | 36,0 | 50,0 | 63,0 | 71,0 | 80,0 | | — | — | N/A |
| >5000 and ≤6300 | 20,0 | 25,0 | 36,0 | 50,0 | 63,0 | 71,0 | 80,0 | — | | — | N/A |
| >5000 and ≤6300 | 40,0 | 50,0 | 72,0 | 100,0 | 126,0 | 142,0 | 160,0 | — | — | | N/A |
| >6300 and ≤8000 | 25,0 | 32,0 | 45,0 | 63,0 | 80,0 | 90,0 | 100,0 | | — | — | N/A |
| >6300 and ≤8000 | 25,0 | 32,0 | 45,0 | 63,0 | 80,0 | 90,0 | 100,0 | — | | — | N/A |
| >6300 and ≤8000 | 50,0 | 64,0 | 90,0 | 126,0 | 160,0 | 180,0 | 200,0 | — | — | | N/A |
| >8000 and ≤10000 | 32,0 | 40,0 | 56,0 | 80,0 | 100,0 | 110,0 | 125,0 | | — | — | N/A |
| >8000 and ≤10000 | 32,0 | 40,0 | 56,0 | 80,0 | 100,0 | 110,0 | 125,0 | — | | — | N/A |
| >8000 and ≤10000 | 64,0 | 80,0 | 112,0 | 160,0 | 200,0 | 220,0 | 250,0 | — | — | | N/A |
| >10000 and ≤12500 | 40,0 | 50,0 | 71,0 | 100,0 | 125,0 | 140,0 | 160,0 | | — | — | N/A |
| >10000 and ≤12500 | 40,0 | 50,0 | 71,0 | 100,0 | 125,0 | 140,0 | 160,0 | — | | — | N/A |
| >10000 and ≤12500 | 80,0 | 100,0 | 142,0 | 200,0 | 250,0 | 280,0 | 320,0 | — | — | | N/A |

| 29.2 | TABLE: Creepage distances, basic, supplementary and reinforced insulation | | | | | | | | | | P |
|---|---|----|-----------|----------------|----|------------|-----|--------------------|-----|--|---------|
| Working voltage (V) | Creepage distance (mm) Pollution degree | | | | | | | | | | |
| | 1 | 2 | | | 3 | | | Type of insulation | | | Verdict |
| | Material group | | | Material group | | | | | | | |
| | I | II | IIIa/IIIb | I | II | IIIa/IIIb* | B** | S** | R** | | |
| <p>Supplementary information:</p> <p>*) Material group IIIb is allowed if the working voltage does not exceed 50 V</p> <p>**) B = Basic insulation, S = Supplementary insulation, R = Reinforced insulation</p> <ol style="list-style-type: none"> The creepage distance for basic insulation between winding and metal enclosure of fan motor is 4,0mm The creepage distance for supplementary insulation between high voltage circuit and low voltage circuit is 4,6mm. The creepage distance for reinforce insulation between inner live part and accessible surface is 8,0 mm. | | | | | | | | | | | |

| 29.2 | TABLE: Creepage distances, functional insulation | | | | | | | P |
|---------------------|--|----------------|------|-----------|----------------|-------|-------------------|------------------|
| Working voltage (V) | Creepage distance (mm) Pollution degree | | | | | | | Verdict / Remark |
| | 1 | 2 | | | 3 | | | |
| | | Material group | | | Material group | | | |
| | | I | II | IIIa/IIIb | I | II | IIIa/IIIb* | |
| ≤10 | 0,08 | 0,4 | 0,4 | 0,4 | 1,0 | 1,0 | 1,0 | N/A |
| 50 | 0,16 | 0,56 | 0,8 | 1,1 | 1,4 | 1,6 | 1,8 | N/A |
| 125 | 0,25 | 0,71 | 1,0 | 1,4 | 1,8 | 2,0 | 2,2 | N/A |
| 250 | 0,42 | 1,0 | 1,4 | 2,0 | 2,5 | 2,8 | <u>3,2</u> | P |
| 400 | 0,75 | 1,6 | 2,2 | 3,2 | 4,0 | 4,5 | 5,0 | N/A |
| 500 | 1,0 | 2,0 | 2,8 | 4,0 | 5,0 | 5,6 | 6,3 | N/A |
| >630 and ≤800 | 1,8 | 3,2 | 4,5 | 6,3 | 8,0 | 9,0 | 10,0 | N/A |
| >800 and ≤1000 | 2,4 | 4,0 | 5,6 | 8,0 | 10,0 | 11,0 | 12,5 | N/A |
| >1000 and ≤1250 | 3,2 | 5,0 | 7,1 | 10,0 | 12,5 | 14,0 | 16,0 | N/A |
| >1250 and ≤1600 | 4,2 | 6,3 | 9,0 | 12,5 | 16,0 | 18,0 | 20,0 | N/A |
| >1600 and ≤2000 | 5,6 | 8,0 | 11,0 | 16,0 | 20,0 | 22,0 | 25,0 | N/A |
| >2000 and ≤2500 | 7,5 | 10,0 | 14,0 | 20,0 | 25,0 | 28,0 | 32,0 | N/A |
| >2500 and ≤3200 | 10,0 | 12,5 | 18,0 | 25,0 | 32,0 | 36,0 | 40,0 | N/A |
| >3200 and ≤4000 | 12,5 | 16,0 | 22,0 | 32,0 | 40,0 | 45,0 | 50,0 | N/A |
| >4000 and ≤5000 | 16,0 | 20,0 | 28,0 | 40,0 | 50,0 | 56,0 | 63,0 | N/A |
| >5000 and ≤6300 | 20,0 | 25,0 | 36,0 | 50,0 | 63,0 | 71,0 | 80,0 | N/A |
| >6300 and ≤8000 | 25,0 | 32,0 | 45,0 | 63,0 | 80,0 | 90,0 | 100,0 | N/A |
| >8000 and ≤10000 | 32,0 | 40,0 | 56,0 | 80,0 | 100,0 | 110,0 | 125,0 | N/A |
| >10000 and ≤12500 | 40,0 | 50,0 | 71,0 | 100,0 | 125,0 | 140,0 | 160,0 | N/A |

Supplementary information:

*) Material group IIIb is allowed if the working voltage does not exceed 50 V

1. The creepage distance for function insulation on PCB is 3,6 mm.

| 30 | | | | | | | | | | | | | | | | | | | | TABLE: Resistance to heat and fire | | | | | | | | | | | | | | | | | | | |
|-------------------------|----------------------------|----------------|--------------------------|--------|---------------|---------------|-------------------------------|-----|---|-----|----|-----|---|-----|-----|-----|---|-----|-----------------------------------|------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Object/ part No. | Manufacturer/ trademark | Type/ model | Ball pressure test °C | | | | Glow wire test (GWT) °C | | | | | | Glow-wire flammability index (GWFI) °C | | | | Glow- wire ignition temp. (GWIT) °C | | Needle- flame test (NFT) | Verdict | | | | | | | | | | | | | | | | | | | |
| | | | 75 | 125 | cl. 11 +40 | cl. 19 +25 | 550 | 650 | | 750 | | 850 | 550 | 650 | 750 | 850 | 675 | 775 | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | te | ti | te | ti | | | | | | | | | | | | | | | | | | | | | | | |
| Bobbin of transformer | - | - | - | 1,2 mm | - | - | - | - | - | 7) | 7) | P | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| Terminal block | - | - | - | 1,5 mm | - | - | - | - | - | 7) | 7) | P | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| Anchorage | - | - | 0,8 mm | - | - | - | P | - | - | - | - | - | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| Groove of internal wire | - | - | 1,1 mm | - | - | - | P | - | - | - | - | - | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| Relay enclosure | - | - | - | 1,0 mm | - | - | - | - | - | 7) | 7) | P | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| Bobbin of fan motor | - | - | - | 1,2 mm | - | - | - | - | - | 7) | 7) | P | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| X2 capacitor | - | - | - | 0,9 mm | - | - | - | - | - | 7) | 7) | P | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| Varistor | - | - | - | 0,8 mm | - | - | - | - | - | 7) | 7) | P | - | - | - | - | - | - | - | P | | | | | | | | | | | | | | | | | | | |
| PCB | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | P | P | | | | | | | | | | | | | | | | | | | |

Supplementary information:

- 1) Parts of material classified at least HB40 or if relevant HBF
- 2) Parts of material classified as V-0 or V-1
- 3) Flame persisting longer than 2 s ($= t_e - t_i$) need only be reported for unattended appliances
- 4) Surrounding parts subjected to the needle-flame test of annex E
- 5) Base material classified as V-0 or if relevant VTM-0
- 6) The GWIT pre-selection option, the 850 °C GWFI pre-selection option, and the 850 °C GWT are not applicable for attended appliances
flame
- 7) No

| Appendix EMF | | TEST: Evaluation of the magnetic fields | | P |
|--|---|--|----------------------------|----------|
| Applied standards: | IEC 62233:2005, EN 62233:2008 (incl. Corr.1:2008) | | | - |
| Method | Used method: 5.5.2 Time domain evaluation | | | — |
| Applied Limit | ICNIRP Guidelines | | | — |
| Identification of the appliance | Type of apparatus | All models | | |
| | Rated Voltage | 220-240V~ | | |
| | Rated Frequency | 50Hz | | |
| Parameters required prior to the test | Laboratory Ambient Temperature | 25 °C ± 10 °C | | |
| | Supply Voltage | (Rated Voltage ± 2 %) V | | |
| | Supply Frequency | (Rated Frequency ± 2 %) Hz | | |
| Parameters recorded during the test | Laboratory Ambient Temperature | 23 °C | | |
| | Supply Voltage | 230V~ | | |
| | Supply Frequency | 50 Hz | | |
| Operating Mode | Cooling and heating | | | |
| Method 5.5.2 | | | | |
| Measuring Positions | Measuring Distance | Coupling Factor | Measurement Uncertainty | |
| Around of appliance | 30 cm | 0,18 | N/A, see information | |
| Frequency (kHz) | Limit (%) | | Measured Maximum Value (%) | |
| 0,01 to 400 | 100 | | 1,32% | |
| Supplementary information: | | | | |
| The measured maximum value in this table may be weighted with the coupling factor if applicable, and the measurement uncertainty is applied if the measured result is more than 75 % of the limit. | | | | |



Attachment No.1

EN 60335-1:2012/A11:2014

**Household and similar electrical appliances - Safety
Part 1: General requirements**

Attachment contains

| | |
|---------------|----------------|
| Cover page: | 1 page |
| Requirements: | 1 page |
| Total: | 2 pages |

Explanation for Abbreviations:

Possible Verdicts: **P** = Pass, **F**= Fail, **N/A** = Not Applicable

Remarks:

Throughout this report, a comma is used as the decimal separator.



| Clause | Requirement – Test | Result – Remark | Verdict |
|---------------------------------|--|--|---------|
| EN 60335-1:2012/A11:2014 | | | |
| Clause | Requirement –Test | Result - Remark | Verdict |
| 7.14 | In NOTE Z1, replace "IEC 82079-1" by "EN 82079-1". | | P |
| Annex ZF | In Table ZF.1 – List of standards under CLC/TC 61, replace line of EN 60335-2-38 by the following: | | N/A |
| | EN 60335-2-38, Commercial electric griddles and griddle grills | <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> With moving parts | |



Attachment No.2

EN 60335-1:2012/A13:2017

**Household and similar electrical appliances - Safety
Part 1: General requirements**

Attachment contains

| | |
|---------------|----------------|
| Cover page: | 1 page |
| Requirements: | 1 page |
| Total: | 2 pages |

Explanation for Abbreviations:

Possible Verdicts: **P** = Pass, **F**= Fail, **N/A** = Not Applicable

Remarks:

Throughout this report, a comma is used as the decimal separator.

| EN 60335-1:2012/A13:2017 | | |
|---------------------------------|--|----|
| ZC | Annex ZC(normative) Normative references to international publications with their corresponding European publications | -- |
| | The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies. | P |
| | | |
| ZZA | ANNEX ZZA (INFORMATIVE) Relationship between this European standard and the safety objectives of Directive 2014/35/EU [2014 OJ L96] aimed to be covered | -- |
| | Compliance with this Part 1 when used together with the relevant Part 2 provides one means of conformity with the safety objectives. | P |
| | | |
| ZZB | Annex ZZB (informative) Relationship between this European standard and the essential requirements of Directive 2006/42/EC aimed to be covered | -- |
| | Compliance with this Part 1 when used together with the relevant Part 2 provides one means of conformity with the relevant essential health and safety requirements. | P |



| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--------------------|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |

| ATTACHMENT TO TEST REPORT IEC 60335-2-40 EUROPEAN GROUP DIFFERENCES AND NATIONAL DIFFERENCES Part-2-40: Particular requirements for electrical heat pumps, air conditioners and dehumidifiers | |
|---|---|
| Differences according to : | EN 60335-2-40:2003 (incl. Corr.:2006) + A11:2004 + A12:2005 + A1:2006 + A2:2009 + A13:2012 (incl. Corr.:2013) EN 60335-1:2012 (incl. Corr.:2014) |
| Attachment Form No. : | EU_GD_IEC60335_2_40J |
| Attachment Originator : | VDE |
| Master Attachment : | 2014-06 |
| Copyright © 2014 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved. | |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--------------------|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |

| CENELEC COMMON MODIFICATIONS | | | |
|-------------------------------------|---|----------|-----|
| 6.1 | Delete "class 0" and "class 01" | | N/A |
| 7.1 | Single-phase appliances to be connected to the supply mains: 230 V covered | 220-240V | P |
| | Multi-phase appliances to be connected to the supply mains: 400 V covered | | N/A |
| 7.10 | Devices used to start/stop operational functions of the appliance distinguished from other manual devices by means of shape, size, surface texture, position, etc. | | P |
| | An indication that the device has been operated is given by: | | - |
| | - a tactile feedback, or | | P |
| | - an audible and visual feedback | | P |
| 7.12 | The instructions include the substance of the following: | | - |
| | - this appliance can be used by children aged from 8 years and above and persons with reduced physical, sensory or mental capabilities or lack of experience and knowledge if they have been given supervision or instruction concerning use of the appliance in a safe way and understand the hazards involved | | P |
| | - children shall not play with the appliance | | P |
| | - cleaning and user maintenance shall not be made by children without supervision | | P |
| 7.12.1 | Installation instructions for appliances intended to be permanently connected to fixed wiring, and have leakage current exceed 10 mA, state that installation of residual current device (RCD) having rated residual operating current not exceeding 30 mA is advisable (EN 60335-2-40) | | P |
| | For appliances not accessible to the general public and which are intended to be permanently connected to fixed wiring and which may have leakage currents exceeding 10 mA, the installation instructions shall specify the rating of the residual current device (RCD) to be installed (EN 60335-2-40/A12) | | N/A |
| 7.12.Z1 | The specific instructions related to the safe operation of this appliance is collated together in the front section of the user instructions | | P |
| | The height of the characters, measured on the capital letters, is at least 3 mm | | P |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|----------------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | These instructions are also available in an alternative format, e.g. on a website | | P |
| 8.1.1 | Also test probe 18 of EN 61032 is applied | | P |
| | The appliance being in every possible position, except that appliances normally used on the floor and having a mass exceeding 40 kg are not tilted. (EN 60335-1:2012/AC:2014) | | P |
| | The force on the probe in the straight position is increased to 10 N when probe 18 is used | | P |
| | When using test probe 18 the appliance is fully assembled as in normal use without any parts removed, and | | P |
| | parts intended to be removed for user maintenance are also not removed | | P |
| 8.2 | Compliance is checked by applying the test probes of EN 61032 | | P |
| | For built-in appliances and fixed appliances, the test probe B and probe 18 of EN 61032 are applied only after installation | | P |
| 11.8 | Footnotes to "External enclosure of motor-operated appliances" to be taken into account | | P |
| 13.2 | Leakage current measurements (EN 60335-2-40) | (See appended table) | P |
| 15.1.2 | Appliances with an automatic cord reel tested with the cord in the most unfavourable position so that the reeling of the wet cord may affect electrical insulation during operation, the cord not being dried before reeling | | N/A |
| 15.2 | Drain pan filled to brim and subjected to continuous overflow and fan(s) switched on (EN 60335-2-40) | | N/A |
| 16.2 | Leakage current measurements (EN 60335-2-40) | (See appended table) | P |
| 20.2 | When using the test probe similar to test probe B with a circular stop face, the accessories and detachable covers are removed | | P |
| | Test probe 18 applied with a force of 2,5 N on the appliance fully assembled | | P |
| 24.1 | Components comply with the safety requirements specified in the relevant standards as far as they reasonably apply | | P |
| | The requirements of clause 29 of this standard apply between live parts of components and accessible parts of the appliance. | | P |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | The requirements of 30.2 of this standard apply to parts of non-metallic material in components including parts of non-metallic material supporting current-carrying connections inside components | | P |
| | Components that have not been previously tested or do not comply with the standard for the relevant component are tested according to the requirements of 30.2 | | N/A |
| | Components that have been previously tested and shown to comply with the resistance to fire requirements in the standard for the relevant component need not be retested provided that: | | - |
| | - the severity specified in the component standard is not less than the severity specified in 30.2, and | | P |
| | - the test report for the component states whether it complied with the standard for the relevant component with or without flame, flames not exceeding 2 s during the test are ignored | | P |
| | Unless components have been previously tested and found to comply with the relevant standard for the number of cycles specified, they are tested in accordance with 24.1.1 to 24.1.9 | | N/A |
| | For components mentioned in 24.1.1 to 24.1.9, no additional tests specified in the relevant standard for the component are necessary other than those specified in 24.1.1 to 24.1.9 | | N/A |
| | Components that have not been separately tested and found to comply with the relevant standard, and | | P |
| | components that are not marked or not used in accordance with their marking, | | P |
| | are tested in accordance with the conditions occurring in the appliance, the number of samples being that required by the relevant standard | | P |
| | Lamp holders and starter holders that have not been previously tested and found to comply with the relevant standard are tested as a part of the appliance and additionally comply with the gauging and interchangeability requirements of the relevant standard under the conditions occurring in the appliance | | N/A |
| | Where the relevant standard specifies these gauging and interchangeability requirements at elevated temperatures, the temperatures measured during the tests of clause 11 are used | | N/A |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | Plugs and socket-outlets and other connecting devices of interconnection cords are not interchangeable with plugs and socket-outlets listed in IEC/TR 60083 or IEC 60906-1, or | | N/A |
| | with connectors and appliance inlets complying with the standard sheets of IEC 60320-1, | | N/A |
| | if direct supply to these parts from the supply mains gives rise to a hazard | | N/A |
| 24.1.7 | If the remote operation of the appliance is via a telecommunication network, the relevant standard for the telecommunication interface circuitry in the appliance is EN 41003 | | N/A |
| | Compliance with clause 8 of this standard is not impaired by connecting the appliance to a device covered by EN 41003 | | N/A |
| 24.Z1 | For motor running capacitors (IEC 60252-1 type P2) with a metallic enclosure having an overpressure fuse the flame testing of internal plastic parts supporting current carrying connections as required in 30.2.2 and 30.2.3.1 is not necessary | | N/A |
| 25.6 | Supply cords of single-phase portable appliances having a rated current not exceeding 16 A, fitted with a plug complying with the following standard sheets of IEC/TR 60083: | | - |
| | - for class I appliances: standard sheet C2b, C3b or C4.....: | | N/A |
| | - for class II appliances: standard sheet C5 or C6 | | N/A |
| 25.7 | Rubber sheathed cords (60245 IEC 53) are not suitable for appliances intended to be used outdoors or when they are liable to be exposed to significant amount of ultraviolet radiation | | N/A |
| | Halogen-free thermoplastic compound sheathed supply cords have properties at least those of: | | - |
| | - halogen-free thermoplastic compound sheathed cords (H03Z1Z1H2-F or H03Z1Z1-F), for appliances having a mass not exceeding 3 kg | | N/A |
| | - halogen-free thermoplastic compound sheathed cords (H05Z1Z1H2-F or H05Z1Z1-F), for other appliances | | N/A |
| | Cross-linked halogen-free compound sheathed supply cords have properties at least those of cross-linked halogen-free compound sheathed cords (H07ZZ-F) | | N/A |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 26.11 | Conductors connected by soldering are not considered to be positioned or fixed so that reliance is not placed upon the soldering alone to maintain them in position unless they are held in place near the terminals independently of the solder | | N/A |
| 29.3.Z1 | Appliance constructed so that if there is a possibility of damaging the insulation during installation, the insulation withstands the scratch and penetration test of 21.2 | | N/A |
| 32 | Compliance regarding electromagnetic fields is checked according to EN 62233 | | P |
| GG.2 | Requirements for charge limits in unventilated areas (EN 60335-2-40/A1) | | N/A |
| GG.Z1 | Non-fixed factory sealed single package units with a charge amount of $m_1 < M \leq 2 \times m_1$ (EN 60335-2-40/A1) | | N/A |
| Annex I, 19.I.101 | The appliance is supplied at rated voltage and operated under normal operation with each of the fault conditions specified | | N/A |
| | The duration of the test is as specified in 19.7 | | N/A |
| ZA | ANNEX ZA (NORMATIVE) SPECIAL NATIONAL CONDITIONS | | - |
| | | | |
| | Norway | | - |
| 19.5 | The test is also applicable to appliances intended to be permanently connected to fixed wiring | | N/A |
| | | | |
| | Norway | | - |
| 22.2 | The second paragraph of this subclause, dealing with single-phase, permanently connected class I appliances having heating elements, is not applicable due to the supply system | | N/A |
| | | | |
| | All CENELEC countries | | - |
| 25.6 and 25.25 | Information concerning National plug and socket-outlets is available from the CENELEC website. Normative national requirements concerning plug and socket-outlets are shown in the relevant National standard | | N/A |
| | | | |
| | Ireland and United Kingdom | | - |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|---|-------------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 25.8 | In the table, the lines for 10 A and 16 A are replaced by: | | - |
| | > 10 and ≤ 13 1,25 (1,0) ^b (EN 60335-1:2012/AC:2014) | | N/A |
| | > 13 and ≤ 16 1,5 (1,0) ^b (EN 60335-1:2012/AC:2014) | | N/A |
| | | | |
| ZB | ANNEX ZB (INFORMATIVE) A-DEVIATIONS | | - |
| | | | |
| | Ireland | | - |
| 25.6 | These regulations apply to all plugs for domestic use at a voltage of not less than 200 V and in general allow only plugs complying with I.S. 401:1997, or equivalent, to be fitted to domestic appliances | | N/A |
| | | | |
| | United Kingdom | | - |
| 25.6 | These regulations apply to all plugs for domestic use at a voltage of not less than 200 V and in general allow only plugs to BS 1363 to be fitted to domestic appliances. It also allows plugs to BS 4573 and EN 50075 to be fitted to shavers and toothbrushes | | N/A |
| | | | |
| ZC | ANNEX ZC (NORMATIVE) NORMATIVE REFERENCES TO INTERNATIONAL PUBLICATIONS WITH THEIR CORRESPONDING EUROPEAN PUBLICATIONS | | - |
| | A list of referenced documents in this standard | | N/A |
| | | | |
| ZD | ANNEX ZD (INFORMATIVE) IEC and CENELEC CODE DESIGNATIONS FOR FLEXIBLE CORDS | | - |
| | A table with IEC and CENELEC code designations for flexible cords | | N/A |
| | | | |
| ZE | ANNEX ZE (NORMATIVE) SPECIFIC ADDITIONAL REQUIREMENTS FOR APPLIANCES AND MACHINES INTENDED FOR COMMERCIAL USE | | - |
| 7.1 | Business name and full address of the manufacturer and, where applicable, his authorized representative.....: | See rating labels | P |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|-------------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | Model or type reference.....: | See rating labels | P |
| | Serial number, if any.....: | | N/A |
| | Production year | | P |
| | Designation of the appliance | | P |
| 7.12 | Instructions provided with the appliance so that the appliance can be used safely | | P |
| | The instructions contain at least the following information: | | - |
| | - the business name and full address of the manufacturer and, where applicable, his authorized representative | | P |
| | - model or type reference of the appliance as marked on the appliance itself, except for the serial number | | P |
| | - the designation of the appliance together with its explanation in case it is given by a combination of letters and/or numbers | | P |
| | - the general description of the appliance, when needed due to the complexity of the appliance | | P |
| | - specific precautions if required during installation, operation, adjusting, user maintenance, cleaning, repairing or moving | | P |
| | - when needed drawings, diagrams, descriptions and explanations necessary for the safe use and user maintenance of the appliance | | P |
| | - the possible reasonably foreseeable misuse and, whenever relevant, a warning against the effects it may have on the safe use of the appliance | | P |
| | The words "Original instructions" appear on the language version(s) verified by the manufacturer or by the authorized representative | | P |
| | When a translation of the original instructions has been provided by a person introducing the appliance on the market; the meaning of the sentence "Translation of the original instructions" appear in the relevant instructions delivered with the appliance | | N/A |
| | The instructions for maintenance/service to be done by specialized personnel, mandated by the manufacturer or the authorized representative may be supplied in only one Community language which the specialized personnel understand | | P |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|---|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | The instructions indicate the type and frequency of inspections and maintenance required for safe operation including the preventive maintenance measures | | P |
| | “This appliance is intended to be used by expert or trained users in shops, in light industry and on farms, or for commercial use by lay persons”. (EN 60335-2-40/A13) | | N/A |
| 7.12.ZE1 | If needed for specific appliances, the following information to be given: | | - |
| | - on use, transportation, assembly, dismantling when out of service, testing or foreseeable breakdowns, if these operations have consequences on stability of the appliance in order to avoid overturning, falling or uncontrolled movements of the appliance or of its component parts | | N/A |
| | - on how to maintain adequate mechanical stability when in use, during transportation, assembly, dismantling, scrapping and any other action involving the appliance | | N/A |
| | - on the protective measures to be taken by the user, including, where appropriate, the personal protective equipment to be provided | | N/A |
| | - on the operating method to be followed in the event of accident or breakdown; if a blockage is likely to occur the operating method to safely unblock the appliance | | N/A |
| | - on the specifications on the spare parts to be used, when these affect the health and safety of the operator | | N/A |
| | - on airborne noise emissions, determined and declared in accordance with the Annex ZAB, which includes: (EN 60335-2-40/A13) | | - |
| | - the A-weighted emission sound pressure level at workstations, where this exceeds 70 dB(A); (EN 60335-2-40/A13) | Less than 70dB | P |
| | - where this level does not exceed 70 dB(A), no value needs to be given, but the instructions shall state that the A-weighted sound pressure level is below 70 dB. (EN 60335-2-40/A13) | | P |
| | - the peak C-weighted instantaneous sound pressure value at workstations, where this exceeds 63 Pa (130 dB in relation to 20 μPa): | | N/A |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|---|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | - the A-weighted sound power level emitted by the machinery, where the A-weighted emission sound pressure level at workstations exceeds 80 dB(A) | | N/A |
| 7.12.ZE2 | The instructions includes a warning to disconnect the appliance from its power source during service and when replacing parts | | P |
| | If the removal of the plug is foreseen, it is clearly indicated that the removal of the plug has to be such that an operator can check from any of the points to which he has access that the plug remains removed | | N/A |
| | If this is not possible, due to the construction of the appliance or its installation, a disconnection with a locking system in the isolated position is provided | | N/A |
| 19.11.4.8 | The appliance continues to operate, without causing any hazard to the user, from the same point in its operating cycle at which the voltage fluctuation occurred, or | | P |
| | a manual operation is required to restart it | | N/A |
| 20.1 | Appliances and their components and fittings have adequate mechanical stability during transportation, assembly, dismantling and any other action involving the appliance | | P |
| 20.2 | Dangerous moving transmission parts safeguarded either by design or guards | | P |
| | When guards are used, they are fixed guards, interlocking movable guards or protective devices | | P |
| | Moving parts directly involved in the function of the appliance which cannot be made completely inaccessible fitted with: | | - |
| | - fixed guards or interlocking movable guards preventing access to those sections of the parts that are not used in the work, and | | P |
| | - adjustable guards restricting access to those sections of the moving parts where access is necessary | | P |
| | Interlocking movable guards used where frequent access is required | | N/A |
| 21.1 | Appliances and their components and fittings have adequate mechanical strength and is constructed to withstand such rough handling that may be expected in normal use, during transportation, assembly, dismantling, scrapping and any other action involving the appliance | | P |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|---|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 22.ZE.1 | For appliances provided with a seat, the seat gives adequate stability | | N/A |
| | The distance between the seat and the control devices capable of being adapted to the operator | | N/A |
| 22.ZE.2 | For appliances provided with separate devices for the start and the stop functions, the stop function is unambiguously identifiable and does always override the start function | | N/A |
| | For appliances provided with one device performing the start and the stop function, the stop function is unambiguously identifiable and does always override the start function | | N/A |
| 22.ZE.3 | Appliances designed in such a way that incorrect mounting is avoided, if this can lead to an unsafe situation | | N/A |
| | If this is not possible, information on the correct mounting is given directly on the part and/or the enclosure | | N/A |
| 22.ZE.4 | Where the weight, size or shape prevents appliances from being moved manually, they are fitted with attachments for lifting gear, or | | P |
| | so designed that they can be fitted with such attachments, or | | N/A |
| | be shaped in such a way that standard lifting gear can easily be used | | P |
| | Appliances to be moved manually are constructed or equipped so that they can be moved easily and safely | | N/A |
| 22.ZE.5 | The fixing systems of fixed guards which prevent access to dangerous moving transmission parts only removable with the use of tools | | P |
| | If such guards have to be removed by the user for routine cleaning or maintenance their fixing systems remain attached to the fixed guards or to the machine after removal | | N/A |
| | Where possible, guards are incapable of remaining in place without their fixings | | P |
| | This does not apply if, after removal of the screws, or if the component is incorrectly repositioned, the appliance becomes inoperative | | N/A |
| | Movable guards are interlocked | | N/A |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | The interlocking devices prevent the start of hazardous appliance functions until the guards are fixed in their position, and give a stop command whenever they are no longer closed | | N/A |
| | Where it is possible for an operator to reach the danger zone before the risk due to hazardous appliance functions has ceased, movable guards associated with a guard locking device in addition to an interlocking device that: | | - |
| | - prevents the start of hazardous appliance functions until the guard is closed and locked, and | | N/A |
| | - keeps the guard closed and locked until the risk of injury from the hazardous appliance functions has ceased | | N/A |
| | Interlocking movable guards remain attached to the appliance when open, and | | N/A |
| | they are designed and constructed in such a way that they can be adjusted only by means of an intentional action | | N/A |
| 22.ZE.6 | Interlocking movable guards designed in such a way that the absence or failure of one of their components prevents starting or stops the hazardous appliance functions | | N/A |
| | The guard is opened at the extent needed to cause the interlocking to operate and is then closed. This operation is carried out for 5 000 cycles at a rate of 5 cycles per min. (EN 60335-2-40/A13/AC) | | N/A |
| | After this test any defect that may be expected in normal use is applied to the interlock system, including interruption of the supply, only one defect being simulated at a time | | N/A |
| | After these tests the interlock system is fit for further use | | N/A |
| 22.ZE.7 | Adjustable guards restricting access to areas of the moving parts strictly necessary for the work are: | | - |
| | - adjustable manually or automatically, depending on the type of work involved, and | | N/A |
| | - readily adjustable without the use of tools | | N/A |
| 22.ZE.8 | In case of interruption, re-establishment after an interruption or fluctuation in whatever manner of the power supply, the appliance does not restart | | P |
| | However, automatic restarting of the operation is allowed if the appliance may continue to operate, without causing any hazard to the user, from the same point in its operating cycle at which the voltage interruption or fluctuation occurred | | N/A |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 22.ZE.9 | Appliances fitted with means to isolate them from all energy sources | | N/A |
| | Such isolators are clearly identified, and | | N/A |
| | they are capable of being locked if reconnection endanger persons | | N/A |
| | After the energy source is disconnected, it is possible to dissipate any energy remaining or stored in the circuits of the appliance without risk to persons | | N/A |
| | | | |
| ZF | ANNEX ZF (INFORMATIVE) CRITERIA APPLIED FOR THE ALLOCATION OF PRODUCTS COVERED BY STANDARDS IN THE EN 60335 SERIES UNDER LVD OR MD | | - |
| | List of standards under CENELEC/TC61 with the allocation under the LVD (Low Voltage Directive) or the MD (Machinery Directive) | LVD and MD | P |
| | | | |
| ZG | ANNEX ZG (NORMATIVE) UV APPLIANCES | | - |
| | The following modifications to this standard apply to appliances having UV emitters | | N/A |
| | This annex is not applicable to appliances covered by the scopes of IEC 60335-2-27, IEC 60335-2-59 or IEC 60335-2-109 | | N/A |
| 7.12.ZG | The instructions for appliances incorporating UVC emitters include the substance of the following: WARNING — This appliance contains a UV emitter. Do not stare at the light source | | N/A |
| 32 | For appliances incorporating UV emitters the manufacturer delivers a declaration providing evidence that the plastic material exposed to the radiation is UV resistant | | N/A |
| | | | |
| ZZ | ANNEX ZZ (INFORMATIVE) COVERAGE OF ESSENTIAL REQUIREMENTS OF EC DIRECTIVES | | - |
| | Description of the relation between this European standard and the LVD (Low Voltage Directive, 2006/95/EC) and the MD (Machinery Directive, 2006/42/EC) | LVD & MD | P |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|---|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| ZAA | ANNEX ZAA (INFORMATIVE) (EN 60335-2-40/A11) THE RELEVENCE OF THE PRESSURE EQUIPMENT DIRECTIVE | | -- |
| | Refrigerating systems having a pressure greater than 0,05 MPa are considered to be assemblies falling within the scope of the Pressure Equipment Directive, 97/23/EC. However, according to Article 1, item 3.6 of the directive, equipment classified no higher than category I and covered by the low voltage directive is excluded from its scope. (EN 60335-2-40/A11) | | P |
| | According to guideline 1/39 of the directive, this exclusion applies to both components and assemblies (refrigerant circuits). This applies to appliances containing vessels (e.g. compressors, receivers) or piping with limits in accordance with the following (EN 60335-2-40/A11): | | P |
| | Vessels (EN 60335-2-40/A11) | | - |
| | - dangerous refrigerants (Annex II, Table 1) (EN 60335-2-40/A11): | | - |
| | - volume not exceeding 1 l, or (EN 60335-2-40/A11) | | N/A |
| | - pressure x volume not exceeding 5 MPa l (EN 60335-2-40/A11) | | N/A |
| | - non-dangerous refrigerants (Annex II, Table 2) (EN 60335-2-40/A11): | | - |
| | - volume not exceeding 1 l, or (EN 60335-2-40/A11) | | N/A |
| | - pressure x volume not exceeding 20 MPa l (EN 60335-2-40/A11) | | P |
| | Piping (EN 60335-2-40/A11) | | - |
| | - dangerous refrigerants (Annex II, Table 6) (EN 60335-2-40/A11): | | - |
| | - numerical designation not exceeding 25, or (EN 60335-2-40/A11) | | N/A |
| | - pressure not exceeding 1 MPa and numerical designation not exceeding 100, or (EN 60335-2-40/A11) | | N/A |
| | - pressure exceeding 1 MPa and pressure x numerical designation not exceeding 100 MPa (EN 60335-2-40/A11). | | N/A |
| | - non-dangerous refrigerants (Annex II, Table 7) (EN 60335-2-40/A11): | | - |
| | - numerical designation not exceeding 100, or (EN 60335-2-40/A11) | | P |
| | - pressure x numerical designation not exceeding 350 MPa (EN 60335-2-40/A11). | | P |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|---|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | For other components, the most onerous limit of the two applies (EN 60335-2-40/A11) | | N/A |
| | The volume is the internal volume of the vessel and includes the volume of pipework up to the first connection. It excludes the volume of fixed internal parts (EN 60335-2-40/A11) | | N/A |
| | The pressure is the maximum pressure the vessel or piping system is exposed to, as specified by the manufacturer of the appliance (EN 60335-2-40/A11) | | N/A |
| | The numerical designation designates the size common to all components in the piping system (EN 60335-2-40/A11) | | P |
| | If any component exceeds the limits given above, the appliance has to comply with the directive. The technical requirements are given in Annex I and the conformity assessment tables and procedures in Annexes II and III of the directive (EN 60335-2-40/A11) | | N/A |
| | Commonly used dangerous refrigerants, identified as Group 1 in the directive, are listed in table ZAA.1 (EN 60335-2-40/A11) | | P |
| | Commonly used non-dangerous refrigerants, identified as Group 2 in the directive, are listed in table ZAA.2 (EN 60335-2-40/A11) | | N/A |
| ZAB | ANNEX ZAA (NORMATIVE) (EN 60335-2-40/A13) EMISSION OF ACOUSTICAL NOISE FROM APPLIANCES COVERED BY ANNEX ZE | | - |
| ZAB.1 | Noise reduction is an integral part of the design process and achieved by particularly applying measures at source to control noise, see for example EN ISO 11688-1. (EN 60335-2-40/A13) | | N/A |
| | Success of the applied noise reduction measures is assessed on the basis of the actual noise emission values in relation to other machines of the same type with comparable non-acoustical technical data. (EN 60335-2-40/A13) | | N/A |
| ZAB.2.1 | A-weighted emission sound pressure level determined in accordance with EN 11203:2009, 6.2.3 d) with the surface S being the measurement surface used for the sound power level determination. (EN 60335-2-40/A13) | | N/A |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|--|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | If the sound power level determination is based on a measurement method requiring a reverberant sound field, the surface S to define Q, shall be a parallelepiped measurement surface at a distance of 1 m from the reference box enclosing the source and assuming only one reflecting surface. (EN 60335-2-40/A13) | | N/A |
| ZAB.2.2 | A-weighted sound power level determined in accordance with EN 12102 applying a measurement method of at least grade 2. (EN 60335-2-40/A13) | | N/A |
| | If a grade 3 measurement method used for determining the A-weighted sound power level, the reasons are explicitly mentioned (EN 60335-2-40/A13) | | N/A |
| ZAB.2.3 | Total measurement uncertainty is depending on the standard deviation of reproducibility σ_{R0} of the measurement method and the standard deviation σ_{omc} representing the instability of the operating and mounting conditions. (EN 60335-2-40/A13) | | N/A |
| | σ_{R0} has an upper value for a grade 2 measurement method of about 1,5 dB, whereas σ_{omc} may have values between 0,5 dB for small variations of the sound power due on the mounting and operating conditions or 4 dB for very instable sources (EN 60335-2-40/A13) | | N/A |
| | Total measurement uncertainty for the A-weighted emission sound pressure level is of the same order as the one for the respective sound power level measurement. (EN 60335-2-40/A13) | | N/A |
| ZAB.2.4 | Information to be recorded covers all the technical requirements of this noise test code. (EN 60335-2-40/A13) | | N/A |
| | Any deviations from this noise test code or from the basic standards upon which it is based are to be recorded together with the technical justification for such deviations. (EN 60335-2-40/A13) | | N/A |
| ZAB.2.5 | Information to be given in the test report includes.: (EN 60335-2-40/A13) | | N/A |
| | - he data required by the manufacturer for inclusion in the noise declaration. (EN 60335-2-40/A13) | | N/A |
| | - the data required by the user to verify the declared values. (EN 60335-2-40/A13) | | N/A |
| | Thus the following information shall be included ...: (EN 60335-2-40/A13) | | N/A |

| IEC60335_2_40J - ATTACHMENT | | | |
|-----------------------------|---|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | - reference to the noise test code and the basic noise emission standards used; (EN 60335-2-40/A13) | | N/A |
| | - description of the installation and operation conditions used; (EN 60335-2-40/A13) | | N/A |
| | - location of the work station(s) and other specified positions; (EN 60335-2-40/A13) | | N/A |
| | - the noise emission values obtained (EN 60335-2-40/A13) | | N/A |
| | Test report states that all requirements of the noise test code have been fulfilled, or, if this is not the case, it shall identify any unfulfilled requirements. (EN 60335-2-40/A13) | | N/A |
| | Deviations from the requirements stated and a technical justification for these deviations shall be given. (EN 60335-2-40/A13) | | N/A |
| ZAB.2.6 | Noise emission declaration is made according to EN ISO 4871 (EN 60335-2-40/A13) | | N/A |
| | Emission sound pressure level L_{pA} is made as a dual number noise emission declaration, thus declaring the determined value for L_{pA} and the respective uncertainty K_{pA} . (EN 60335-2-40/A13) | | N/A |
| | Sound power level L_{WA} is declared as single number noise emission declaration declaring the sum of the measured sound power level and its uncertainty K_{WA} . (EN 60335-2-40/A13) | | N/A |
| | Noise declaration states that the noise emission values have been obtained according to this noise test code. (EN 60335-2-40/A13) | | N/A |
| | Any deviations from this noise test code or from the basic standards upon which it is based are clearly indicated. (EN 60335-2-40/A13) | | N/A |
| | Additional noise emission values are given in the declaration. (EN 60335-2-40/A13) | | N/A |
| | If undertaken, verification of the noise emission values shall be conducted according to EN ISO 4871, using the same mounting and operating conditions as those used for the initial determination. (EN 60335-2-40/A13) | | N/A |



Attachment No.4

Model List

Attachment contains

| | |
|---------------|-----------------|
| Cover page: | 1 page |
| Requirements: | 16 pages |
| Total: | 17 pages |

Explanation for Abbreviations:

Possible Verdicts: **P** = Pass, **F**= Fail, **N/A** = Not Applicable

Remarks:

Throughout this report, a comma is used as the decimal separator.

Table 1: Indoor unit

| Series | Model | Rated Voltage (V) | Rated current (A) |
|--------|------------------|-------------------|--|
| A1 | MDV-D36DL/N1-C | 220-240 | 0,23 |
| A2 | MDV-D45DL/N1-C | 220-240 | 0,67 |
| A3 | MDV-D56DL/N1-C | 220-240 | 0,67 |
| A4 | MDV-D71DL/N1-C | 220-240 | 0,67 |
| A5 | MDV-D80DL/N1-C | 220-240 | 0,83 |
| A6 | MDV-D90DL/N1-C | 220-240 | 0,83 |
| A7 | MDV-D112DL/N1-C | 220-240 | 1,11 |
| A8 | MDV-D140DL/N1-C | 220-240 | 1,11 |
| A9 | MDVC-D36DL/N1-C | 220-240 | 0,23 |
| A10 | MDVC-D45DL/N1-C | 220-240 | 0,67 |
| A11 | MDVC-D56DL/N1-C | 220-240 | 0,67 |
| A12 | MDVC-D71DL/N1-C | 220-240 | 0,67 |
| A13 | MDVC-D80DL/N1-C | 220-240 | 0,83 |
| A14 | MDVC-D90DL/N1-C | 220-240 | 0,83 |
| A15 | MDVC-D112DL/N1-C | 220-240 | 1,11 |
| A16 | MDVC-D140DL/N1-C | 220-240 | 1,11 |
| A17 | MI-36DL/DHN1-C | 220-240 | 0,32 |
| A18 | MI-45DL/DHN1-C | 220-240 | 0,89 |
| A19 | MI-56DL/DHN1-C | 220-240 | 0,89 |
| A20 | MI-71DL/DHN1-C | 220-240 | 0,89 |
| A21 | MI-80DL/DHN1-C | 220-240 | 1,14 |
| A22 | MI-90DL/DHN1-C | 220-240 | 1,14 |
| A23 | MI-112DL/DHN1-C | 220-240 | 1,25 |
| A24 | MI-140DL/DHN1-C | 220-240 | 1,25 |
| B1 | MDV-D22G/DN1-S | 220-240 | Cooling: 0,14; Heating: 0,14+3,38(heater) |
| B2 | MDV-D28G/DN1-S | 220-240 | Cooling: 0,14; Heating: 0,14+3,38(heater) |
| B3 | MDV-D36G/DN1-S | 220-240 | Cooling: 0,14; Heating: 0,14+3,38(heater) |
| B4 | MDV-D45G/DN1-S | 220-240 | Cooling: 0,2; Heating: 0,2+4,05(heater) |
| B5 | MDV-D56G/DN1-S | 220-240 | Cooling: 0,2; Heating: 0,2+4,05(heater) |
| B6 | MDV-D22G/N1-S | 220-240 | 0,14 |
| B7 | MDV-D28G/N1-S | 220-240 | 0,14 |
| B8 | MDV-D36G/N1-S | 220-240 | 0,14 |
| B9 | MDV-D45G/N1-S | 220-240 | 0,2 |
| B10 | MDV-D56G/N1-S | 220-240 | 0,2 |
| B11 | MDVC-D22G/DN1-S | 220-240 | 0,14 |

| | | | |
|-----|--------------------|---------|------|
| B12 | MDVC-D28G/DN1-S | 220-240 | 0,14 |
| B13 | MDVC-D36G/DN1-S | 220-240 | 0,14 |
| B14 | MDVC-D45G/DN1-S | 220-240 | 0,2 |
| B15 | MDVC-D56G/DN1-S | 220-240 | 0,2 |
| B16 | MDVC-D22G/N1-S | 220-240 | 0,14 |
| B17 | MDVC-D28G/N1-S | 220-240 | 0,14 |
| B18 | MDVC-D36G/N1-S | 220-240 | 0,14 |
| B19 | MDVC-D45G/N1-S | 220-240 | 0,2 |
| B20 | MDVC-D56G/N1-S | 220-240 | 0,2 |
| B21 | MDV-D71G-R3/N1Y | 220-240 | 0,33 |
| B22 | MDV-D80G-R3/N1Y | 220-240 | 0,39 |
| B23 | MDV-D90G-R3/N1Y | 220-240 | 0,39 |
| B24 | MDVC-D71G-R3/N1Y | 220-240 | 0,33 |
| B25 | MDVC-D80G-R3/N1Y | 220-240 | 0,39 |
| B26 | MDVC-D90G-R3/N1Y | 220-240 | 0,39 |
| B27 | MDV-D15G/N1-S | 220-240 | 0,12 |
| B28 | MDV-D17G/N1-S | 220-240 | 0,12 |
| B29 | MDVC-D15G/N1-S | 220-240 | 0,12 |
| B30 | MDVC-D17G/N1-S | 220-240 | 0,12 |
| B31 | MDV-D15G/N1YB | 220-240 | 0,12 |
| B32 | MDV-D17G/N1YB | 220-240 | 0,12 |
| B33 | MDVC-D15G/N1YB | 220-240 | 0,12 |
| B34 | MDVC-D17G/N1YB | 220-240 | 0,12 |
| B35 | MDV-D22G/N1Y-11D5 | 220-240 | 0,13 |
| B36 | MDV-D28G/N1Y-11D5 | 220-240 | 0,15 |
| B37 | MDV-D36G/N1Y-11D5 | 220-240 | 0,18 |
| B38 | MDV-D45G/N1Y-11D5 | 220-240 | 0,21 |
| B39 | MDV-D56G/N1Y-11D5 | 220-240 | 0,30 |
| B40 | MDV-D71G/N1Y-11D5 | 220-240 | 0,35 |
| B41 | MDVC-D22G/N1Y-11D5 | 220-240 | 0,13 |
| B42 | MDVC-D28G/N1Y-11D5 | 220-240 | 0,15 |
| B43 | MDVC-D36G/N1Y-11D5 | 220-240 | 0,18 |
| B44 | MDVC-D45G/N1Y-11D5 | 220-240 | 0,21 |
| B45 | MDVC-D56G/N1Y-11D5 | 220-240 | 0,30 |
| B46 | MDVC-D71G/N1Y-11D5 | 220-240 | 0,35 |
| B47 | MI-15G/DHN1-S | 220-240 | 0,25 |
| B48 | MI-22G/DHN1-S | 220-240 | 0,28 |
| B49 | MI-28G/DHN1-S | 220-240 | 0,28 |
| B50 | MI-36G/DHN1-S | 220-240 | 0,31 |
| B51 | MI-45G/DHN1-S | 220-240 | 0,35 |
| B52 | MI-56G/DHN1-S | 220-240 | 0,41 |

| | | | |
|-----|------------------|---------|------|
| B53 | MI-71G/DHN1-R3 | 220-240 | 0,49 |
| B54 | MI-80G/DHN1- R3 | 220-240 | 0,68 |
| B55 | MI-90G/DHN1- R3 | 220-240 | 0,68 |
| B56 | MIC-15G/DHN1-S | 220-240 | 0,25 |
| B57 | MIC-22G/DHN1-S | 220-240 | 0,28 |
| B58 | MIC-28G/DHN1-S | 220-240 | 0,28 |
| B59 | MIC-36G/DHN1-S | 220-240 | 0,31 |
| B60 | MIC-45G/DHN1-S | 220-240 | 0,35 |
| B61 | MIC-56G/DHN1-S | 220-240 | 0,41 |
| B62 | MIC-71G/DHN1-R3 | 220-240 | 0,49 |
| B63 | MIC-80G/DHN1- R3 | 220-240 | 0,68 |
| B64 | MIC-90G/DHN1- R3 | 220-240 | 0,68 |
| C1 | MDV-D28Q1/N1-C | 220-240 | 0,23 |
| C2 | MDV-D36Q1/N1-C | 220-240 | 0,23 |
| C3 | MDV-D45Q1/N1-C | 220-240 | 0,37 |
| C4 | MDV-D56Q1/N1-C | 220-240 | 0,39 |
| C5 | MDV-D71Q1/N1-C | 220-240 | 0,41 |
| C6 | MDVC-D28Q1/N1-C | 220-240 | 0,23 |
| C7 | MDVC-D36Q1/N1-C | 220-240 | 0,23 |
| C8 | MDVC-D45Q1/N1-C | 220-240 | 0,37 |
| C9 | MDVC-D56Q1/N1-C | 220-240 | 0,39 |
| C10 | MDVC-D71Q1/N1-C | 220-240 | 0,41 |
| C11 | MDV-D18Q1/N1-D | 220-240 | 0,24 |
| C12 | MDV-D22Q1/N1-D | 220-240 | 0,24 |
| C13 | MDV-D28Q1/N1-D | 220-240 | 0,25 |
| C14 | MDV-D36Q1/N1-D | 220-240 | 0,25 |
| C15 | MDVC-D18Q1/N1-D | 220-240 | 0,24 |
| C16 | MDVC-D22Q1/N1-D | 220-240 | 0,24 |
| C17 | MDVC-D28Q1/N1-D | 220-240 | 0,25 |
| C18 | MDVC-D36Q1/N1-D | 220-240 | 0,25 |
| C19 | MDV-D45Q1/N1-D | 220-240 | 0,27 |
| C20 | MDV-D56Q1/N1-D | 220-240 | 0,32 |
| C21 | MDV-D71Q1/N1-D | 220-240 | 0,36 |
| D1 | MDV-D22Q2/N1 | 220-240 | 0,4 |
| D2 | MDV-D28Q2/N1 | 220-240 | 0,4 |
| D3 | MDV-D36Q2/N1 | 220-240 | 0,4 |
| D4 | MDV-D45Q2/N1 | 220-240 | 0,5 |
| D5 | MDV-D56Q2/N1 | 220-240 | 0,65 |
| D6 | MDV-D71Q2/N1 | 220-240 | 0,85 |
| D7 | MDVC-D22Q2/N1 | 220-240 | 0,4 |
| D8 | MDVC-D28Q2/N1 | 220-240 | 0,4 |

| | | | |
|-----|-------------------|---------|------|
| D9 | MDVC-D36Q2/N1 | 220-240 | 0,4 |
| D10 | MDVC-D45Q2/N1 | 220-240 | 0,5 |
| D11 | MDVC-D56Q2/N1 | 220-240 | 0,65 |
| D12 | MDVC-D71Q2/N1 | 220-240 | 0,85 |
| E1 | MDV-D22Q4/N1-A3 | 220-240 | 0,22 |
| E2 | MDV-D28Q4/N1-A3 | 220-240 | 0,22 |
| E3 | MDV-D36Q4/N1-A3 | 220-240 | 0,25 |
| E4 | MDV-D45Q4/N1-A3 | 220-240 | 0,25 |
| E5 | MDVC-D22Q4/N1-A3 | 220-240 | 0,22 |
| E6 | MDVC-D28Q4/N1-A3 | 220-240 | 0,22 |
| E7 | MDVC-D36Q4/N1-A3 | 220-240 | 0,25 |
| E8 | MDVC-D45Q4/N1-A3 | 220-240 | 0,25 |
| E9 | MDV-D15Q4/N1-A3 | 220-240 | 0,22 |
| E10 | MDV-D17Q4/N1-A3 | 220-240 | 0,22 |
| E11 | MDVC-D15Q4/N1-A3 | 220-240 | 0,22 |
| E12 | MDVC-D17Q4/N1-A3 | 220-240 | 0,22 |
| E13 | MI-15Q4/DHN1-A3 | 220-240 | 0,23 |
| E14 | MI-22Q4/DHN1-A3 | 220-240 | 0,26 |
| E15 | MI-28Q4/DHN1-A3 | 220-240 | 0,26 |
| E16 | MI-36Q4/DHN1-A3 | 220-240 | 0,28 |
| E17 | MI-45Q4/DHN1-A3 | 220-240 | 0,28 |
| F1 | MDV-D125T1/N1-FA | 220-240 | 2,4 |
| F2 | MDV-D140T1/N1-FA | 220-240 | 2,4 |
| F3 | MDV-D200T1/N1-FA | 220-240 | 5,3 |
| F4 | MDV-D250T1/N1-FA | 220-240 | 5,6 |
| F5 | MDV-D280T1/N1-FA | 220-240 | 5,6 |
| F6 | MDVC-D125T1/N1-FA | 220-240 | 2,4 |
| F7 | MDVC-D140T1/N1-FA | 220-240 | 2,4 |
| F8 | MDVC-D200T1/N1-FA | 220-240 | 5,3 |
| F9 | MDVC-D250T1/N1-FA | 220-240 | 5,6 |
| F10 | MDVC-D280T1/N1-FA | 220-240 | 5,6 |
| G1 | MDV-D22T2/N1-BA5 | 220-240 | 0,28 |
| G2 | MDV-D28T2/N1-BA5 | 220-240 | 0,28 |
| G3 | MDV-D36T2/N1-BA5 | 220-240 | 0,28 |
| G4 | MDV-D45T2/N1-BA5 | 220-240 | 0,5 |
| G5 | MDV-D56T2/N1-BA5 | 220-240 | 0,5 |
| G6 | MDV-D71T2/N1-BA5 | 220-240 | 0,7 |
| G7 | MDV-D80T2/N1-BA5 | 220-240 | 1 |
| G8 | MDV-D90T2/N1-BA5 | 220-240 | 1 |
| G9 | MDV-D112T2/N1-BA5 | 220-240 | 1,8 |
| G10 | MDV-D140T2/N1-BA5 | 220-240 | 1,55 |

| | | | |
|-----|---------------------|---------|------|
| G11 | MDVC-D22T2/N1-BA5 | 220-240 | 0,28 |
| G12 | MDVC-D28T2/N1-BA5 | 220-240 | 0,28 |
| G13 | MDVC-D36T2/N1-BA5 | 220-240 | 0,28 |
| G14 | MDVC-D45T2/N1-BA5 | 220-240 | 0,5 |
| G15 | MDVC-D56T2/N1-BA5 | 220-240 | 0,5 |
| G16 | MDVC-D71T2/N1-BA5 | 220-240 | 0,7 |
| G17 | MDVC-D80T2/N1-BA5 | 220-240 | 1,0 |
| G18 | MDVC-D90T2/N1-BA5 | 220-240 | 1,0 |
| G19 | MDVC-D112T2/N1-BA5 | 220-240 | 1,8 |
| G20 | MDVC-D140T2/N1-BA5 | 220-240 | 1,55 |
| G21 | MDV-D71T2/N1-CA5 | 220-240 | 0,7 |
| G22 | MDVC-D71T2/N1-CA5 | 220-240 | 0,7 |
| G23 | MDV-D15T2/N1-DA5 | 220-240 | 0,31 |
| G24 | MDV-D17T2/N1-DA5 | 220-240 | 0,31 |
| G25 | MDV-D22T2/N1-DA5 | 220-240 | 0,31 |
| G26 | MDV-D28T2/N1-DA5 | 220-240 | 0,31 |
| G27 | MDV-D36T2/N1-DA5 | 220-240 | 0,33 |
| G28 | MDVC-D15T2/N1-DA5 | 220-240 | 0,31 |
| G29 | MDVC-D17T2/N1-DA5 | 220-240 | 0,31 |
| G30 | MDVC-D22T2/N1-DA5 | 220-240 | 0,31 |
| G31 | MDVC-D28T2/N1-DA5 | 220-240 | 0,31 |
| G32 | MDVC-D36T2/N1-DA5 | 220-240 | 0,33 |
| G33 | MDV-D45T2/N1-DA5 | 220-240 | 0,36 |
| G34 | MDV-D56T2/N1-DA5 | 220-240 | 0,36 |
| G35 | MDV-D71T2/N1-DA5 | 220-240 | 0,47 |
| G36 | MDVC-D45T2/N1-DA5 | 220-240 | 0,36 |
| G37 | MDVC-D56T2/N1-DA5 | 220-240 | 0,36 |
| G38 | MDVC-D71T2/N1-DA5 | 220-240 | 0,47 |
| G39 | MI-15T2/DHN1-DA5 | 220-240 | 0,5 |
| G40 | MI-22T2/DHN1-DA5 | 220-240 | 0,5 |
| G41 | MI-28T2/DHN1-DA5 | 220-240 | 0,5 |
| G42 | MI-36T2/DHN1-DA5 | 220-240 | 0,5 |
| G43 | MI-45T2/DHN1-DA5 | 220-240 | 0,7 |
| G44 | MI-56T2/DHN1-DA5 | 220-240 | 0,7 |
| G45 | MI-71T2/DHN1-DA5 | 220-240 | 0,8 |
| G46 | MI-80T2/DHN1-BA5 | 220-240 | 1,1 |
| G47 | MI-90T2/DHN1-BA5 | 220-240 | 1,2 |
| G48 | MI-112T2/DHN1-BA5 | 220-240 | 2,1 |
| G49 | MI-140T2/DHN1-BA5 | 220-240 | 2,0 |
| G50 | MI-15T2/DHN1-DA5-AU | 220-240 | 0,5 |
| G51 | MI-18T2/DHN1-DA5-AU | 220-240 | 0,5 |

| | | | |
|-----|------------------|---------|------|
| G52 | MI-18T2/DHN1-DA5 | 220-240 | 0,5 |
| G53 | MI-22T2/DHN1-DA5 | 220-240 | 0,5 |
| H1 | MDV-D18T3/N1-B | 220-240 | 0,18 |
| H2 | MDV-D22T3/N1-B | 220-240 | 0,18 |
| H3 | MDV-D28T3/N1-B | 220-240 | 0,18 |
| H4 | MDV-D36T3/N1-B | 220-240 | 0,18 |
| H5 | MDV-D45T3/N1-B | 220-240 | 0,25 |
| H6 | MDV-D56T3/N1-B | 220-240 | 0,25 |
| H7 | MDVC-D18T3/N1-B | 220-240 | 0,18 |
| H8 | MDVC-D22T3/N1-B | 220-240 | 0,18 |
| H9 | MDVC-D28T3/N1-B | 220-240 | 0,18 |
| H10 | MDVC-D36T3/N1-B | 220-240 | 0,18 |
| H11 | MDVC-D45T3/N1-B | 220-240 | 0,25 |
| H12 | MDVC-D56T3/N1-B | 220-240 | 0,25 |
| H13 | MDV-D18T3/N1-C | 220-240 | 0,31 |
| H14 | MDV-D22T3/N1-C | 220-240 | 0,31 |
| H15 | MDV-D28T3/N1-C | 220-240 | 0,31 |
| H16 | MDV-D36T3/N1-C | 220-240 | 0,33 |
| H17 | MDV-D45T3/N1-C | 220-240 | 0,36 |
| H18 | MDV-D56T3/N1-C | 220-240 | 0,36 |
| H19 | MDV-D71T3/N1-C | 220-240 | 0,5 |
| H20 | MDVC-D18T3/N1-C | 220-240 | 0,31 |
| H21 | MDVC-D22T3/N1-C | 220-240 | 0,31 |
| H22 | MDVC-D28T3/N1-C | 220-240 | 0,31 |
| H23 | MDVC-D36T3/N1-C | 220-240 | 0,33 |
| H24 | MDVC-D45T3/N1-C | 220-240 | 0,36 |
| H25 | MDVC-D56T3/N1-C | 220-240 | 0,36 |
| H26 | MDVC-D71T3/N1-C | 220-240 | 0,5 |
| H27 | MI-18T3/DHN1-C | 220-240 | 0,5 |
| H28 | MI-22T3/DHN1-C | 220-240 | 0,5 |
| H29 | MI-28T3/DHN1-C | 220-240 | 0,5 |
| H30 | MI-36T3/DHN1-C | 220-240 | 0,5 |
| H31 | MI-45T3/DHN1-C | 220-240 | 0,8 |
| H32 | MI-56T3/DHN1-C | 220-240 | 0,8 |
| H33 | MI-71T3/DHN1-C | 220-240 | 0,8 |
| I1 | MDV-D22Z/DN1-B | 220-240 | 0,09 |
| I2 | MDV-D28Z/DN1-B | 220-240 | 0,11 |
| I3 | MDV-D36Z/DN1-B | 220-240 | 0,15 |
| I4 | MDV-D45Z/DN1-B | 220-240 | 0,2 |
| I5 | MDVC-D22Z/DN1-B | 220-240 | 0,09 |
| I6 | MDVC-D28Z/DN1-B | 220-240 | 0,11 |

| | | | |
|-----|------------------|---------|------|
| I7 | MDVC-D36Z/DN1-B | 220-240 | 0,15 |
| I8 | MDVC-D45Z/DN1-B | 220-240 | 0,2 |
| J1 | MDV-D22Z/N1-F1B | 220-240 | 0,18 |
| J2 | MDV-D22Z/N1-F2B | 220-240 | 0,18 |
| J3 | MDV-D22Z/N1-F3B | 220-240 | 0,18 |
| J4 | MDV-D28Z/N1-F1B | 220-240 | 0,21 |
| J5 | MDV-D28Z/N1-F2B | 220-240 | 0,21 |
| J6 | MDV-D28Z/N1-F3B | 220-240 | 0,21 |
| J7 | MDV-D36Z/N1-F1B | 220-240 | 0,22 |
| J8 | MDV-D36Z/N1-F2B | 220-240 | 0,22 |
| J9 | MDV-D36Z/N1-F3B | 220-240 | 0,22 |
| J10 | MDV-D45Z/N1-F1B | 220-240 | 0,22 |
| J11 | MDV-D45Z/N1-F2B | 220-240 | 0,22 |
| J12 | MDV-D45Z/N1-F3B | 220-240 | 0,22 |
| J13 | MDV-D56Z/N1-F1B | 220-240 | 0,4 |
| J14 | MDV-D56Z/N1-F2B | 220-240 | 0,4 |
| J15 | MDV-D56Z/N1-F3B | 220-240 | 0,4 |
| J16 | MDV-D71Z/N1-F1B | 220-240 | 0,59 |
| J17 | MDV-D71Z/N1-F2B | 220-240 | 0,59 |
| J18 | MDV-D71Z/N1-F3B | 220-240 | 0,59 |
| J19 | MDV-D80Z/N1-F1B | 220-240 | 0,59 |
| J20 | MDV-D80Z/N1-F2B | 220-240 | 0,59 |
| J21 | MDV-D80Z/N1-F3B | 220-240 | 0,59 |
| J22 | MDVC-D22Z/N1-F1B | 220-240 | 0,18 |
| J23 | MDVC-D22Z/N1-F2B | 220-240 | 0,18 |
| J24 | MDVC-D22Z/N1-F3B | 220-240 | 0,18 |
| J25 | MDVC-D28Z/N1-F1B | 220-240 | 0,21 |
| J26 | MDVC-D28Z/N1-F2B | 220-240 | 0,21 |
| J27 | MDVC-D28Z/N1-F3B | 220-240 | 0,21 |
| J28 | MDVC-D36Z/N1-F1B | 220-240 | 0,22 |
| J29 | MDVC-D36Z/N1-F2B | 220-240 | 0,22 |
| J30 | MDVC-D36Z/N1-F3B | 220-240 | 0,22 |
| J31 | MDVC-D45Z/N1-F1B | 220-240 | 0,22 |
| J32 | MDVC-D45Z/N1-F2B | 220-240 | 0,22 |
| J33 | MDVC-D45Z/N1-F3B | 220-240 | 0,22 |
| J34 | MDVC-D56Z/N1-F1B | 220-240 | 0,4 |
| J35 | MDVC-D56Z/N1-F2B | 220-240 | 0,4 |
| J36 | MDVC-D56Z/N1-F3B | 220-240 | 0,4 |
| J37 | MDVC-D71Z/N1-F1B | 220-240 | 0,59 |
| J38 | MDVC-D71Z/N1-F2B | 220-240 | 0,59 |
| J39 | MDVC-D71Z/N1-F3B | 220-240 | 0,59 |

| | | | |
|-----|------------------|---------|------|
| J40 | MDVC-D80Z/N1-F1B | 220-240 | 0,59 |
| J41 | MDVC-D80Z/N1-F2B | 220-240 | 0,59 |
| J42 | MDVC-D80Z/N1-F3B | 220-240 | 0,59 |
| K1 | MDV-D22Z/N1-F4 | 220-240 | 0,18 |
| K2 | MDV-D22Z/N1-F5 | 220-240 | 0,18 |
| K3 | MDV-D28Z/N1-F4 | 220-240 | 0,19 |
| K4 | MDV-D28Z/N1-F5 | 220-240 | 0,19 |
| K5 | MDV-D36Z/N1-F4 | 220-240 | 0,22 |
| K6 | MDV-D36Z/N1-F5 | 220-240 | 0,22 |
| K7 | MDV-D45Z/N1-F4 | 220-240 | 0,22 |
| K8 | MDV-D45Z/N1-F5 | 220-240 | 0,22 |
| K9 | MDV-D56Z/N1-F4 | 220-240 | 0,43 |
| K10 | MDV-D56Z/N1-F5 | 220-240 | 0,43 |
| K11 | MDV-D71Z/N1-F4 | 220-240 | 0,63 |
| K12 | MDV-D71Z/N1-F5 | 220-240 | 0,63 |
| K13 | MDV-D80Z/N1-F4 | 220-240 | 0,63 |
| K14 | MDV-D80Z/N1-F5 | 220-240 | 0,63 |
| K15 | MDVC-D22Z/N1-F4 | 220-240 | 0,18 |
| K16 | MDVC-D22Z/N1-F5 | 220-240 | 0,18 |
| K17 | MDVC-D28Z/N1-F4 | 220-240 | 0,19 |
| K18 | MDVC-D28Z/N1-F5 | 220-240 | 0,19 |
| K19 | MDVC-D36Z/N1-F4 | 220-240 | 0,22 |
| K20 | MDVC-D36Z/N1-F5 | 220-240 | 0,22 |
| K21 | MDVC-D45Z/N1-F4 | 220-240 | 0,22 |
| K22 | MDVC-D45Z/N1-F5 | 220-240 | 0,22 |
| K23 | MDVC-D56Z/N1-F4 | 220-240 | 0,43 |
| K24 | MDVC-D56Z/N1-F5 | 220-240 | 0,43 |
| K25 | MDVC-D71Z/N1-F4 | 220-240 | 0,63 |
| K26 | MDVC-D71Z/N1-F5 | 220-240 | 0,63 |
| K27 | MDVC-D80Z/N1-F4 | 220-240 | 0,63 |
| K28 | MDVC-D80Z/N1-F5 | 220-240 | 0,63 |
| K29 | MI-22Z/DHN1-F4 | 220-240 | 0,29 |
| K30 | MI-28Z/DHN1-F4 | 220-240 | 0,32 |
| K31 | MI-36Z/DHN1-F4 | 220-240 | 0,33 |
| K32 | MI-45Z/DHN1-F4 | 220-240 | 0,35 |
| K33 | MI-56Z/DHN1-F4 | 220-240 | 0,55 |
| K34 | MI-71Z/DHN1-F4 | 220-240 | 0,81 |
| K35 | MI-80Z/DHN1-F4 | 220-240 | 0,82 |
| K36 | MI-22Z/DHN1-F5 | 220-240 | 0,29 |
| K37 | MI-28Z/DHN1-F5 | 220-240 | 0,32 |
| K38 | MI-36Z/DHN1-F5 | 220-240 | 0,33 |

| | | | |
|-----|------------------|----------|------|
| K39 | MI-45Z/DHN1-F5 | 220-240 | 0,35 |
| K40 | MI-56Z/DHN1-F5 | 220-240 | 0,55 |
| K41 | MI-71Z/DHN1-F5 | 220-240 | 0,81 |
| K42 | MI-80Z/DHN1-F5 | 220-240 | 0,82 |
| K43 | MI-22Z/DHN1-F3B | 220-240 | 0,29 |
| K44 | MI-28Z/DHN1-F3B | 220-240 | 0,32 |
| K45 | MI-36Z/DHN1-F3B | 220-240 | 0,33 |
| K46 | MI-45Z/DHN1-F3B | 220-240 | 0,35 |
| K47 | MI-56Z/DHN1-F3B | 220-240 | 0,55 |
| K48 | MI-71Z/DHN1-F3B | 220-240 | 0,81 |
| K49 | MI-80Z/DHN1-F3B | 220-240 | 0,82 |
| L1 | MDV-D71T1/N1-B | 220-240 | 1,23 |
| L2 | MDV-D80T1/N1-B | 220-240 | 1,23 |
| L3 | MDV-D90T1/N1-B | 220-240 | 1,87 |
| L4 | MDV-D112T1/N1-B | 220-240 | 2,3 |
| L5 | MDV-D140T1/N1-B | 220-240 | 2,85 |
| L6 | MDV-D160T1/N1-B | 220-240 | 4,77 |
| L7 | MDV-D200T1/N1-B | 220-240 | 8,6 |
| L8 | MDV-D250T1/N1-B | 220-240 | 8,6 |
| L9 | MDV-D280T1/N1-B | 220-240 | 8,6 |
| L10 | MDVC-D71T1/N1-B | 220-240 | 1,23 |
| L11 | MDVC-D80T1/N1-B | 220-240 | 1,23 |
| L12 | MDVC-D90T1/N1-B | 220-240 | 1,87 |
| L13 | MDVC-D112T1/N1-B | 220-240 | 2,3 |
| L14 | MDVC-D140T1/N1-B | 220-240 | 2,85 |
| L15 | MDVC-D160T1/N1-B | 220-240 | 4,77 |
| L16 | MDVC-D200T1/N1-B | 220-240 | 8,6 |
| L17 | MDVC-D250T1/N1-B | 220-240 | 8,6 |
| L18 | MDVC-D280T1/N1-B | 220-240 | 8,6 |
| L19 | MDV-D400T1/N1 | 220-240V | 12,5 |
| L20 | MDV-D450T1/N1 | 220-240V | 12,5 |
| L21 | MDV-D560T1/N1 | 220-240V | 15,5 |
| L22 | MDVC-D400T1/N1 | 220-240V | 12,5 |
| L23 | MDVC-D450T1/N1 | 220-240V | 12,5 |
| L24 | MDVC-D560T1/N1 | 220-240V | 15,5 |
| M1 | MDV-D28Q4/N1-D | 220-240 | 0,41 |
| M2 | MDV-D36Q4/N1-D | 220-240 | 0,41 |
| M3 | MDV-D45Q4/N1-D | 220-240 | 0,41 |
| M4 | MDV-D56Q4/N1-D | 220-240 | 0,41 |
| M5 | MDV-D71Q4/N1-D | 220-240 | 0,52 |
| M6 | MDV-D80Q4/N1-D | 220-240 | 0,52 |

| | | | |
|-----|------------------|---------|------|
| M7 | MDV-D90Q4/N1-D | 220-240 | 0,73 |
| M8 | MDV-D100Q4/N1-D | 220-240 | 0,73 |
| M9 | MDV-D112Q4/N1-D | 220-240 | 0,73 |
| M10 | MDV-D140Q4/N1-D | 220-240 | 0,82 |
| M11 | MDVC-D28Q4/N1-D | 220-240 | 0,41 |
| M12 | MDVC-D36Q4/N1-D | 220-240 | 0,41 |
| M13 | MDVC-D45Q4/N1-D | 220-240 | 0,41 |
| M14 | MDVC-D56Q4/N1-D | 220-240 | 0,41 |
| M15 | MDVC-D71Q4/N1-D | 220-240 | 0,52 |
| M16 | MDVC-D80Q4/N1-D | 220-240 | 0,52 |
| M17 | MDVC-D90Q4/N1-D | 220-240 | 0,73 |
| M18 | MDVC-D100Q4/N1-D | 220-240 | 0,73 |
| M19 | MDVC-D112Q4/N1-D | 220-240 | 0,73 |
| M20 | MDVC-D140Q4/N1-D | 220-240 | 0,82 |
| M21 | MDV-D28Q4/N1-E | 220-240 | 0,31 |
| M22 | MDV-D36Q4/N1-E | 220-240 | 0,31 |
| M23 | MDV-D45Q4/N1-E | 220-240 | 0,41 |
| M24 | MDV-D56Q4/N1-E | 220-240 | 0,41 |
| M25 | MDV-D71Q4/N1-E | 220-240 | 0,41 |
| M26 | MDV-D80Q4/N1-E | 220-240 | 0,48 |
| M27 | MDV-D90Q4/N1-E | 220-240 | 0,67 |
| M28 | MDV-D100Q4/N1-E | 220-240 | 0,72 |
| M29 | MDV-D112Q4/N1-E | 220-240 | 0,72 |
| M30 | MDV-D140Q4/N1-E | 220-240 | 0,75 |
| M31 | MDVC-D28Q4/N1-E | 220-240 | 0,31 |
| M32 | MDVC-D36Q4/N1-E | 220-240 | 0,31 |
| M33 | MDVC-D45Q4/N1-E | 220-240 | 0,41 |
| M34 | MDVC-D56Q4/N1-E | 220-240 | 0,41 |
| M35 | MDVC-D71Q4/N1-E | 220-240 | 0,41 |
| M36 | MDVC-D80Q4/N1-E | 220-240 | 0,48 |
| M37 | MDVC-D90Q4/N1-E | 220-240 | 0,67 |
| M38 | MDVC-D100Q4/N1-E | 220-240 | 0,72 |
| M39 | MDVC-D112Q4/N1-E | 220-240 | 0,72 |
| M40 | MDVC-D140Q4/N1-E | 220-240 | 0,75 |
| M41 | MI-28Q4/DHN1-D | 220-240 | 0,32 |
| M42 | MI-36Q4/DHN1-D | 220-240 | 0,32 |
| M43 | MI-45Q4/DHN1-D | 220-240 | 0,34 |
| M44 | MI-56Q4/DHN1-D | 220-240 | 0,34 |
| M45 | MI-71Q4/DHN1-D | 220-240 | 0,36 |
| M46 | MI-80Q4/DHN1-D | 220-240 | 0,37 |
| M47 | MI-90Q4/DHN1-D | 220-240 | 0,82 |

| | | | |
|-----|------------------|---------|--|
| M48 | MI-100Q4/DHN1-D | 220-240 | 0,82 |
| M49 | MI-112Q4/DHN1-D | 220-240 | 0,82 |
| M50 | MI-140Q4/DHN1-D | 220-240 | 0,98 |
| M51 | MIC-28Q4/DHN1-D | 220-240 | 0,32 |
| M52 | MIC-36Q4/DHN1-D | 220-240 | 0,32 |
| M53 | MIC-45Q4/DHN1-D | 220-240 | 0,34 |
| M54 | MIC-56Q4/DHN1-D | 220-240 | 0,34 |
| M55 | MIC-71Q4/DHN1-D | 220-240 | 0,36 |
| M56 | MIC-80Q4/DHN1-D | 220-240 | 0,37 |
| M57 | MIC-90Q4/DHN1-D | 220-240 | 0,82 |
| M58 | MIC-100Q4/DHN1-D | 220-240 | 0,82 |
| M59 | MIC-112Q4/DHN1-D | 220-240 | 0,82 |
| M60 | MIC-140Q4/DHN1-D | 220-240 | 0,98 |
| N1 | MDV-D22G/DN1YB | 220-240 | Cooling: 0,14; Heating: 0,14+3,38(heater) |
| N2 | MDV-D28G/DN1YB | 220-240 | Cooling: 0,14; Heating: 0,14+3,38(heater) |
| N3 | MDV-D36G/DN1YB | 220-240 | Cooling: 0,14; Heating: 0,14+3,38(heater) |
| N4 | MDV-D45G/DN1YB | 220-240 | Cooling: 0,2; Heating: 0,2+4,05(heater) |
| N5 | MDV-D56G/DN1YB | 220-240 | Cooling: 0,2; Heating: 0,2+4,05(heater) |
| N6 | MDV-D22G/N1YB | 220-240 | 0,14 |
| N7 | MDV-D28G/N1YB | 220-240 | 0,14 |
| N8 | MDV-D36G/N1YB | 220-240 | 0,14 |
| N9 | MDV-D45G/N1YB | 220-240 | 0,2 |
| N10 | MDV-D56G/N1YB | 220-240 | 0,2 |
| N11 | MDVC-D22G/DN1YB | 220-240 | 0,14 |
| N12 | MDVC-D28G/DN1YB | 220-240 | 0,14 |
| N13 | MDVC-D36G/DN1YB | 220-240 | 0,14 |
| N14 | MDVC-D45G/DN1YB | 220-240 | 0,2 |
| N15 | MDVC-D56G/DN1YB | 220-240 | 0,2 |
| N16 | MDVC-D22G/N1YB | 220-240 | 0,14 |
| N17 | MDVC-D28G/N1YB | 220-240 | 0,14 |
| N18 | MDVC-D36G/N1YB | 220-240 | 0,14 |
| N19 | MDVC-D45G/N1YB | 220-240 | 0,2 |
| N20 | MDVC-D56G/N1YB | 220-240 | 0,2 |
| O1 | MDV-D160DL/N1-C | 220-240 | 1,41 |
| O2 | MDVC-D160DL/N1-C | 220-240 | 1,41 |
| P1 | MI-22G/N1-S | 220-240 | 0,14 |
| P2 | MI-28G/N1-S | 220-240 | 0,14 |
| P3 | MI-36G/N1-S | 220-240 | 0,14 |

| | | | |
|-----|------------------|---------|------|
| P4 | MI-45G/N1-S | 220-240 | 0,20 |
| P5 | MI-56G/N1-S | 220-240 | 0,20 |
| Q1 | MI-28Q4/N1-E | 220-240 | 0,38 |
| Q2 | MI-36Q4/N1-E | 220-240 | 0,38 |
| Q3 | MI-45Q4/N1-E | 220-240 | 0,48 |
| Q4 | MI-56Q4/N1-E | 220-240 | 0,48 |
| Q5 | MI-71Q4/N1-E | 220-240 | 0,48 |
| Q6 | MI-80Q4/N1-E | 220-240 | 0,59 |
| Q7 | MI-90Q4/N1-E | 220-240 | 0,98 |
| Q8 | MI-100Q4/N1-E | 220-240 | 0,99 |
| Q9 | MI-112Q4/N1-E | 220-240 | 0,99 |
| Q10 | MI-140Q4/N1-E | 220-240 | 1,01 |
| R1 | MI-22T2/N1-EA5 | 220-240 | 0,31 |
| R2 | MI-28T2/N1-EA5 | 220-240 | 0,31 |
| R3 | MI-36T2/N1-EA5 | 220-240 | 0,39 |
| R4 | MI-45T2/N1-EA5 | 220-240 | 0,46 |
| R5 | MI-56T2/N1-EA5 | 220-240 | 0,46 |
| R6 | MI-71T2/N1-EA5 | 220-240 | 0,47 |
| R7 | MI-80T2/N1-EA5 | 220-240 | 1,0 |
| R8 | MI-90T2/N1-EA5 | 220-240 | 1,0 |
| R9 | MI-112T2/N1-EA5 | 220-240 | 1,8 |
| R10 | MI-140T2/N1-EA5 | 220-240 | 1,55 |
| S1 | MI-22Q4/N1-A3 | 220-240 | 0,22 |
| S2 | MI-28Q4/N1-A3 | 220-240 | 0,22 |
| S3 | MI-36Q4/N1-A3 | 220-240 | 0,27 |
| S4 | MI-45Q4/N1-A3 | 220-240 | 0,27 |
| T1 | MI-71T1/DHN1-B | 220-240 | 1,7 |
| T2 | MI-80T1/DHN1-B | 220-240 | 1,7 |
| T3 | MI-90T1/DHN1-B | 220-240 | 2,4 |
| T4 | MI-112T1/DHN1-B | 220-240 | 3,6 |
| T5 | MI-140T1/DHN1-B | 220-240 | 4,5 |
| T6 | MI-160T1/DHN1-B | 220-240 | 4,5 |
| T7 | MI-200T1/DHN1-B | 220-240 | 7,5 |
| T8 | MI-250T1/DHN1-B | 220-240 | 7,5 |
| T9 | MI-280T1/DHN1-B | 220-240 | 7,5 |
| T10 | MI-125T1/DHN1-FA | 220-240 | 2,8 |
| T11 | MI-140T1/DHN1-FA | 220-240 | 2,8 |
| T12 | MI-200T1/DHN1-FA | 220-240 | 4,5 |

| | | | |
|-----|-------------------|---------|------|
| T13 | MI-250T1/DHN1-FA | 220-240 | 5 |
| T14 | MI-280T1/DHN1-FA | 220-240 | 5 |
| U1 | MI-22G/DHN1-M | 220-240 | 0,27 |
| U2 | MI-28G/DHN1-M | 220-240 | 0,31 |
| U3 | MI-36G/DHN1-M | 220-240 | 0,43 |
| U4 | MI-45G/DHN1-M | 220-240 | 0,44 |
| U5 | MI-56G/DHN1-M | 220-240 | 0,58 |
| U6 | MI-71G/DHN1-M | 220-240 | 0,6 |
| U7 | MI-80G/DHN1-M | 220-240 | 0,6 |
| U8 | MI-90G/DHN1-M | 220-240 | 0,78 |
| U9 | MIC-22G/DHN1-M | 220-240 | 0,27 |
| U10 | MIC-28G/DHN1-M | 220-240 | 0,31 |
| U11 | MIC-36G/DHN1-M | 220-240 | 0,43 |
| U12 | MIC-45G/DHN1-M | 220-240 | 0,44 |
| U13 | MIC-56G/DHN1-M | 220-240 | 0,58 |
| U14 | MIC-71G/DHN1-M | 220-240 | 0,6 |
| U15 | MIC-80G/DHN1-M | 220-240 | 0,6 |
| U16 | MIC-90G/DHN1-M | 220-240 | 0,78 |
| V1 | MI-22T2/DHN1-EA5 | 220-240 | 1,0 |
| V2 | MI-28T2/DHN1-EA5 | 220-240 | 1,0 |
| V3 | MI-36T2/DHN1-EA5 | 220-240 | 1,0 |
| V4 | MI-45T2/DHN1-EA5 | 220-240 | 2,5 |
| V5 | MI-56T2/DHN1-EA5 | 220-240 | 2,5 |
| V6 | MI-71T2/DHN1-EA5 | 220-240 | 2,5 |
| V7 | MI-90T2/DHN1-EA5 | 220-240 | 2,5 |
| V8 | MI-112T2/DHN1-EA5 | 220-240 | 3,0 |
| V9 | MI-140T2/DHN1-EA5 | 220-240 | 3,0 |
| X1 | MI2-22T2DN1 | 220-240 | 0,74 |
| X2 | MI2-28T2DN1 | 220-240 | 0,74 |
| X3 | MI2-36T2DN1 | 220-240 | 0,77 |
| X4 | MI2-45T2DN1 | 220-240 | 1,0 |
| X5 | MI2-56T2DN1 | 220-240 | 1,0 |
| X6 | MI2-71T2DN1 | 220-240 | 1,1 |

| | | | |
|------|--------------|---------|------|
| X7 | MI2-80T2DN1 | 220-240 | 1,3 |
| X8 | MI2-90T2DN1 | 220-240 | 1,3 |
| X9 | MI2-112T2DN1 | 220-240 | 1,5 |
| X10 | MI2-140T2DN1 | 220-240 | 2,6 |
| Y1 | MI2-18Q1DN1 | 220-240 | 0,38 |
| Y2 | MI2-22Q1DN1 | 220-240 | 0,38 |
| Y3 | MI2-28Q1DN1 | 220-240 | 0,39 |
| Y4 | MI2-36Q1DN1 | 220-240 | 0,39 |
| Y5 | MI2-45Q1DN1 | 220-240 | 0,53 |
| Y6 | MI2-56Q1DN1 | 220-240 | 0,57 |
| Y7 | MI2-71Q1DN1 | 220-240 | 0,59 |
| Z1 | MI2-22Q2DN1 | 220-240 | 0,47 |
| Z2 | MI2-28Q2DN1 | 220-240 | 0,47 |
| Z3 | MI2-36Q2DN1 | 220-240 | 0,52 |
| Z4 | MI2-45Q2DN1 | 220-240 | 0,59 |
| Z5 | MI2-56Q2DN1 | 220-240 | 0,9 |
| Z6 | MI2-71Q2DN1 | 220-240 | 1,3 |
| AA1 | MI2-28Q4DN1 | 220-240 | 0,41 |
| AA2 | MI2-36Q4DN1 | 220-240 | 0,41 |
| AA3 | MI2-45Q4DN1 | 220-240 | 0,56 |
| AA4 | MI2-56Q4DN1 | 220-240 | 0,56 |
| AA5 | MI2-71Q4DN1 | 220-240 | 0,56 |
| AA6 | MI2-80Q4DN1 | 220-240 | 0,76 |
| AA7 | MI2-90Q4DN1 | 220-240 | 0,88 |
| AA8 | MI2-100Q4DN1 | 220-240 | 1,0 |
| AA9 | MI2-112Q4DN1 | 220-240 | 1,0 |
| AA10 | MI2-140Q4DN1 | 220-240 | 1,2 |
| AB1 | MI2-22Q4CDN1 | 220-240 | 0,43 |
| AB2 | MI2-28Q4CDN1 | 220-240 | 0,43 |
| AB3 | MI2-36Q4CDN1 | 220-240 | 0,48 |
| AB4 | MI2-45Q4CDN1 | 220-240 | 0,48 |
| AC1 | MI2-36DLDN1 | 220-240 | 0,45 |
| AC2 | MI2-45DLDN1 | 220-240 | 1,2 |
| AC3 | MI2-56DLDN1 | 220-240 | 1,2 |

| | | | |
|------|--------------|---------|------|
| AC4 | MI2-71DLDN1 | 220-240 | 1,2 |
| AC5 | MI2-80DLDN1 | 220-240 | 1,3 |
| AC6 | MI2-90DLDN1 | 220-240 | 1,3 |
| AC7 | MI2-112DLDN1 | 220-240 | 1,7 |
| AC8 | MI2-140DLDN1 | 220-240 | 1,7 |
| AD1 | MI2-22F3DN1 | 220-240 | 0,49 |
| AD2 | MI2-28F3DN1 | 220-240 | 0,55 |
| AD3 | MI2-36F3DN1 | 220-240 | 0,55 |
| AD4 | MI2-45F3DN1 | 220-240 | 0,55 |
| AD5 | MI2-56F3DN1 | 220-240 | 0,85 |
| AD6 | MI2-71F3DN1 | 220-240 | 1,4 |
| AD7 | MI2-80F3DN1 | 220-240 | 1,4 |
| AD8 | MI2-22F4DN1 | 220-240 | 0,49 |
| AD9 | MI2-28F4DN1 | 220-240 | 0,55 |
| AD10 | MI2-36F4DN1 | 220-240 | 0,55 |
| AD11 | MI2-45F4DN1 | 220-240 | 0,55 |
| AD12 | MI2-56F4DN1 | 220-240 | 0,85 |
| AD13 | MI2-71F4DN1 | 220-240 | 1,4 |
| AD14 | MI2-80F4DN1 | 220-240 | 1,4 |
| AD15 | MI2-22F5DN1 | 220-240 | 0,49 |
| AD16 | MI2-28F5DN1 | 220-240 | 0,55 |
| AD17 | MI2-36F5DN1 | 220-240 | 0,55 |
| AD18 | MI2-45F5DN1 | 220-240 | 0,55 |
| AD19 | MI2-56F5DN1 | 220-240 | 0,85 |
| AD20 | MI2-71F5DN1 | 220-240 | 1,4 |
| AD21 | MI2-80F5DN1 | 220-240 | 1,4 |
| AE1 | MI2-71T1DN1 | 220-240 | 2,1 |
| AE2 | MI2-80T1DN1 | 220-240 | 2,1 |
| AE3 | MI2-90T1DN1 | 220-240 | 2,2 |
| AE4 | MI2-112T1DN1 | 220-240 | 2,9 |
| AE5 | MI2-140T1DN1 | 220-240 | 4,5 |
| AE6 | MI2-160T1DN1 | 220-240 | 4,7 |
| AE7 | MI2-200T1DN1 | 220-240 | 6,7 |
| AE8 | MI2-250T1DN1 | 220-240 | 6,7 |

| | | | |
|------|--------------|---------|------|
| AE9 | MI2-280T1DN1 | 220-240 | 6,7 |
| AE10 | MI2-125FADN1 | 220-240 | 3,5 |
| AE11 | MI2-140FADN1 | 220-240 | 3,5 |
| AE12 | MI2-200FADN1 | 220-240 | 5,2 |
| AE13 | MI2-250FADN1 | 220-240 | 5,2 |
| AE14 | MI2-280FADN1 | 220-240 | 5,2 |
| AF1 | MI2-22GDN1 | 220-240 | 0,32 |
| AF2 | MI2-28GDN1 | 220-240 | 0,32 |
| AF3 | MI2-36GDN1 | 220-240 | 0,45 |
| AF4 | MI2-45GDN1 | 220-240 | 0,47 |
| AF5 | MI2-56GDN1 | 220-240 | 0,58 |
| AF6 | MI2-71GDN1 | 220-240 | 0,90 |
| AF7 | MI2-80GDN1 | 220-240 | 0,90 |
| AF8 | MI2-90GDN1 | 220-240 | 1,1 |
| AG1 | MI2-22ZDN1 | 220-240 | 0,37 |
| AG2 | MI2-28ZDN1 | 220-240 | 0,40 |
| AG3 | MI2-36ZDN1 | 220-240 | 0,42 |
| AG4 | MI2-45ZDN1 | 220-240 | 0,53 |

| Series | Model | Rated Voltage (V) | Rated power (W) |
|--------|--------------|-------------------|-----------------|
| W1 | SMK-D140/MN1 | 220-240 | 10 |



Attachment No.5

Marking plate

Attachment contains

| | |
|---------------|------------------|
| Cover page: | 1 page |
| Requirements: | 108 pages |
| Total: | 109 pages |

Explanation for Abbreviations:





Possible Verdicts: **P** = Pass, **F**= Fail, **N/A** = Not Applicable





Remarks:





Throughout this report, a comma is used as the Decimal separator.



MDV-D36DL/N1-C

MDV-D45DL/N1-C

| | |
|---|---|
|   | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D36DLN1-C |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX.  0.23A/5.0A |
| NET WEIGHT | 26kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
|  | |

| | |
|--|---|
|   | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D45DLN1-C |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX.  0.67A/5.0A |
| NET WEIGHT | 28kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
|  | |

| | |
|---|---|
|   | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D56DLN1-C |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | 5.3kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX.  0.67A/5.0A |
| NET WEIGHT | 28kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
|  | |

| | |
|--|---|
|   | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D71DLN1-C |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | 8.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX.  0.67A/5.0A |
| NET WEIGHT | 28kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
|  | |

MDV-D56DL/N1-C

MDV-D71DL/N1-C

MDV-D80DL/N1-C

| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80DL/N1-C | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.83A/5.0A |
| NET WEIGHT | 34.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D90DL/N1-C

| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D90DL/N1-C | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.83A/5.0A |
| NET WEIGHT | 34.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|-----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D112DL/N1-C | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 1.11A/5.0A |
| NET WEIGHT | 54kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D112DL/N1-C

| | | |
|---|-----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D140DL/N1-C | |
| COOLING CAPACITY | 14kW | |
| HEATING CAPACITY | 15kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 1.11A/5.0A |
| NET WEIGHT | 54kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D140DL/N1-C

MDVC-D36DL/N1-C

| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36DLN1-C | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | ----- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.23A/5.0A |
| NET WEIGHT | 26kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45DL/N1-C

| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45DLN1-C | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | ----- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.67A/5.0A |
| NET WEIGHT | 28kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56DL/N1-C

| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56DLN1-C | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | ----- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.67A/5.0A |
| NET WEIGHT | 28kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71DLN1-C | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | ----- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.67A/5.0A |
| NET WEIGHT | 28kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D71DL/N1-C




| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80DLN1-C | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | ----- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.83A/5.0A |
| NET WEIGHT | 34.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D80DL/N1-C




| | | |
|---|----------------|------------|
| | | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D90DLN1-C | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | ----- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.83A/5.0A |
| NET WEIGHT | 34.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D90DL/N1-C

MDVC-D112DL/N1-C

| | |
|---|-----------------|
|   | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D112DLN1-C |
| COOLING CAPACITY | 11.2kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.11A/5.0A |
| NET WEIGHT | 54kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
|  | |

MDVC-D140DL/N1-C

| | |
|---|-----------------|
|   | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D140DLN1-C |
| COOLING CAPACITY | 14kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.11A/5.0A |
| NET WEIGHT | 54kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
|  | |

MDV-D22G/DN1-S

| | | | |
|--|----------------|---------|----------------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D22G/DN1-S | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | 2.4kW+0.75kW | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.14A/8A |
| | | HEATING | 0.14A+3.38A/8A |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D28G/DN1-S

| | | | |
|--|----------------|---------|----------------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D28G/DN1-S | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW+0.75kW | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.14A/8A |
| | | HEATING | 0.14A+3.38A/8A |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36G/DN1-S

| | | | |
|--|----------------|---------|----------------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36G/DN1-S | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW+0.75kW | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.14A/8A |
| | | HEATING | 0.14A+3.38A/8A |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|----------------|---------|----------------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45G/DN1-S | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW+0.9kW | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 15.1kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.20A/8A |
| | | HEATING | 0.20A+4.05A/8A |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45G/DN1-S

| | | | |
|--|----------------|---------|----------------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D56G/DN1-S | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | 6.3kW+0.9kW | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 15.1kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.20A/8A |
| | | HEATING | 0.20A+4.05A/8A |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D56G/DN1-S

MDV-D22G/N1-S

| | | | |
|--|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D22G/N1-S | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | 2.4kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.14A/5A | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D28G/N1-S

| | | | |
|--|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D28G/N1-S | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.14A/5A | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36G/N1-S

| | | | |
|--|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36G/N1-S | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.14A/5A | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45G/N1-S | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.20A/5A | |
| NET WEIGHT | 15.1kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45G/N1-S

| | | | |
|--|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D56G/N1-S | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | 6.3kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.20A/5A | |
| NET WEIGHT | 15.1kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D56G/N1-S

MDVC-D22G/DN1-S

| | | | |
|---|-----------------|---------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D22G/DN1-S | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.14A/8A |
| | | HEATING | - |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D28G/DN1-S

| | | | |
|---|-----------------|---------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D28G/DN1-S | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.14A/8A |
| | | HEATING | - |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D36G/DN1-S

| | | | |
|---|-----------------|---------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D36G/DN1-S | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 13kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.14A/8A |
| | | HEATING | - |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D45G/DN1-S

| | | | |
|---|-----------------|---------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D45G/DN1-S | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 15.1kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.20A/8A |
| | | HEATING | - |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D56G/DN1-S

| | | | |
|---|-----------------|---------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D56G/DN1-S | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V- 50Hz | | |
| NET WEIGHT | 15.1kg | | |
| REFRIGERANT | R410A | | |
| RATED CURRENT | MAX | COOLING | 0.20A/8A |
| | | HEATING | - |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D22G/N1-S

| | | |
|---|----------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22G/N1-S | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.14A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28G/N1-S

| | | |
|---|----------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28G/N1-S | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.14A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36G/N1-S

| | | |
|---|----------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36G/N1-S | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.14A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45G/N1-S

| | | |
|---|----------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45G/N1-S | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.20A/5A |
| NET WEIGHT | 15.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56G/N1-S

| | | |
|---|----------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56G/N1-S | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.20A/5A |
| NET WEIGHT | 15.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Q1/N1-C

| | | |
|---|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Q1/N1-C | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.23A/5A |
| NET WEIGHT | 23.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36Q1/N1-C

| | | |
|---|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36Q1/N1-C | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.23A/5A |
| NET WEIGHT | 23.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28Q1/N1-C

| | | |
|---|-----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Q1/N1-C | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.23A/5A |
| NET WEIGHT | 23.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Q1/N1-C

| | | |
|---|-----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Q1/N1-C | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.23A/5A |
| NET WEIGHT | 23.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Q2/N1

| | | | |
|---|----------------|-----------|--|
| | | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D22Q2/N1 | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | 2.6kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.4A/5.0A | |
| NET WEIGHT | 34kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D28Q2/N1

| | | | |
|---|----------------|-----------|--|
| | | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D28Q2/N1 | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.4A/5.0A | |
| NET WEIGHT | 34kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36Q2/N1

| | | | |
|---|----------------|-----------|--|
| | | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36Q2/N1 | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.4A/5.0A | |
| NET WEIGHT | 34kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45Q2/N1

| | | | |
|---|----------------|-----------|--|
| | | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45Q2/N1 | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.5A/5.0A | |
| NET WEIGHT | 36kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D56Q2/N1

| | | | |
|---|----------------|------------|--|
| | | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D56Q2/N1 | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | 6.3kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.65A/5.0A | |
| NET WEIGHT | 36kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D71Q2/N1

| | | | |
|---|----------------|------------|--|
| | | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D71Q2/N1 | | |
| COOLING CAPACITY | 7.1kW | | |
| HEATING CAPACITY | 8.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.85A/5.0A | |
| NET WEIGHT | 36kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45Q2/N1

MDV-D56Q2/N1

MDV-D71Q2/N1

MDVC-D22Q2/N1

| | | |
|--|----------------|-----------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22Q2/N1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.4A/5.0A |
| NET WEIGHT | 34kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28Q2/N1

| | | |
|--|----------------|-----------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Q2/N1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.4A/5.0A |
| NET WEIGHT | 34kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Q2/N1

| | | |
|--|----------------|-----------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Q2/N1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.4A/5.0A |
| NET WEIGHT | 34kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45Q2/N1

| | | |
|--|----------------|-----------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Q2/N1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.5A/5.0A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56Q2/N1

| | | |
|--|----------------|------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56Q2/N1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.65A/5.0A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D71Q2/N1

| | | |
|--|----------------|------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71Q2/N1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.85A/5.0A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Q4/N1-A3

| | | |
|---|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Q4N1-A3 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Q4/N1-A3

| | | |
|---|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Q4N1-A3 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36Q4N1-A3 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5.0A |
| NET WEIGHT | 19kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36Q4/N1-A3

| | | |
|---|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D45Q4N1-A3 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5.0A |
| NET WEIGHT | 19kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D45Q4/N1-A3

MDVC-D22Q4/N1-A3

| | | |
|---|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22Q4N1-A3 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5.0A |
| NET WEIGHT | 16kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28Q4/N1-A3

| | | |
|---|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Q4N1-A3 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5.0A |
| NET WEIGHT | 16kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Q4/N1-A3

| | | |
|---|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Q4N1-A3 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5.0A |
| NET WEIGHT | 18kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45Q4/N1-A3

| | | |
|---|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Q4N1-A3 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5.0A |
| NET WEIGHT | 18kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D125T1/N1-FA

| | | | |
|--|------------------|-----------|--|
| | | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D125T1/N1-FA | | |
| COOLING CAPACITY | 12.5kW | | |
| HEATING CAPACITY | 10.5kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 2.4A/5.0A | |
| NET WEIGHT | 69.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D140T1/N1-FA

| | | | |
|--|------------------|-----------|--|
| | | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D140T1/N1-FA | | |
| COOLING CAPACITY | 14.0kW | | |
| HEATING CAPACITY | 12.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 2.4A/5.0A | |
| NET WEIGHT | 69.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D200T1/N1-FA

| | | | |
|--|------------------|----------|--|
| | | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D200T1/N1-FA | | |
| COOLING CAPACITY | 20.0kW | | |
| HEATING CAPACITY | 18.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 5.3A/10A | |
| NET WEIGHT | 115kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|------------------|----------|--|
| | | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D250T1/N1-FA | | |
| COOLING CAPACITY | 25.0kW | | |
| HEATING CAPACITY | 20.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 5.6A/10A | |
| NET WEIGHT | 115kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D250T1/N1-FA

| | | | |
|--|------------------|----------|--|
| | | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D280T1/N1-FA | | |
| COOLING CAPACITY | 28.0kW | | |
| HEATING CAPACITY | 22.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 5.6A/10A | |
| NET WEIGHT | 115kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D280T1/N1-FA

MDVC-D125T1/N1-FA

| | | |
|--|-------------------|-----------|
| | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D125T1/N1-FA | |
| COOLING CAPACITY | 12.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.4A/5.0A |
| NET WEIGHT | 69.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D140T1/N1-FA

| | | |
|--|-------------------|-----------|
| | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D140T1/N1-FA | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.4A/5.0A |
| NET WEIGHT | 69.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D200T1/N1-FA

| | | |
|--|-------------------|----------|
| | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D200T1/N1-FA | |
| COOLING CAPACITY | 20.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 5.3A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D250T1/N1-FA

| | | |
|--|-------------------|----------|
| | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D250T1/N1-FA | |
| COOLING CAPACITY | 25.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 5.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D280T1/N1-FA

| | | |
|--|-------------------|----------|
| | | |
| FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D280T1/N1-FA | |
| COOLING CAPACITY | 28.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 5.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22T2/N1-BA5

| | | | |
|--|------------------|------------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D22T2/N1-BA5 | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | 2.4kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.28A/5.0A | |
| NET WEIGHT | 21.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D28T2/N1-BA5

| | | | |
|--|------------------|------------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D28T2/N1-BA5 | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.28A/5.0A | |
| NET WEIGHT | 21.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36T2/N1-BA5

| | | | |
|--|------------------|------------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36T2/N1-BA5 | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.28A/5.0A | |
| NET WEIGHT | 22kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|------------------|-----------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45T2/N1-BA5 | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.5A/5.0A | |
| NET WEIGHT | 27kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45T2/N1-BA5





| | | | |
|--|------------------|-----------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D56T2/N1-BA5 | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | 6.3kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.5A/5.0A | |
| NET WEIGHT | 27kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D56T2/N1-BA5





| | | | |
|--|------------------|-----------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D71T2/N1-BA5 | | |
| COOLING CAPACITY | 7.1kW | | |
| HEATING CAPACITY | 8.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.7A/5.0A | |
| NET WEIGHT | 30kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D71T2/N1-BA5





MDV-D80T2/N1-BA5

| | | |
|---|--|---|
|  | |  |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80T2N1-BA5 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX.  | 1.0A/5.0A |
| NET WEIGHT | 40kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |





MDV-D90T2/N1-BA5

| | | |
|---|--|---|
|  | |  |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D90T2N1-BA5 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX.  | 1.0A/5.0A |
| NET WEIGHT | 42kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDV-D112T2/N1-BA5

| | | |
|---|--|---|
|  | |  |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D112T2/N1-BA5 | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX.  | 1.8A/5.0A |
| NET WEIGHT | 42kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDV-D140T2/N1-BA5

| | | |
|---|--|---|
|  | |  |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D140T2/N1-BA5 | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 15.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX.  | 1.55A/5.0A |
| NET WEIGHT | 50kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D22T2/N1-BA5

| | | | |
|--|-------------------|------------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D22T2/N1-BA5 | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.28A/5.0A | |
| NET WEIGHT | 21.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D28T2/N1-BA5

| | | | |
|--|-------------------|------------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D28T2/N1-BA5 | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.28A/5.0A | |
| NET WEIGHT | 21.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D36T2/N1-BA5

| | | | |
|--|-------------------|------------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D36T2/N1-BA5 | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.28A/5.0A | |
| NET WEIGHT | 22kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D45T2/N1-BA5

| | | | |
|--|-------------------|-----------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D45T2/N1-BA5 | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.5A/5.0A | |
| NET WEIGHT | 27kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |




MDVC-D56T2/N1-BA5

| | | | |
|--|-------------------|-----------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D56T2/N1-BA5 | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.5A/5.0A | |
| NET WEIGHT | 27kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |




MDVC-D71T2/N1-BA5




| | | | |
|--|-------------------|-----------|--|
| | | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D71T2/N1-BA5 | | |
| COOLING CAPACITY | 7.1kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.7A/5.0A | |
| NET WEIGHT | 30kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D80T2/N1-BA5




| | | |
|---|-------------------|-----------|
|   | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80T2/N1-BA5 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.0A/5.0A |
| NET WEIGHT | 38kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D90T2/N1-BA5

| | | |
|--|-------------------|-----------|
|   | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D90T2/N1-BA5 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.0A/5.0A |
| NET WEIGHT | 40kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

| | | |
|---|--------------------|-----------|
|   | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D112T2/N1-BA5 | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.8A/5.0A |
| NET WEIGHT | 40kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D112T2/N1-BA5

| | | |
|--|--------------------|------------|
|   | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D140T2/N1-BA5 | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.55A/5.0A |
| NET WEIGHT | 49kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D140T2/N1-BA5

MDV-D18T3/N1-B

| | | | |
|---|----------------|------------|--|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D18T3/N1-B | | |
| COOLING CAPACITY | 1.8kW | | |
| HEATING CAPACITY | 2.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.18A/5.0A | |
| NET WEIGHT | 11.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D22T3/N1-B

| | | | |
|---|----------------|------------|--|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D22T3/N1-B | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | 2.6kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.18A/5.0A | |
| NET WEIGHT | 11.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D28T3/N1-B

| | | | |
|---|----------------|------------|--|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D28T3/N1-B | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.18A/5.0A | |
| NET WEIGHT | 11.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|---|----------------|------------|--|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36T3/N1-B | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.18A/5.0A | |
| NET WEIGHT | 11.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36T3/N1-B

| | | | |
|---|----------------|------------|--|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45T3/N1-B | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.25A/5.0A | |
| NET WEIGHT | 14kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45T3/N1-B

| | | | |
|---|----------------|------------|--|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D56T3/N1-B | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | 6.3kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.25A/5.0A | |
| NET WEIGHT | 14kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D56T3/N1-B

MDVC-D18T3/N1-B

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D18T3N1-B | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5.0A |
| NET WEIGHT | 11.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22T3/N1-B

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22T3N1-B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5.0A |
| NET WEIGHT | 11.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28T3/N1-B

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28T3N1-B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5.0A |
| NET WEIGHT | 11.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36T3/N1-B

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36T3N1-B | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5.0A |
| NET WEIGHT | 11.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45T3/N1-B

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45T3N1-B | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5.0A |
| NET WEIGHT | 14kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56T3/N1-B

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56T3N1-B | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5.0A |
| NET WEIGHT | 14kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Z/DN1-B

| | | |
|---|----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Z/DN1-B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.09A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Z/DN1-B

| | | |
|---|----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Z/DN1-B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.11A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36Z/DN1-B

| | | |
|---|----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36Z/DN1-B | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.15A/5A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D45Z/DN1-B

| | | |
|---|----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D45Z/DN1-B | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.20A/5A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22Z/DN1-B

| | | |
|---|-----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22Z/DN1-B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.09A/5A |
| NET WEIGHT | 14kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28Z/DN1-B

| | | |
|---|-----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Z/DN1-B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.11A/5A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Z/DN1-B

| | | |
|---|-----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Z/DN1-B | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.15A/5A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45Z/DN1-B

| | | |
|---|-----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Z/DN1-B | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.20A/5A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Z/N1-F1B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Z/N1-F1B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Z/N1-F2B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Z/N1-F2B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Z/N1-F3B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Z/N1-F3B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 26kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Z/N1-F1B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.21A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Z/N1-F1B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Z/N1-F2B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.21A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Z/N1-F2B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Z/N1-F3B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.21A/5A |
| NET WEIGHT | 26kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Z/N1-F3B

MDV-D36Z/N1-F1B

| | | | |
|--|-----------------|----------|--|
| | | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36Z/N1-F1B | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.22A/5A | |
| NET WEIGHT | 37kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36Z/N1-F2B

| | | | |
|--|-----------------|----------|--|
| | | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36Z/N1-F2B | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.22A/5A | |
| NET WEIGHT | 37kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36Z/N1-F3B

| | | | |
|--|-----------------|----------|--|
| | | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36Z/N1-F3B | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.22A/5A | |
| NET WEIGHT | 29.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|-----------------|----------|--|
| | | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45Z/N1-F1B | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.22A/5A | |
| NET WEIGHT | 37kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45Z/N1-F1B

| | | | |
|--|-----------------|----------|--|
| | | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45Z/N1-F2B | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.22A/5A | |
| NET WEIGHT | 37kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45Z/N1-F2B

| | | | |
|--|-----------------|----------|--|
| | | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45Z/N1-F3B | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.22A/5A | |
| NET WEIGHT | 29.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45Z/N1-F3B

MDV-D56Z/N1-F1B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56Z/N1-F1B | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.40A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D56Z/N1-F2B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56Z/N1-F2B | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.40A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D56Z/N1-F3B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56Z/N1-F3B | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.40A/5A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71Z/N1-F1B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71Z/N1-F1B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71Z/N1-F2B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71Z/N1-F2B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71Z/N1-F3B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V- 50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71Z/N1-F3B

MDV-D80Z/N1-F1B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80Z/N1-F1B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D80Z/N1-F2B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80Z/N1-F2B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D80Z/N1-F3B

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80Z/N1-F3B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22Z/N1-F1B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22Z/N1-F1B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22Z/N1-F2B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22Z/N1-F2B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28Z/N1-F1B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Z/N1-F1B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.21A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22Z/N1-F3B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22Z/N1-F3B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 25kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28Z/N1-F3B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Z/N1-F3B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.21A/5A |
| NET WEIGHT | 25kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56Z/N1-F3B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56Z/N1-F3B | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.40A/5A |
| NET WEIGHT | 33kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71Z/N1-F3B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 33kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D71Z/N1-F3B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Z/N1-F2B | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Z/N1-F2B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Z/N1-F2B | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45Z/N1-F2B

| | |
|---|------------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D36Z/N1-F2B |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5A |
| NET WEIGHT | 35kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D36Z/N1-F2B

| | |
|---|------------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D45Z/N1-F2B |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5A |
| NET WEIGHT | 35kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D45Z/N1-F2B

MDVC-D45Z/N1-F3B

| | |
|---|------------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D45Z/N1-F3B |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5A |
| NET WEIGHT | 29.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D56Z/N1-F1B

| | |
|---|------------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D56Z/N1-F1B |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.40A/5A |
| NET WEIGHT | 44kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D56Z/N1-F2B

| | |
|---|------------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D56Z/N1-F2B |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.40A/5A |
| NET WEIGHT | 41kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D71Z/N1-F2B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71Z/N1-F2B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D80Z/N1-F2B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80Z/N1-F2B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 42kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D71Z/N1-F1B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71Z/N1-F1B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Z/N1-F1B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Z/N1-F1B | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 34.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |





MDVC-D45Z/N1-F1B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Z/N1-F1B | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 34.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |





MDVC-D80Z/N1-F1B

| | | |
|--|------------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80Z/N1-F1B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.59A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |





MDVC-D28Z/N1-F2B

| | | |
|---|---|---|
|  | |  |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Z/N1-F2B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX  | 0.21A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D36Z/N1-F3B

| | | |
|---|---|---|
|  | |  |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Z/N1-F3B | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX  | 0.22A/5A |
| NET WEIGHT | 29.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D80Z/N1-F3B

| | | |
|---|---|---|
|  | |  |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80Z/N1-F3B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX  | 0.59A/5A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDV-D22Z/N1-F4

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Z/N1-F4 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Z/N1-F5

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Z/N1-F5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Z/N1-F4

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Z/N1-F4 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.19A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Z/N1-F5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.19A/5A |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Z/N1-F5

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36Z/N1-F4 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36Z/N1-F4

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36Z/N1-F5 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 35.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36Z/N1-F5

MDV-D45Z/N1-F4

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D45Z/N1-F4 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D45Z/N1-F5

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D45Z/N1-F5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 35.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D56Z/N1-F4

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56Z/N1-F4 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.43A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56Z/N1-F5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.43A/5A |
| NET WEIGHT | 42kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D56Z/N1-F5





| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71Z/N1-F4 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.63A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71Z/N1-F4





| | | |
|--|----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71Z/N1-F5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.63A/5A |
| NET WEIGHT | 42kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71Z/N1-F5

MDV-D80Z/N1-F4

| | | |
|---|---|----------|
|   | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80Z/N1-F4 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT |  | 0.63A/5A |
| NET WEIGHT | 42.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDV-D80Z/N1-F5

| | | |
|---|---|----------|
|   | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80Z/N1-F5 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT |  | 0.63A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D22Z/N1-F4

| | |
|---|-----------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D22Z/N1-F4 |
| COOLING CAPACITY | 2.2kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.18A/5A |
| NET WEIGHT | 30kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D22Z/N1-F5

| | |
|---|-----------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D22Z/N1-F5 |
| COOLING CAPACITY | 2.2kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.18A/5A |
| NET WEIGHT | 30kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D28Z/N1-F4

| | |
|---|-----------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D28Z/N1-F4 |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.19A/5A |
| NET WEIGHT | 30kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|---|-----------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D28Z/N1-F5 |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.19A/5A |
| NET WEIGHT | 30kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D28Z/N1-F5

| | |
|---|-----------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D36Z/N1-F4 |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5A |
| NET WEIGHT | 36kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D36Z/N1-F4

| | |
|---|-----------------|
| | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D36Z/N1-F5 |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5A |
| NET WEIGHT | 35.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D36Z/N1-F5

MDVC-D45Z/N1-F4

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Z/N1-F4 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45Z/N1-F5

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Z/N1-F5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5A |
| NET WEIGHT | 35.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56Z/N1-F4

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56Z/N1-F4 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.43A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56Z/N1-F5

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56Z/N1-F5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.43A/5A |
| NET WEIGHT | 42kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |




MDVC-D71Z/N1-F4

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71Z/N1-F4 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.63A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |




MDVC-D71Z/N1-F5

| | | |
|--|-----------------|----------|
| | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71Z/N1-F5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.63A/5A |
| NET WEIGHT | 42kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D80Z/N1-F4

| | | |
|---|--|----------|
|  | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80Z/N1-F5 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX.  | 0.63A/5A |
| NET WEIGHT | 44kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDVC-D80Z/N1-F5

| | | |
|---|--|----------|
|  | | |
| DIGITAL SCROLL FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80Z/N1-F4 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V-50Hz | |
| RATED CURRENT | MAX.  | 0.63A/5A |
| NET WEIGHT | 42.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|  | | |

MDV-D71T1/N1-B

| | | |
|---|----------------|------------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71T1/N1-B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.23A/5.0A |
| NET WEIGHT | 45kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D80T1/N1-B

| | | |
|---|----------------|------------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D80T1/N1-B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.23A/5.0A |
| NET WEIGHT | 45kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D90T1/N1-B

| | | |
|---|----------------|------------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D90T1/N1-B | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.87A/5.0A |
| NET WEIGHT | 46.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|-----------------|-----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D112T1/N1-B | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.3A/5.0A |
| NET WEIGHT | 50.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D112T1/N1-B

| | | |
|---|-----------------|------------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D140T1/N1-B | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 16.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.85A/5.0A |
| NET WEIGHT | 70kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D140T1/N1-B

| | | |
|---|-----------------|------------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D160T1/N1-B | |
| COOLING CAPACITY | 16.0kW | |
| HEATING CAPACITY | 17.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 4.77A/5.0A |
| NET WEIGHT | 70kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D160T1/N1-B

MDV-D200T1/N1-B

| | | |
|---|-----------------|----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D200T1/N1-B | |
| COOLING CAPACITY | 20.0kW | |
| HEATING CAPACITY | 22.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 8.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D250T1/N1-B

| | | |
|---|-----------------|----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D250T1/N1-B | |
| COOLING CAPACITY | 25.0kW | |
| HEATING CAPACITY | 26.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 8.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D280T1/N1-B

| | | |
|---|-----------------|----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D280T1/N1-B | |
| COOLING CAPACITY | 28.0kW | |
| HEATING CAPACITY | 31.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 8.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D200T1/N1-B

| | | |
|---|------------------|----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D200T1/N1-B | |
| COOLING CAPACITY | 20.0kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 8.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D250T1/N1-B

| | | |
|---|------------------|----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D250T1/N1-B | |
| COOLING CAPACITY | 25.0kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 8.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D280T1/N1-B

| | | |
|---|------------------|----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D280T1/N1-B | |
| COOLING CAPACITY | 28.0kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 8.6A/10A |
| NET WEIGHT | 115kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D71T1/N1-B

| | |
|---|------------------|
| | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D71T1/N1-B |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.23A/5.0A |
| NET WEIGHT | 45kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D80T1/N1-B

| | |
|---|------------------|
| | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D80T1/N1-B |
| COOLING CAPACITY | 8.0kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.23A/5.0A |
| NET WEIGHT | 45kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D90T1/N1-B

| | |
|---|------------------|
| | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D90T1/N1-B |
| COOLING CAPACITY | 9.0kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.87A/5.0A |
| NET WEIGHT | 46.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|---|------------------|
| | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D112T1/N1-B |
| COOLING CAPACITY | 11.2kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 2.3A/5.0A |
| NET WEIGHT | 50.6kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D112T1/N1-B

| | |
|---|------------------|
| | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D140T1/N1-B |
| COOLING CAPACITY | 14.0kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 2.85A/5.0A |
| NET WEIGHT | 70kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D140T1/N1-B

| | |
|---|------------------|
| | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D160T1/N1-B |
| COOLING CAPACITY | 16.0kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 4.77A/6.0A |
| NET WEIGHT | 70kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D160T1/N1-B

MDV-D28Q4/N1-D

| | | | |
|--|----------------|------------|--|
| | | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D28Q4/N1-D | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.41A/5.0A | |
| NET WEIGHT | 24kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36Q4/N1-D

| | | | |
|--|----------------|------------|--|
| | | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36Q4/N1-D | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.41A/5.0A | |
| NET WEIGHT | 24kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45Q4/N1-D

| | | | |
|--|----------------|------------|--|
| | | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45Q4/N1-D | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.41A/5.0A | |
| NET WEIGHT | 26kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|----------------|------------|--|
| | | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D56Q4/N1-D | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | 6.3kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.41A/5.0A | |
| NET WEIGHT | 26kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D56Q4/N1-D

| | | | |
|--|----------------|------------|--|
| | | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D71Q4/N1-D | | |
| COOLING CAPACITY | 7.1kW | | |
| HEATING CAPACITY | 8.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.52A/5.0A | |
| NET WEIGHT | 26kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D71Q4/N1-D

| | | | |
|--|----------------|------------|--|
| | | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D80Q4/N1-D | | |
| COOLING CAPACITY | 8.0kW | | |
| HEATING CAPACITY | 9.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.52A/5.0A | |
| NET WEIGHT | 26kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D80Q4/N1-D

MDV-D90Q4/N1-D

| | |
|--|------------------|
| | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D90Q4/N1-D |
| COOLING CAPACITY | 9.0kW |
| HEATING CAPACITY | 10.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.73A/5.0A |
| NET WEIGHT | 32kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D100Q4/N1-D

| | |
|--|------------------|
| | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D100Q4/N1-D |
| COOLING CAPACITY | 10.0kW |
| HEATING CAPACITY | 11.1kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.73A/5.0A |
| NET WEIGHT | 32kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|------------------|
| | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D112Q4/N1-D |
| COOLING CAPACITY | 11.2kW |
| HEATING CAPACITY | 12.5kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.73A/5.0A |
| NET WEIGHT | 32kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D112Q4/N1-D

| | |
|--|------------------|
| | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D140Q4/N1-D |
| COOLING CAPACITY | 14kW |
| HEATING CAPACITY | 15kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.82A/5.0A |
| NET WEIGHT | 32kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D140Q4/N1-D

MDVC-D28Q4/N1-D

| | | |
|--|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Q4/N1-D | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.41A/5.0A |
| NET WEIGHT | 24kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Q4/N1-D

| | | |
|--|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Q4/N1-D | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.41A/5.0A |
| NET WEIGHT | 24kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45Q4/N1-D

| | | |
|--|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45Q4/N1-D | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.41A/5.0A |
| NET WEIGHT | 26kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56Q4/N1-D

| | | |
|--|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56Q4/N1-D | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.41A/5.0A |
| NET WEIGHT | 26kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D71Q4/N1-D

| | | |
|--|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71Q4/N1-D | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.52A/5.0A |
| NET WEIGHT | 26kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D80Q4/N1-D

| | | |
|--|-----------------|------------|
| | | |
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D80Q4/N1-D | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.52A/5.0A |
| NET WEIGHT | 26kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22G/DN1YB

| | |
|---|---|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D22G/DN1YB |
| COOLING CAPACITY | 2.2kW |
| HEATING CAPACITY | 2.4kW+0.75kW |
| POWER SOURCE | 220-240V~ 50Hz |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX. COOLING 0.14A/BA HEATING 0.14A+3.38A/BA |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D28G/DN1YB

| | |
|---|---|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D28G/DN1YB |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | 3.2kW+0.75kW |
| POWER SOURCE | 220-240V~ 50Hz |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX. COOLING 0.14A/BA HEATING 0.14A+3.38A/BA |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D36G/DN1YB

| | |
|---|---|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D36G/DN1YB |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW+0.75kW |
| POWER SOURCE | 220-240V~ 50Hz |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX. COOLING 0.14A/BA HEATING 0.14A+3.38A/BA |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|---|---|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D45G/DN1YB |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW+0.9kW |
| POWER SOURCE | 220-240V~ 50Hz |
| NET WEIGHT | 15kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX. COOLING 0.20A/BA HEATING 0.20A+4.05A/BA |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D45G/DN1YB

| | |
|---|---|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D56G/DN1YB |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | 6.3kW+0.9kW |
| POWER SOURCE | 220-240V~ 50Hz |
| NET WEIGHT | 15kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX. COOLING 0.20A/BA HEATING 0.20A+4.05A/BA |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D56G/DN1YB

MDV-D22G/N1YB

| | | | |
|---|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D22G/N1YB | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | 2.4kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.14A/5A | |
| NET WEIGHT | 12kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D28G/N1YB

| | | | |
|---|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D28G/N1YB | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.14A/5A | |
| NET WEIGHT | 12kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D36G/N1YB

| | | | |
|---|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D36G/N1YB | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.14A/5A | |
| NET WEIGHT | 12kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|---|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D45G/N1YB | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | 5.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.20A/5A | |
| NET WEIGHT | 15kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D45G/N1YB

| | | | |
|---|----------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D56G/N1YB | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | 6.3kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 0.20A/5A | |
| NET WEIGHT | 15kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D56G/N1YB

MDVC-D22G/DN1YB

| | |
|---|----------------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D22G/DN1YB |
| COOLING CAPACITY | 2.2kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V- 50Hz |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX COOLING 0.14A/8A |
| | HEATING - |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D28G/DN1YB

| | |
|---|----------------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D28G/DN1YB |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V- 50Hz |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX COOLING 0.14A/8A |
| | HEATING - |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D36G/DN1YB

| | |
|---|----------------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D36G/DN1YB |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V- 50Hz |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX COOLING 0.14A/8A |
| | HEATING - |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D45G/DN1YB

| | |
|---|----------------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D45G/DN1YB |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V- 50Hz |
| NET WEIGHT | 15kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX COOLING 0.20A/8A |
| | HEATING - |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D56G/DN1YB

| | |
|---|------------------------------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D56G/DN1YB |
| COOLING CAPACITY | 5.8kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| NET WEIGHT | 15kg |
| REFRIGERANT | R410A |
| RATED CURRENT | MAX. COOLING 0.20A/8A HEATING — |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D71T2/N1-CA5

| | |
|---|------------------|
| | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D71T2/N1-CA5 |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | 8.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.7A/5.0A |
| NET WEIGHT | 31.8kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D71T2/N1-CA5

| | |
|---|-------------------|
| | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D71T2/N1-CA5 |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.7A/5.0A |
| NET WEIGHT | 31.8kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D71G-R3/N1Y

| | |
|---|-----------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D71G-R3/N1Y |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | 8.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.33A/10A |
| NET WEIGHT | 19.9kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D80G-R3/N1Y

| | |
|---|-----------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D80G-R3/N1Y |
| COOLING CAPACITY | 8.0kW |
| HEATING CAPACITY | 9.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.39A/10A |
| NET WEIGHT | 19.9kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D90G-R3/N1Y

| | |
|---|-----------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D90G-R3/N1Y |
| COOLING CAPACITY | 9.0kW |
| HEATING CAPACITY | 10.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.39A/10A |
| NET WEIGHT | 19.9kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D71G-R3/N1Y

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDVC-D71G-R3/N1Y | | | | |
| COOLING CAPACITY | 7.1kW | | | | |
| HEATING CAPACITY | — | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.33A/10A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.33A/10A | | |
| MAX. | 0.33A/10A | | | | |
| | | | | | |
| NET WEIGHT | 19.9kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="0"> <tr> <td style="text-align: center;">HIGH</td> <td>4.4MPa</td> </tr> <tr> <td style="text-align: center;">LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MDVC-D80G-R3/N1Y

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDVC-D80G-R3/N1Y | | | | |
| COOLING CAPACITY | 8.0kW | | | | |
| HEATING CAPACITY | — | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.39A/10A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.39A/10A | | |
| MAX. | 0.39A/10A | | | | |
| | | | | | |
| NET WEIGHT | 19.9kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="0"> <tr> <td style="text-align: center;">HIGH</td> <td>4.4MPa</td> </tr> <tr> <td style="text-align: center;">LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MDVC-D90G-R3/N1Y

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDVC-D90G-R3/N1Y | | | | |
| COOLING CAPACITY | 9.0kW | | | | |
| HEATING CAPACITY | — | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.39A/10A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.39A/10A | | |
| MAX. | 0.39A/10A | | | | |
| | | | | | |
| NET WEIGHT | 19.9kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="0"> <tr> <td style="text-align: center;">HIGH</td> <td>4.4MPa</td> </tr> <tr> <td style="text-align: center;">LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MDV-D400T1/N1

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDV-D400T1/N1 | | | | |
| COOLING CAPACITY | 40kW | | | | |
| HEATING CAPACITY | 45kW | | | | |
| POWER SOURCE | 220-240V-50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">12.5A/20A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 12.5A/20A | | |
| MAX. | 12.5A/20A | | | | |
| | | | | | |
| NET WEIGHT | 232kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="0"> <tr> <td style="text-align: center;">HIGH</td> <td>4.4MPa</td> </tr> <tr> <td style="text-align: center;">LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MDV-D450T1/N1

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDV-D450T1/N1 | | | | |
| COOLING CAPACITY | 45kW | | | | |
| HEATING CAPACITY | 50kW | | | | |
| POWER SOURCE | 220-240V~50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">12.5A/20A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 12.5A/20A | | |
| MAX. | 12.5A/20A | | | | |
| | | | | | |
| NET WEIGHT | 232kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="0"> <tr> <td style="text-align: center;">HIGH</td> <td>4.4MPa</td> </tr> <tr> <td style="text-align: center;">LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MDV-D560T1/N1

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDV-D560T1/N1 | | | | |
| COOLING CAPACITY | 56kW | | | | |
| HEATING CAPACITY | 63kW | | | | |
| POWER SOURCE | 220-240V~50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">15.5A/20A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 15.5A/20A | | |
| MAX. | 15.5A/20A | | | | |
| | | | | | |
| NET WEIGHT | 235kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="0"> <tr> <td style="text-align: center;">HIGH</td> <td>4.4MPa</td> </tr> <tr> <td style="text-align: center;">LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MDVC-D400T1/N1

| | | |
|--|----------------|-----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D400T1/N1 | |
| COOLING CAPACITY | 40kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 12.5A/20A |
| NET WEIGHT | 232kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D450T1/N1

| | | |
|--|----------------|-----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D450T1/N1 | |
| COOLING CAPACITY | 45kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 12.5A/20A |
| NET WEIGHT | 232kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D560T1/N1

| | | |
|--|----------------|-----------|
| | | |
| HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D560T1/N1 | |
| COOLING CAPACITY | 56kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 15.5A/20A |
| NET WEIGHT | 235kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D15T2/N1-DA5

| | | |
|--|------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D15T2/N1-DA5 | |
| COOLING CAPACITY | 1.5kW | |
| HEATING CAPACITY | 1.7kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D17T2/N1-DA5

| | | |
|--|------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D17T2/N1-DA5 | |
| COOLING CAPACITY | 1.7kW | |
| HEATING CAPACITY | 2.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22T2/N1-DA5

| | | |
|--|------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22T2/N1-DA5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 18.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28T2/N1-DA5

| | | |
|--|------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28T2/N1-DA5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 18.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28T2/N1-DA5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | _____ | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36T2/N1-DA5 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | _____ | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.33A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D15T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D15T2/N1-DA5 | |
| COOLING CAPACITY | 1.5kW | |
| HEATING CAPACITY | _____ | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D17T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D17T2/N1-DA5 | |
| COOLING CAPACITY | 1.7kW | |
| HEATING CAPACITY | _____ | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22T2/N1-DA5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | _____ | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D15Q4/N1-A3

| | |
|---|------------------|
| | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D15Q4/N1-A3 |
| COOLING CAPACITY | 1.5kW |
| HEATING CAPACITY | 1.7kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5.0A |
| NET WEIGHT | 16kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D36T2/N1-DA5

| | |
|---|------------------|
| | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D36T2/N1-DA5 |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.33A/5.0A |
| NET WEIGHT | 18.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D17Q4/N1-A3

| | |
|---|------------------|
| | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D17Q4/N1-A3 |
| COOLING CAPACITY | 1.7kW |
| HEATING CAPACITY | 2.2kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5.0A |
| NET WEIGHT | 16kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D15Q4/N1-A3

| | |
|---|------------------|
| | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D15Q4/N1-A3 |
| COOLING CAPACITY | 1.5kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5.0A |
| NET WEIGHT | 16kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDVC-D17Q4/N1-A3

| | |
|---|------------------|
| | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDVC-D17Q4/N1-A3 |
| COOLING CAPACITY | 1.7kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.22A/5.0A |
| NET WEIGHT | 16kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D15G/N1-S

| | |
|---|----------------|
| | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MDV-D15G/N1-S |
| COOLING CAPACITY | 1.5kW |
| HEATING CAPACITY | 1.7kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.12A/8A |
| NET WEIGHT | 12.4kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MDV-D17G/N1-S

| | | | |
|---|---|------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D17G/N1-S | | |
| COOLING CAPACITY | 1.7kW | | |
| HEATING CAPACITY | 1.9kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1" style="display: inline-table; vertical-align: middle;"> <tr> <td style="text-align: center;">MAX.</td> <td style="text-align: center;">0.12A/8A</td> </tr> </table> | MAX. | 0.12A/8A |
| MAX. | 0.12A/8A | | |
| NET WEIGHT | 12.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDV-D15G/N1YB

| | | | |
|---|---|------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D15G/N1YB | | |
| COOLING CAPACITY | 1.5kW | | |
| HEATING CAPACITY | 1.7kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1" style="display: inline-table; vertical-align: middle;"> <tr> <td style="text-align: center;">MAX.</td> <td style="text-align: center;">0.12A/8A</td> </tr> </table> | MAX. | 0.12A/8A |
| MAX. | 0.12A/8A | | |
| NET WEIGHT | 12.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDVC-D15G/N1-S

| | | | |
|---|---|------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D15G/N1-S | | |
| COOLING CAPACITY | 1.5kW | | |
| HEATING CAPACITY | ————— | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1" style="display: inline-table; vertical-align: middle;"> <tr> <td style="text-align: center;">MAX.</td> <td style="text-align: center;">0.12A/8A</td> </tr> </table> | MAX. | 0.12A/8A |
| MAX. | 0.12A/8A | | |
| NET WEIGHT | 12.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDVC-D17G/N1-S

| | | | |
|---|---|------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D17G/N1-S | | |
| COOLING CAPACITY | 1.7kW | | |
| HEATING CAPACITY | ————— | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1" style="display: inline-table; vertical-align: middle;"> <tr> <td style="text-align: center;">MAX.</td> <td style="text-align: center;">0.12A/8A</td> </tr> </table> | MAX. | 0.12A/8A |
| MAX. | 0.12A/8A | | |
| NET WEIGHT | 12.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDV-D17G/N1YB

| | | | |
|---|---|------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D17G/N1YB | | |
| COOLING CAPACITY | 1.7kW | | |
| HEATING CAPACITY | 1.9kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1" style="display: inline-table; vertical-align: middle;"> <tr> <td style="text-align: center;">MAX.</td> <td style="text-align: center;">0.12A/8A</td> </tr> </table> | MAX. | 0.12A/8A |
| MAX. | 0.12A/8A | | |
| NET WEIGHT | 12.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDVC-D15G/N1YB

| | | | |
|---|---|------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D15G/N1YB | | |
| COOLING CAPACITY | 1.5kW | | |
| HEATING CAPACITY | ————— | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1" style="display: inline-table; vertical-align: middle;"> <tr> <td style="text-align: center;">MAX.</td> <td style="text-align: center;">0.12A/8A</td> </tr> </table> | MAX. | 0.12A/8A |
| MAX. | 0.12A/8A | | |
| NET WEIGHT | 12.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDVC-D17G/N1YB

| | | | |
|---|---|------|----------|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D17G/N1YB | | |
| COOLING CAPACITY | 1.7kW | | |
| HEATING CAPACITY | ————— | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1" style="display: inline-table; vertical-align: middle;"> <tr> <td style="text-align: center;">MAX.</td> <td style="text-align: center;">0.12A/8A</td> </tr> </table> | MAX. | 0.12A/8A |
| MAX. | 0.12A/8A | | |
| NET WEIGHT | 12.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDV-D22G/N1Y-11D5,

| | | |
|--|-------------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22G/N1Y-11D5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.13A/5A |
| NET WEIGHT | 6.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28G/N1Y-11D5,

| | | |
|--|-------------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28G/N1Y-11D5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.15A/5A |
| NET WEIGHT | 7.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36G/N1Y-11D5

| | | |
|--|-------------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36G/N1Y-11D5 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.18A/5A |
| NET WEIGHT | 7.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D45G/N1Y-11D5,

| | | |
|--|-------------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D45G/N1Y-11D5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.21A/5A |
| NET WEIGHT | 9.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D56G/N1Y-11D5,

| | | |
|--|-------------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56G/N1Y-11D5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.30A/5A |
| NET WEIGHT | 12.9kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71G/N1Y-11D5

| | | |
|--|-------------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71G/N1Y-11D5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.35A/5A |
| NET WEIGHT | 12.9kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22G/N1Y-11D5,

| | | | |
|--|--------------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D22G/N1Y-11D5 | | |
| COOLING CAPACITY | 2.2kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | | 0.13A/5A | |
| NET WEIGHT | 6.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D28G/N1Y-11D5,

| | | | |
|--|--------------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D28G/N1Y-11D5 | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | | 0.15A/5A | |
| NET WEIGHT | 7.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D36G/N1Y-11D5

| | | | |
|--|--------------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D36G/N1Y-11D5 | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | | 0.18A/5A | |
| NET WEIGHT | 7.4kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D45G/N1Y-11D5

| | | | |
|--|--------------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D45G/N1Y-11D5 | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | | 0.21A/5A | |
| NET WEIGHT | 9.1kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D56G/N1Y-11D5

| | | | |
|--|--------------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D56G/N1Y-11D5 | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | | 0.30A/5A | |
| NET WEIGHT | 12.9kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDVC-D71G/N1Y-11D5

| | | | |
|--|--------------------|----------|--|
| | | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D71G/N1Y-11D5 | | |
| COOLING CAPACITY | 7.1kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | | 0.35A/5A | |
| NET WEIGHT | 12.9kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MDV-D18Q1/N1-D

| | | |
|---|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D18Q1/N1-D | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | 2.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.24A/5A |
| NET WEIGHT | 12.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22Q1/N1-D

| | | |
|---|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22Q1/N1-D | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.24A/5A |
| NET WEIGHT | 12.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Q1/N1-D

| | | |
|---|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28Q1/N1-D | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36Q1/N1-D,

| | | |
|---|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36Q1/N1-D | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D18Q1/N1-D

| | | |
|---|-----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D18Q1/N1-D | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.24A/5A |
| NET WEIGHT | 12.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22Q1/N1-D

| | | |
|---|-----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22Q1/N1-D | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.24A/5A |
| NET WEIGHT | 12.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28Q1/N1-D

| | | |
|---|-----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28Q1/N1-D | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36Q1/N1-D

| | | |
|---|-----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D36Q1/N1-D | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.25A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28Q4/N1-E,

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDV-D28Q4/N1-E | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.31A/5.0A | |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDVC-D28Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDVC-D28Q4/N1-E | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.31A/5.0A | |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D36Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDV-D36Q4/N1-E | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.31A/5.0A | |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDVC-D36Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDVC-D36Q4/N1-E | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.31A/5.0A | |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D45Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDV-D45Q4/N1-E | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.41A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDVC-D45Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDVC-D45Q4/N1-E | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.41A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D56Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|--------|
| MODEL | MDV-D56Q4/N1-E | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED MAX. CURRENT | 0.41A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDVC-D56Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDVC-D56Q4/N1-E | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED MAX. CURRENT | 0.41A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D71Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|--------|
| MODEL | MDV-D71Q4/N1-E | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED MAX. CURRENT | 0.41A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDVC-D71Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDVC-D71Q4/N1-E | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED MAX. CURRENT | 0.41A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D80Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|--------|
| MODEL | MDV-D80Q4/N1-E | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED MAX. CURRENT | 0.48A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDVC-D80Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MDVC-D80Q4/N1-E | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | --- | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED MAX. CURRENT | 0.48A/5.0A | |
| NET WEIGHT | 23.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D90Q4/N1-E

MDVC-D90Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|------------|
| MODEL | MDV-D90Q4/N1-E | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.67A/5.0A |
| NET WEIGHT | 28.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|------------|
| MODEL | MDVC-D90Q4/N1-E | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.67A/5.0A |
| NET WEIGHT | 28.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D100Q4/N1-E

MDVC-D100Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|------------|
| MODEL | MDV-D100Q4/N1-E | |
| COOLING CAPACITY | 10.0kW | |
| HEATING CAPACITY | 11.1kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.72A/5.0A |
| NET WEIGHT | 28.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|------------------|------------|
| MODEL | MDVC-D100Q4/N1-E | |
| COOLING CAPACITY | 10.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.72A/5.0A |
| NET WEIGHT | 28.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D112Q4/N1-E

MDVC-D112Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|------------|
| MODEL | MDV-D112Q4/N1-E | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.72A/5.0A |
| NET WEIGHT | 28.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|------------------|------------|
| MODEL | MDVC-D112Q4/N1-E | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.72A/5.0A |
| NET WEIGHT | 28.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MDV-D140Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|------------|
| MODEL | MDV-D140Q4/N1-E | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 16.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.75A/5.0A |
| NET WEIGHT | 30.9kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |
| | | |

MDVC-D140Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|------------------|------------|
| MODEL | MDVC-D140Q4/N1-E | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.75A/5.0A |
| NET WEIGHT | 30.9kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |
| | | |

MDV-D45T2/N1-DA5

| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
|--|------------------|------------|
| | | |
| MODEL | MDV-D45T2/N1-DA5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.36A/5.0A |
| NET WEIGHT | 22.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D56T2/N1-DA5

| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
|--|------------------|------------|
| | | |
| MODEL | MDV-D56T2/N1-DA5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.36A/5.0A |
| NET WEIGHT | 22.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71T2/N1-DA5

| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
|--|------------------|------------|
| | | |
| MODEL | MDV-D71T2/N1-DA5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.47A/5.0A |
| NET WEIGHT | 28kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D45T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D45T2/N1-DA5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.36A/5.0A |
| NET WEIGHT | 22.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D56T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D56T2/N1-DA5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.36A/5.0A |
| NET WEIGHT | 22.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D71T2/N1-DA5

| | | |
|--|-------------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D71T2/N1-DA5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.47A/5.0A |
| NET WEIGHT | 28kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D18T3/N1-C

| | | |
|---|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D18T3/N1-C | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | 2.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 14 kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D22T3/N1-C

| | | |
|---|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D22T3/N1-C | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 14 kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D28T3/N1-C

| | | |
|---|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D28T3/N1-C | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 14 kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D36T3/N1-C

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D36T3/N1-C | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.33A/5.0A |
| NET WEIGHT | 14 kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D45T3/N1-C

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D45T3/N1-C | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.36A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D56T3/N1-C

| | | |
|--|----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56T3/N1-C | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.36A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D18T3/N1-C

| | | |
|--|-----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D18T3/N1-C | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 14 kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D22T3/N1-C

| | | |
|--|-----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D22T3/N1-C | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 14 kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D28T3/N1-C

| | | |
|--|-----------------|------------|
| | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDVC-D28T3/N1-C | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.31A/5.0A |
| NET WEIGHT | 14 kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDVC-D36T3/N1-C

MDVC-D45T3/N1-C

MDVC-D56T3/N1-C

| | | | |
|--|--|------|------------|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D36T3/N1-C | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.33A/5.0A</td> </tr> </table> | MAX. | 0.33A/5.0A |
| MAX. | 0.33A/5.0A | | |
| NET WEIGHT | 14 kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDV-D71T3/N1-C

| | | | |
|--|---|------|-----------|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDV-D71T3/N1-C | | |
| COOLING CAPACITY | 7.1kW | | |
| HEATING CAPACITY | 8.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.5A/5.0A</td> </tr> </table> | MAX. | 0.5A/5.0A |
| MAX. | 0.5A/5.0A | | |
| NET WEIGHT | 21kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDV-D45Q1/N1-C

| | | | |
|--|--|------|------------|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D45T3/N1-C | | |
| COOLING CAPACITY | 4.5kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.36A/5.0A</td> </tr> </table> | MAX. | 0.36A/5.0A |
| MAX. | 0.36A/5.0A | | |
| NET WEIGHT | 17.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDVC-D71T3/N1-C

| | | | |
|--|---|------|-----------|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D71T3/N1-C | | |
| COOLING CAPACITY | 7.1kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.5A/5.0A</td> </tr> </table> | MAX. | 0.5A/5.0A |
| MAX. | 0.5A/5.0A | | |
| NET WEIGHT | 21kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDV-D56Q1/N1-C

| | | | |
|--|--|------|------------|
| | | | |
| LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MDVC-D56T3/N1-C | | |
| COOLING CAPACITY | 5.6kW | | |
| HEATING CAPACITY | — | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.36A/5.0A</td> </tr> </table> | MAX. | 0.36A/5.0A |
| MAX. | 0.36A/5.0A | | |
| NET WEIGHT | 17.5kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH 4.4MPa | | |
| | LOW 2.6MPa | | |
| | | | |

MDV-D71Q1/N1-C

| | | | | | |
|---|--|----------|---|----------|---|
| | | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDV-D45Q1/N1-C | | | | |
| COOLING CAPACITY | 4.5kW | | | | |
| HEATING CAPACITY | 5.0kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0" style="display: inline-table;"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="border: none; padding: 0 5px;">=</td> <td rowspan="2" style="border: none;">0.37A/5A</td> </tr> <tr> <td style="text-align: center;">—</td> </tr> </table> | MAX. | = | 0.37A/5A | — |
| MAX. | = | 0.37A/5A | | | |
| — | | | | | |
| NET WEIGHT | 31.5kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

| | | | | | |
|---|--|----------|---|----------|---|
| | | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDV-D56Q1/N1-C | | | | |
| COOLING CAPACITY | 5.6kW | | | | |
| HEATING CAPACITY | 6.3kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0" style="display: inline-table;"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="border: none; padding: 0 5px;">=</td> <td rowspan="2" style="border: none;">0.39A/5A</td> </tr> <tr> <td style="text-align: center;">—</td> </tr> </table> | MAX. | = | 0.39A/5A | — |
| MAX. | = | 0.39A/5A | | | |
| — | | | | | |
| NET WEIGHT | 31.5kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

| | | | | | |
|---|--|----------|---|----------|---|
| | | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDV-D71Q1/N1-C | | | | |
| COOLING CAPACITY | 7.1kW | | | | |
| HEATING CAPACITY | 8.0kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0" style="display: inline-table;"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="border: none; padding: 0 5px;">=</td> <td rowspan="2" style="border: none;">0.41A/5A</td> </tr> <tr> <td style="text-align: center;">—</td> </tr> </table> | MAX. | = | 0.41A/5A | — |
| MAX. | = | 0.41A/5A | | | |
| — | | | | | |
| NET WEIGHT | 32.5kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

MDVC-D45Q1/N1-C

| | | | | | |
|---|--|----------|---|----------|---|
| | | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDVC-D45Q1/N1-C | | | | |
| COOLING CAPACITY | 4.5kW | | | | |
| HEATING CAPACITY | — | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0" style="display: inline-table;"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="border: none; padding: 0 5px;">=</td> <td rowspan="2" style="border: none;">0.37A/5A</td> </tr> <tr> <td style="text-align: center;">—</td> </tr> </table> | MAX. | = | 0.37A/5A | — |
| MAX. | = | 0.37A/5A | | | |
| — | | | | | |
| NET WEIGHT | 31.5kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

MDVC-D56Q1/N1-C

| | | | | | |
|---|--|----------|---|----------|---|
| | | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDVC-D56Q1/N1-C | | | | |
| COOLING CAPACITY | 5.6kW | | | | |
| HEATING CAPACITY | — | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0" style="display: inline-table;"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="border: none; padding: 0 5px;">=</td> <td rowspan="2" style="border: none;">0.39A/5A</td> </tr> <tr> <td style="text-align: center;">—</td> </tr> </table> | MAX. | = | 0.39A/5A | — |
| MAX. | = | 0.39A/5A | | | |
| — | | | | | |
| NET WEIGHT | 31.5kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

MDVC-D71Q1/N1-C

| | | | | | |
|---|--|----------|---|----------|---|
| | | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MDVC-D71Q1/N1-C | | | | |
| COOLING CAPACITY | 7.1kW | | | | |
| HEATING CAPACITY | — | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0" style="display: inline-table;"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="border: none; padding: 0 5px;">=</td> <td rowspan="2" style="border: none;">0.41A/5A</td> </tr> <tr> <td style="text-align: center;">—</td> </tr> </table> | MAX. | = | 0.41A/5A | — |
| MAX. | = | 0.41A/5A | | | |
| — | | | | | |
| NET WEIGHT | 32.5kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

| | | |
|--|-----------------|------------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-28Q4/DHN1-D | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | ———— | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.32A/5.0A |
| NET WEIGHT | 21.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|-----------------|------------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-36Q4/DHN1-D | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | ———— | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.32A/5.0A |
| NET WEIGHT | 21.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|-----------------|------------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-45Q4/DHN1-D | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | ———— | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.34A/5.0A |
| NET WEIGHT | 24kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-56Q4/DHN1-D

| | | |
|--|-----------------|------------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-56Q4/DHN1-D | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | ———— | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.34A/5.0A |
| NET WEIGHT | 24kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-71Q4/DHN1-D

| | | |
|--|-----------------|------------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-71Q4/DHN1-D | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | ———— | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.36A/5.0A |
| NET WEIGHT | 24kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-80Q4/DHN1-D

| | | |
|--|-----------------|------------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-80Q4/DHN1-D | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | ———— | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.37A/5.0A |
| NET WEIGHT | 24kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-90Q4/DHN1-D

MIC-100Q4/DHN1-D

MIC-112Q4/DHN1-D

| | | |
|--|-----------------|--------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-90Q4/DHN1-D | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.82A/5.0A | |
| NET WEIGHT | 27.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|------------------|--------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-100Q4/DHN1-D | |
| COOLING CAPACITY | 10.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.82A/5.0A | |
| NET WEIGHT | 27.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|------------------|--------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-112Q4/DHN1-D | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.82A/5.0A | |
| NET WEIGHT | 27.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-140Q4/DHN1-D

| | | |
|--|------------------|--------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-140Q4/DHN1-D | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.98A/5.0A | |
| NET WEIGHT | 30kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-28Q4/DHN1-D

| | | |
|--|----------------|--------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-28Q4/DHN1-D | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.32A/5.0A | |
| NET WEIGHT | 21.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-36Q4/DHN1-D

| | | |
|--|----------------|--------|
| | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36Q4/DHN1-D | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.32A/5.0A | |
| NET WEIGHT | 21.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-45Q4/DHN1-D

MI-56Q4/DHN1-D

MI-71Q4/DHN1-D

| | |
|--|---------------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-45Q4/DHN1-D |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.34A/5.0A |
| NET WEIGHT | 24kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa LOW 2.6MPa |
| | |

| | |
|--|---------------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-56Q4/DHN1-D |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | 6.3kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.34A/5.0A |
| NET WEIGHT | 24kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa LOW 2.6MPa |
| | |

| | |
|--|---------------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-71Q4/DHN1-D |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | 8.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.36A/5.0A |
| NET WEIGHT | 24kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa LOW 2.6MPa |
| | |

MI-80Q4/DHN1-D

| | |
|--|---------------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-80Q4/DHN1-D |
| COOLING CAPACITY | 8.0kW |
| HEATING CAPACITY | 9.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.37A/5.0A |
| NET WEIGHT | 24kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa LOW 2.6MPa |
| | |

MI-90Q4/DHN1-D

| | |
|--|---------------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-90Q4/DHN1-D |
| COOLING CAPACITY | 9.0kW |
| HEATING CAPACITY | 10.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.82A/5.0A |
| NET WEIGHT | 27.4kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa LOW 2.6MPa |
| | |

MI-100Q4/DHN1-D

| | |
|--|---------------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-100Q4/DHN1-D |
| COOLING CAPACITY | 10.0kW |
| HEATING CAPACITY | 11.1kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.82A/5.0A |
| NET WEIGHT | 27.4kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa LOW 2.6MPa |
| | |

MI-112Q4/DHN1-D

MI-140Q4/DHN1-D

| | | | | |
|---|---|------|------------|--|
| | | | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-112Q4/DHN1-D | | | |
| COOLING CAPACITY | 11.2kW | | | |
| HEATING CAPACITY | 12.5kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.82A/5.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.82A/5.0A | |
| MAX. | 0.82A/5.0A | | | |
| | | | | |
| NET WEIGHT | 27.4kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

| | | | | |
|---|---|------|------------|--|
| | | | | |
| DC FAN MOTOR FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-140Q4/DHN1-D | | | |
| COOLING CAPACITY | 14.0kW | | | |
| HEATING CAPACITY | 15.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.98A/5.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.98A/5.0A | |
| MAX. | 0.98A/5.0A | | | |
| | | | | |
| NET WEIGHT | 30kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI-15Q4/DHN1-A3

| | | | | |
|--|---|------|------------|--|
| | | | | |
| DC FAN MOTOR FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-15Q4/DHN1-A3 | | | |
| COOLING CAPACITY | 1.5kW | | | |
| HEATING CAPACITY | 1.7kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.23A/5.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.23A/5.0A | |
| MAX. | 0.23A/5.0A | | | |
| | | | | |
| NET WEIGHT | 16kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI-22Q4/DHN1-A3

| | | | | |
|--|---|------|------------|--|
| | | | | |
| DC FAN MOTOR FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-22Q4/DHN1-A3 | | | |
| COOLING CAPACITY | 2.2kW | | | |
| HEATING CAPACITY | 2.4kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.26A/5.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.26A/5.0A | |
| MAX. | 0.26A/5.0A | | | |
| | | | | |
| NET WEIGHT | 16kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI-28Q4/DHN1-A3

| | | | | |
|--|---|------|------------|--|
| | | | | |
| DC FAN MOTOR FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-28Q4/DHN1-A3 | | | |
| COOLING CAPACITY | 2.8kW | | | |
| HEATING CAPACITY | 3.2kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.26A/5.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.26A/5.0A | |
| MAX. | 0.26A/5.0A | | | |
| | | | | |
| NET WEIGHT | 16kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI-36Q4/DHN1-A3

MI-45Q4/DHN1-A3

MIC-15G/DHN1-S

| | |
|--|------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-36Q4/DHN1-A3 |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.28A/5.0A |
| NET WEIGHT | 17.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|------------------|
| | |
| DC FAN MOTOR FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-45Q4/DHN1-A3 |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.28A/5.0A |
| NET WEIGHT | 17.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-15G/DHN1-S |
| COOLING CAPACITY | 1.5kW |
| HEATING CAPACITY | ———— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.25A/5A |
| NET WEIGHT | 11.6kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-22G/DHN1-S

| | |
|--|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-22G/DHN1-S |
| COOLING CAPACITY | 2.2kW |
| HEATING CAPACITY | ———— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.28A/5A |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-28G/DHN1-S

| | |
|--|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-28G/DHN1-S |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | ———— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.28A/5A |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-36G/DHN1-S

| | |
|--|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-36G/DHN1-S |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | ———— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.31A/5A |
| NET WEIGHT | 12kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-45G/DHN1-S

MIC-56G/DHN1-S

MIC-71G/DHN1-R3

| | |
|--|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-45G/DHN1-S |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | —— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.35A/5A |
| NET WEIGHT | 14.4kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-56G/DHN1-S |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | —— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.41A/5A |
| NET WEIGHT | 14.4kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|-----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-71G/DHN1-R3 |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | —— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.49A/5.0A |
| NET WEIGHT | 18.3kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-80G/DHN1-R3

| | |
|--|-----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-80G/DHN1-R3 |
| COOLING CAPACITY | 8.0kW |
| HEATING CAPACITY | —— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.68A/5A |
| NET WEIGHT | 18.3kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-90G/DHN1-R3

| | |
|--|-----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-90G/DHN1-R3 |
| COOLING CAPACITY | 9.0kW |
| HEATING CAPACITY | —— |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.68A/5A |
| NET WEIGHT | 18.3kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-15G/DHN1-S

| | |
|--|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-15G/DHN1-S |
| COOLING CAPACITY | 1.5kW |
| HEATING CAPACITY | 1.7kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.25A/5A |
| NET WEIGHT | 11.6kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-22G/DHN1-S

MI-28G/DHN1-S

MI-36G/DHN1-S

| | | | | | |
|---|---|----------|---|----------|---|
| | | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-22G/DHN1-S | | | | |
| COOLING CAPACITY | 2.2kW | | | | |
| HEATING CAPACITY | 2.4kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">=</td> <td rowspan="2">0.28A/5A</td> </tr> <tr> <td style="text-align: center;">=</td> </tr> </table> | MAX. | = | 0.28A/5A | = |
| MAX. | = | 0.28A/5A | | | |
| = | | | | | |
| NET WEIGHT | 12kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

| | | | | | |
|---|---|----------|---|----------|---|
| | | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-28G/DHN1-S | | | | |
| COOLING CAPACITY | 2.8kW | | | | |
| HEATING CAPACITY | 3.2kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">=</td> <td rowspan="2">0.28A/5A</td> </tr> <tr> <td style="text-align: center;">=</td> </tr> </table> | MAX. | = | 0.28A/5A | = |
| MAX. | = | 0.28A/5A | | | |
| = | | | | | |
| NET WEIGHT | 12kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

| | | | | | |
|---|---|----------|---|----------|---|
| | | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-36G/DHN1-S | | | | |
| COOLING CAPACITY | 3.6kW | | | | |
| HEATING CAPACITY | 4.0kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">=</td> <td rowspan="2">0.31A/5A</td> </tr> <tr> <td style="text-align: center;">=</td> </tr> </table> | MAX. | = | 0.31A/5A | = |
| MAX. | = | 0.31A/5A | | | |
| = | | | | | |
| NET WEIGHT | 12kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

MI-45G/DHN1-S

| | | | | | |
|---|---|----------|---|----------|---|
| | | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-45G/DHN1-S | | | | |
| COOLING CAPACITY | 4.5kW | | | | |
| HEATING CAPACITY | 5.0kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">=</td> <td rowspan="2">0.35A/5A</td> </tr> <tr> <td style="text-align: center;">=</td> </tr> </table> | MAX. | = | 0.35A/5A | = |
| MAX. | = | 0.35A/5A | | | |
| = | | | | | |
| NET WEIGHT | 14.4kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

MI-56G/DHN1-S

| | | | | | |
|---|---|----------|---|----------|---|
| | | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-56G/DHN1-S | | | | |
| COOLING CAPACITY | 5.6kW | | | | |
| HEATING CAPACITY | 6.3kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">=</td> <td rowspan="2">0.41A/5A</td> </tr> <tr> <td style="text-align: center;">=</td> </tr> </table> | MAX. | = | 0.41A/5A | = |
| MAX. | = | 0.41A/5A | | | |
| = | | | | | |
| NET WEIGHT | 14.4kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

MI-71G/DHN1-R3

| | | | | | |
|---|---|------------|---|------------|---|
| | | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-71G/DHN1-R3 | | | | |
| COOLING CAPACITY | 7.1kW | | | | |
| HEATING CAPACITY | 8.0kW | | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">=</td> <td rowspan="2">0.49A/5.0A</td> </tr> <tr> <td style="text-align: center;">=</td> </tr> </table> | MAX. | = | 0.49A/5.0A | = |
| MAX. | = | 0.49A/5.0A | | | |
| = | | | | | |
| NET WEIGHT | 18.3kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | HIGH | 4.4MPa | | | |
| | LOW | 2.6MPa | | | |
| | | | | | |

MI-80G/DHN1-R3

MI-90G/DHN1-R3

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-80G/DHN1-R3 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.68A/5A |
| NET WEIGHT | 18.3kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-90G/DHN1-R3 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.68A/5A |
| NET WEIGHT | 18.3kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-36DL/DHN1-C

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36DL/DHN1-C | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.32A/5.0A |
| NET WEIGHT | 25kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-45DL/DHN1-C

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45DL/DHN1-C | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.89A/5.0A |
| NET WEIGHT | 27kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-56DL/DHN1-C

MI-71DL/DHN1-C

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-56DL/DHN1-C | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.89A/5.0A |
| NET WEIGHT | 27kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-71DL/DHN1-C | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.89A/5.0A |
| NET WEIGHT | 27kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-80DL/DHN1-C

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-80DL/DHN1-C | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.14A/5.0A |
| NET WEIGHT | 33.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-90DL/DHN1-C

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-90DL/DHN1-C | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.14A/5.0A |
| NET WEIGHT | 33.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-112DL/DHN1-C

MI-140DL/DHN1-C

| | | |
|---|-----------------|--------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-112DL/DHN1-C | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 1.25A/5.0A | |
| NET WEIGHT | 49kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|-----------------|--------|
| | | |
| DC FAN MOTOR CEILING & FLOOR TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-140DL/DHN1-C | |
| COOLING CAPACITY | 14kW | |
| HEATING CAPACITY | 15kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 1.25A/5.0A | |
| NET WEIGHT | 49kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-15T2/DHN1-DA5

| | | |
|---|------------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-15T2/DHN1-DA5 | |
| COOLING CAPACITY | 1.5kW | |
| HEATING CAPACITY | 1.7kW | |
| POWER SOURCE | 220-240V ~ 50Hz | |
| RATED CURRENT | 0.5A/5.0A | |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-22T2/DHN1-DA5

| | | |
|---|------------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-22T2/DHN1-DA5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V ~ 50Hz | |
| RATED CURRENT | 0.5A/5.0A | |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-28T2/DHN1-DA5

| | | |
|---|------------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-28T2/DHN1-DA5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V ~ 50Hz | |
| RATED CURRENT | 0.5A/5.0A | |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-36T2/DHN1-DA5

MI-45T2/DHN1-DA5

MI-56T2/DHN1-DA5

| | |
|--|------------------|
| | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-36T2/DHN1-DA5 |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.5A/5.0A |
| NET WEIGHT | 17.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|------------------|
| | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-45T2/DHN1-DA5 |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW |
| POWER SUPPLY | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.7A/5.0A |
| NET WEIGHT | 21.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|------------------|
| | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-56T2/DHN1-DA5 |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | 6.3kW |
| POWER SUPPLY | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.7A/5.0A |
| NET WEIGHT | 21.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-71T2/DHN1-DA5

| | |
|--|------------------|
| | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-71T2/DHN1-DA5 |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | 8.0kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.8A/5.0A |
| NET WEIGHT | 26.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-80T2/DHN1-BA5

| | |
|--|------------------|
| | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-80T2/DHN1-BA5 |
| COOLING CAPACITY | 8.0kW |
| HEATING CAPACITY | 9.0kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 1.1A/5.0A |
| NET WEIGHT | 36.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-90T2/DHN1-BA5

MI-112T2/DHN1-BA5

MI-140T2/DHN1-BA5

| | | | | | |
|--|--|------|-----------|-----|--------|
| | | | | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-90T2/DHN1-BA5 | | | | |
| COOLING CAPACITY | 9.0kW | | | | |
| HEATING CAPACITY | 10.0kW | | | | |
| POWER SOURCE | 220-240V ~ 50Hz | | | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>1.2A/5.0A</td> </tr> </table> | MAX. | 1.2A/5.0A | | |
| MAX. | 1.2A/5.0A | | | | |
| NET WEIGHT | 37kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="1"> <tr> <td>HIGH</td> <td>4.4MPa</td> </tr> <tr> <td>LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

| | | | | | |
|--|--|------|-----------|-----|--------|
| | | | | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-112T2/DHN1-BA5 | | | | |
| COOLING CAPACITY | 11.2kW | | | | |
| HEATING CAPACITY | 12.5kW | | | | |
| POWER SOURCE | 220-240V ~ 50Hz | | | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>2.1A/5.0A</td> </tr> </table> | MAX. | 2.1A/5.0A | | |
| MAX. | 2.1A/5.0A | | | | |
| NET WEIGHT | 37kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="1"> <tr> <td>HIGH</td> <td>4.4MPa</td> </tr> <tr> <td>LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

| | | | | | |
|--|--|------|-----------|-----|--------|
| | | | | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-140T2/DHN1-BA5 | | | | |
| COOLING CAPACITY | 14.0kW | | | | |
| HEATING CAPACITY | 15.5kW | | | | |
| POWER SOURCE | 220-240V ~ 50Hz | | | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>2.0A/5.0A</td> </tr> </table> | MAX. | 2.0A/5.0A | | |
| MAX. | 2.0A/5.0A | | | | |
| NET WEIGHT | 46.5kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="1"> <tr> <td>HIGH</td> <td>4.4MPa</td> </tr> <tr> <td>LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MI-18T3/DHN1-C

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| DC FAN MOTOR LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-18T3/DHN1-C | | | | |
| COOLING CAPACITY | 1.8kW | | | | |
| HEATING CAPACITY | 2.2kW | | | | |
| POWER SOURCE | 220-240V ~ 50Hz | | | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.5A/5.0A</td> </tr> </table> | MAX. | 0.5A/5.0A | | |
| MAX. | 0.5A/5.0A | | | | |
| NET WEIGHT | 14 kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="1"> <tr> <td>HIGH</td> <td>4.4MPa</td> </tr> <tr> <td>LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MI-22T3/DHN1-C

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| DC FAN MOTOR LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-22T3/DHN1-C | | | | |
| COOLING CAPACITY | 2.2kW | | | | |
| HEATING CAPACITY | 2.6kW | | | | |
| POWER SOURCE | 220-240V ~ 50Hz | | | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.5A/5.0A</td> </tr> </table> | MAX. | 0.5A/5.0A | | |
| MAX. | 0.5A/5.0A | | | | |
| NET WEIGHT | 14 kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="1"> <tr> <td>HIGH</td> <td>4.4MPa</td> </tr> <tr> <td>LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MI-28T3/DHN1-C

| | | | | | |
|---|--|------|-----------|-----|--------|
| | | | | | |
| DC FAN MOTOR LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | | | | |
| MODEL | MI-28T3/DHN1-C | | | | |
| COOLING CAPACITY | 2.8kW | | | | |
| HEATING CAPACITY | 3.2kW | | | | |
| POWER SOURCE | 220-240V ~ 50Hz | | | | |
| RATED CURRENT | <table border="1"> <tr> <td>MAX.</td> <td>0.5A/5.0A</td> </tr> </table> | MAX. | 0.5A/5.0A | | |
| MAX. | 0.5A/5.0A | | | | |
| NET WEIGHT | 14 kg | | | | |
| REFRIGERANT | R410A | | | | |
| PS | <table border="1"> <tr> <td>HIGH</td> <td>4.4MPa</td> </tr> <tr> <td>LOW</td> <td>2.6MPa</td> </tr> </table> | HIGH | 4.4MPa | LOW | 2.6MPa |
| HIGH | 4.4MPa | | | | |
| LOW | 2.6MPa | | | | |
| | | | | | |

MI-36T3/DHN1-C

MI-45T3/DHN1-C

MI-56T3/DHN1-C

| | |
|---|-----------------|
| | |
| DC FAN MOTOR LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-36T3/DHN1-C |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.5A/5.0A |
| NET WEIGHT | 14 kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|---|-----------------|
| | |
| DC FAN MOTOR LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-45T3/DHN1-C |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.8A/5.0A |
| NET WEIGHT | 17 kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|---|-----------------|
| | |
| DC FAN MOTOR LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-56T3/DHN1-C |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | 6.3kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.8A/5.0A |
| NET WEIGHT | 17 kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-71T3/DHN1-C

| | |
|---|-----------------|
| | |
| DC FAN MOTOR LOW STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-71T3/DHN1-C |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | 8.0kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.8A/5.0A |
| NET WEIGHT | 21 kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-22Z/DHN1-F4

| | |
|---|-----------------|
| | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-22Z/DHN1-F4 |
| COOLING CAPACITY | 2.2kW |
| HEATING CAPACITY | 2.4kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.29A/5A |
| NET WEIGHT | 29kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-28Z/DHN1-F4

| | |
|---|-----------------|
| | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-28Z/DHN1-F4 |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | 3.2kW |
| POWER SOURCE | 220-240V ~ 50Hz |
| RATED CURRENT | MAX. 0.32A/5A |
| NET WEIGHT | 29kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI-36Z/DHN1-F4

MI-45Z/DHN1-F4

MI-56Z/DHN1-F4

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36Z/DHN1-F4 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.33A/5A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45Z/DHN1-F4 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.35A/5A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-56Z/DHN1-F4 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.55A/5A |
| NET WEIGHT | 40kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-71Z/DHN1-F4

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-71Z/DHN1-F4 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.81A/5A |
| NET WEIGHT | 40kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-80Z/DHN1-F4

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-80Z/DHN1-F4 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.82A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-22Z/DHN1-F5

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-22Z/DHN1-F5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.29A/5A |
| NET WEIGHT | 27.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-28Z/DHN1-F5

MI-36Z/DHN1-F5

MI-45Z/DHN1-F5

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-28Z/DHN1-F5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.32A/5A |
| NET WEIGHT | 27.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36Z/DHN1-F5 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.33A/5A |
| NET WEIGHT | 33kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45Z/DHN1-F5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.35A/5A |
| NET WEIGHT | 33kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-56Z/DHN1-F5

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-56Z/DHN1-F5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.55A/5A |
| NET WEIGHT | 38.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-71Z/DHN1-F5

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-71Z/DHN1-F5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.81A/5A |
| NET WEIGHT | 38.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-80Z/DHN1-F5

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-80Z/DHN1-F5 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | | 0.82A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-22Z/DHN1-F3B

MI-28Z/DHN1-F3B

MI-36Z/DHN1-F3B

| | | |
|--|-----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-22Z/DHN1-F3B | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.29A/5A |
| NET WEIGHT | 21kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|-----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-28Z/DHN1-F3B | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.32A/5A |
| NET WEIGHT | 21kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|-----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36Z/DHN1-F3B | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.33A/5A |
| NET WEIGHT | 28kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-45Z/DHN1-F3B

| | | |
|--|-----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45Z/DHN1-F3B | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.35A/5A |
| NET WEIGHT | 28kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-56Z/DHN1-F3B

| | | |
|--|-----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-56Z/DHN1-F3B | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.55A/5A |
| NET WEIGHT | 32kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-71Z/DHN1-F3B

| | | |
|--|-----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-71Z/DHN1-F3B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.81A/5A |
| NET WEIGHT | 32kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-80Z/DHN1-F3B

MDV-D45Q1/N1-D

MDV-D56Q1/N1-D

| | | |
|--|-----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-80Z/DHN1-F3B | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.82A/5A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D45Q1/N1-D | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.27A/5A |
| NET WEIGHT | 18.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D56Q1/N1-D | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.32A/5A |
| NET WEIGHT | 18.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MDV-D71Q1/N1-D

| | | |
|--|----------------|----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MDV-D71Q1/N1-D | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.36A/5A |
| NET WEIGHT | 19.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-22G/N1-S

| | | |
|--|----------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-22G/N1-S | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.14A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-28G/N1-S

| | | |
|--|----------------|----------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-28G/N1-S | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.14A/5A |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-36G/N1-S

MI-45G/N1-S

MI-56G/N1-S

| | | |
|--|----------------|--------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36G/N1-S | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.14A/5A | |
| NET WEIGHT | 13kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|--------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45G/N1-S | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.20A/5A | |
| NET WEIGHT | 15.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|--------|
| | | |
| WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-56G/N1-S | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.20A/5A | |
| NET WEIGHT | 15.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-28Q4/N1-E



| | | | |
|---|----------------|--|--------|
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MI-28Q4/N1-E | | |
| COOLING CAPACITY | 2.8kW | | |
| HEATING CAPACITY | 3.2kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | 0.38A/5.0A | | |
| NET WEIGHT | 21.0kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | | 4.4MPa |
| | LOW | | 2.6MPa |



MI-36Q4/N1-E

| | | | |
|---|----------------|--|--------|
| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | |
| MODEL | MI-36Q4/N1-E | | |
| COOLING CAPACITY | 3.6kW | | |
| HEATING CAPACITY | 4.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | 0.38A/5.0A | | |
| NET WEIGHT | 21.0kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | | 4.4MPa |
| | LOW | | 2.6MPa |



MI-45Q4/N1-E

MI-56Q4/N1-E



| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|--|-----------------|--------|
| MODEL | MI-45Q4/N1-E | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.48A/5.0A | |
| NET WEIGHT | 23.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|   | | |

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|--|-----------------|--------|
| MODEL | MI-56Q4/N1-E | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.48A/5.0A | |
| NET WEIGHT | 23.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|   | | |



MI-71Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MI-71Q4/N1-E | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.48A/5.0A | |
| NET WEIGHT | 23.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|   | | |



MI-80Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|-----------------|--------|
| MODEL | MI-80Q4/N1-E | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.59A/5.0A | |
| NET WEIGHT | 23.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|   | | |

MI-90Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|--|-----------------|--------|
| MODEL | MI-90Q4/N1-E | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.98A/5.0A | |
| NET WEIGHT | 27.6kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|   | | |

MI-100Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|--|-----------------|--------|
| MODEL | MI-100Q4/N1-E | |
| COOLING CAPACITY | 10.0kW | |
| HEATING CAPACITY | 11.1kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. 0.99A/5.0A | |
| NET WEIGHT | 27.6kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
|   | | |

MI-112Q4/N1-E

MI-140Q4/N1-E

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|------------|---|----------------|------------|
| MODEL | MI-112Q4/N1-E | | MODEL | MI-140Q4/N1-E | |
| COOLING CAPACITY | 11.2kW | | COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 12.5kW | | HEATING CAPACITY | 16.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | | POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.99A/5.0A | RATED CURRENT | | 1.01A/5.0A |
| NET WEIGHT | 27.6kg | | NET WEIGHT | 30.0kg | |
| REFRIGERANT | R410A | | REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa | PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa | | LOW | 2.6MPa |
| | | | | | |
| | | | | | |

MI-22T2/N1-EA5

MI-28T2/N1-EA5

MI-36T2/N1-EA5

| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
|--|----------------|------------|
| MODEL | MI-22T2/N1-EA5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |
| | | |

| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
|--|----------------|------------|
| MODEL | MI-28T2/N1-EA5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.31A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |
| | | |

| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
|--|----------------|------------|
| MODEL | MI-36T2/N1-EA5 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.39A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |
| | | |

MI-45T2/N1-EA5

MI-56T2/N1-EA5

MI-71T2/N1-EA5

| | | |
|--|----------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45T2/N1-EA5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.46A/5.0A |
| NET WEIGHT | 22.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-56T2/N1-EA5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.46A/5.0A |
| NET WEIGHT | 22.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-71T2/N1-EA5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.47A/5.0A |
| NET WEIGHT | 27kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-80T2/N1-EA5

| | | |
|--|----------------|-----------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-80T2/N1-EA5 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.0A/5.0A |
| NET WEIGHT | 38kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-90T2/N1-EA5

| | | |
|--|----------------|-----------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-90T2/N1-EA5 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.0A/5.0A |
| NET WEIGHT | 39kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-112T2/N1-EA5

| | | |
|--|-----------------|-----------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-112T2/N1-EA5 | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.8A/5.0A |
| NET WEIGHT | 40kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-140T2/N1-EA5

MI-22Q4/N1-A3

MI-28Q4/N1-A3

| | | |
|--|-----------------|------------|
| | | |
| MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-140T2/N1-EA5 | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 15.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.55A/5.0A |
| NET WEIGHT | 49kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-22Q4/N1-A3 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5.0A |
| NET WEIGHT | 17kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-28Q4/N1-A3 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.22A/5.0A |
| NET WEIGHT | 17kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-36Q4/N1-A3

| | | |
|--|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36Q4/N1-A3 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.27A/5.0A |
| NET WEIGHT | 18.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-45Q4/N1-A3

| | | |
|--|----------------|------------|
| | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45Q4/N1-A3 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.27A/5.0A |
| NET WEIGHT | 18.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-280T1/DHN1-B

MI-250T1/DHN1-B

MI-200T1/DHN1-B

MI-160T1/DHN1-B

| | | | |
|--|-----------------|----------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-280T1/DHN1-B | | |
| COOLING CAPACITY | 28.0kW | | |
| HEATING CAPACITY | 31.5kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 7.5A/10A | |
| NET WEIGHT | 108kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|-----------------|----------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-250T1/DHN1-B | | |
| COOLING CAPACITY | 25.0kW | | |
| HEATING CAPACITY | 26.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 7.5A/10A | |
| NET WEIGHT | 108kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|-----------------|----------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-200T1/DHN1-B | | |
| COOLING CAPACITY | 20.0kW | | |
| HEATING CAPACITY | 22.5kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 7.5A/10A | |
| NET WEIGHT | 108kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

| | | | |
|--|-----------------|---------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-160T1/DHN1-B | | |
| COOLING CAPACITY | 16.0kW | | |
| HEATING CAPACITY | 17.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 4.5A/6A | |
| NET WEIGHT | 63kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MI-140T1/DHN1-B

| | | | |
|--|-----------------|---------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-140T1/DHN1-B | | |
| COOLING CAPACITY | 14.0kW | | |
| HEATING CAPACITY | 16.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 4.5A/6A | |
| NET WEIGHT | 63kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MI-112T1/DHN1-B

| | | | |
|--|-----------------|---------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-112T1/DHN1-B | | |
| COOLING CAPACITY | 11.2kW | | |
| HEATING CAPACITY | 12.5kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 3.6A/5A | |
| NET WEIGHT | 47kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MI-90T1/DHN1-B

| | | | |
|--|----------------|---------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-90T1/DHN1-B | | |
| COOLING CAPACITY | 9.0kW | | |
| HEATING CAPACITY | 10.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 2.4A/5A | |
| NET WEIGHT | 47kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MI-80T1/DHN1-B

| | | | |
|--|----------------|---------|--|
| | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | |
| MODEL | MI-80T1/DHN1-B | | |
| COOLING CAPACITY | 8.0kW | | |
| HEATING CAPACITY | 9.0kW | | |
| POWER SOURCE | 220-240V~ 50Hz | | |
| RATED CURRENT | MAX. | 1.7A/5A | |
| NET WEIGHT | 41kg | | |
| REFRIGERANT | R410A | | |
| PS | HIGH | 4.4MPa | |
| | LOW | 2.6MPa | |
| | | | |

MI-71T1/DHN1-B

| | | |
|--|----------------|---------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI-71T1/DHN1-B | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.7A/5A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-280T1/DHN1-FA

| | | |
|--|------------------|--------|
| | | |
| DC FAN MOTOR FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI-280T1/DHN1-FA | |
| COOLING CAPACITY | 28.0kW | |
| HEATING CAPACITY | 22.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 5A/10A |
| NET WEIGHT | 108kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-250T1/DHN1-FA

| | | |
|--|------------------|--------|
| | | |
| DC FAN MOTOR FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI-250T1/DHN1-FA | |
| COOLING CAPACITY | 25.0kW | |
| HEATING CAPACITY | 20.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 5A/10A |
| NET WEIGHT | 108kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-200T1/DHN1-FA

| | | |
|--|------------------|----------|
| | | |
| DC FAN MOTOR FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI-200T1/DHN1-FA | |
| COOLING CAPACITY | 20.0kW | |
| HEATING CAPACITY | 18.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 4.5A/10A |
| NET WEIGHT | 108kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-140T1/DHN1-FA

| | | |
|--|------------------|---------|
| | | |
| DC FAN MOTOR FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI-140T1/DHN1-FA | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 12.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.8A/5A |
| NET WEIGHT | 63kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-125T1/DHN1-FA

| | | |
|--|------------------|---------|
| | | |
| DC FAN MOTOR FRESH AIR HANDLING DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI-125T1/DHN1-FA | |
| COOLING CAPACITY | 12.5kW | |
| HEATING CAPACITY | 10.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.8A/5A |
| NET WEIGHT | 63kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-15T2/DHN1-DA5-AU

| | | |
|---|---------------------|-----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-15T2/DHN1-DA5-AU | |
| COOLING CAPACITY | 1.5kW | |
| HEATING CAPACITY | 1.7kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.5A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-18T2/DHN1-DA5-AU

| | | |
|---|---------------------|-----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-18T2/DHN1-DA5-AU | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | 2.2kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.5A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-22G/DHN1-M

MI-28G/DHN1-M

MI-36G/DHN1-M

| | | | | |
|---|---|--------|----------|--|
| | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-22G/DHN1-M | | | |
| COOLING CAPACITY | 2.2kW | | | |
| HEATING CAPACITY | 2.4kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="1"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">0.27A/5A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.27A/5A | |
| MAX. | 0.27A/5A | | | |
| | | | | |
| NET WEIGHT | 8.4kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

| | | | | |
|---|---|--------|----------|--|
| | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-28G/DHN1-M | | | |
| COOLING CAPACITY | 2.8kW | | | |
| HEATING CAPACITY | 3.2kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="1"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">0.31A/5A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.31A/5A | |
| MAX. | 0.31A/5A | | | |
| | | | | |
| NET WEIGHT | 9.5kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

| | | | | |
|---|---|--------|----------|--|
| | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-36G/DHN1-M | | | |
| COOLING CAPACITY | 3.6kW | | | |
| HEATING CAPACITY | 4.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="1"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">0.43A/5A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.43A/5A | |
| MAX. | 0.43A/5A | | | |
| | | | | |
| NET WEIGHT | 11.4kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI-45G/DHN1-M

| | | | | |
|---|---|--------|----------|--|
| | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-45G/DHN1-M | | | |
| COOLING CAPACITY | 4.5kW | | | |
| HEATING CAPACITY | 5.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="1"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">0.44A/5A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.44A/5A | |
| MAX. | 0.44A/5A | | | |
| | | | | |
| NET WEIGHT | 12.8kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI-56G/DHN1-M

| | | | | |
|---|---|--------|----------|--|
| | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-56G/DHN1-M | | | |
| COOLING CAPACITY | 5.6kW | | | |
| HEATING CAPACITY | 6.3kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="1"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">0.58A/5A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.58A/5A | |
| MAX. | 0.58A/5A | | | |
| | | | | |
| NET WEIGHT | 12.8kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI-71G/DHN1-M

| | | | | |
|---|--|--------|---------|--|
| | | | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI-71G/DHN1-M | | | |
| COOLING CAPACITY | 7.1kW | | | |
| HEATING CAPACITY | 8.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="1"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="text-align: center;">0.6A/5A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.6A/5A | |
| MAX. | 0.6A/5A | | | |
| | | | | |
| NET WEIGHT | 17kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI-80G/DHN1-M

MI-90G/DHN1-M

| | |
|---|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-80G/DHN1-M |
| COOLING CAPACITY | 8.0kW |
| HEATING CAPACITY | 9.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.6A/5A |
| NET WEIGHT | 17kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|---|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI-90G/DHN1-M |
| COOLING CAPACITY | 9.0kW |
| HEATING CAPACITY | 10.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.78A/5A |
| NET WEIGHT | 17kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-22G/DHN1-M

| | |
|---|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-22G/DHN1-M |
| COOLING CAPACITY | 2.2kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.27A/5A |
| NET WEIGHT | 8.4kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-28G/DHN1-M

| | |
|---|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-28G/DHN1-M |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.31A/5A |
| NET WEIGHT | 9.5kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-36G/DHN1-M

| | |
|---|----------------|
| | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | |
| MODEL | MIC-36G/DHN1-M |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | — |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 0.43A/5A |
| NET WEIGHT | 11.4kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MIC-45G/DHN1-M

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-45G/DHN1-M | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.44A/5A |
| NET WEIGHT | 12.3kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-56G/DHN1-M

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-56G/DHN1-M | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.58A/5A |
| NET WEIGHT | 12.3kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-71G/DHN1-M

| | | |
|---|----------------|---------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-71G/DHN1-M | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.6A/5A |
| NET WEIGHT | 16.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-80G/DHN1-M

| | | |
|---|----------------|---------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-80G/DHN1-M | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.6A/5A |
| NET WEIGHT | 17kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MIC-90G/DHN1-M

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MIC-90G/DHN1-M | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | — | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.78A/5A |
| NET WEIGHT | 17kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-18T2/DHN1-DA5

| | | |
|---|------------------|-----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-18T2/DHN1-DA5 | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | 2.2kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.5A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-22T2/DHN1-DA5

| | | |
|---|------------------|-----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-22T2/DHN1-DA5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.5A/5.0A |
| NET WEIGHT | 17.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-22T2/DHN1-EA5

| | | |
|---|------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-22T2/DHN1-EA5 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | | 1.0A/15A |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-28T2/DHN1-EA5

| | | |
|---|------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-28T2/DHN1-EA5 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | | 1.0A/15A |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-36T2/DHN1-EA5

| | | |
|---|------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-36T2/DHN1-EA5 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | | 1.0A/15A |
| NET WEIGHT | 22kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-45T2/DHN1-EA5

| | | |
|---|------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-45T2/DHN1-EA5 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | | 2.5A/15A |
| NET WEIGHT | 29kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-56T2/DHN1-EA5

MI-71T2/DHN1-EA5

MI-90T2/DHN1-EA5

| | | |
|---|------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-56T2/DHN1-EA5 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.5A/15A |
| NET WEIGHT | 29kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-71T2/DHN1-EA5 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.5A/15A |
| NET WEIGHT | 36kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-90T2/DHN1-EA5 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.5A/15A |
| NET WEIGHT | 37kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-112T2/DHN1-EA5

| | | |
|---|-------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-112T2/DHN1-EA5 | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 3.0A/15A |
| NET WEIGHT | 46kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI-140T2/DHN1-EA5

| | | |
|---|-------------------|----------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI-140T2/DHN1-EA5 | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 15.5kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 3.0A/15A |
| NET WEIGHT | 46kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

SMK-D140/MN1

| | | |
|--------------------------|----------------|----------|
| | | |
| WATER HEAT EXCHANGE | | |
| MODEL | SMK-D140/MN1 | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED INPUT | 10W | |
| WATER HEATING CAPACITY | 14.0kW | |
| OPERATION PANGE | AMBIENT | -20~35°C |
| | WATER SIDE | 20~45°C |
| NET WEIGHT | 55.0kg | |
| NOISE LEVEL | 26dB(A) | |
| PRESSURE OF WATER SYSTEM | 0.3MPa | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| RESISTANCE CLASS | IP20 | |

MI2-22T2DN1

| | | |
|---|----------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-22T2DN1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.74A/15.0A | |
| NET WEIGHT | 18.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-28T2DN1

| | | |
|---|----------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-28T2DN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.74A/15.0A | |
| NET WEIGHT | 18.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-36T2DN1

| | | |
|---|----------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-36T2DN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 0.77A/15.0A | |
| NET WEIGHT | 18.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-45T2DN1

| | | |
|---|----------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-45T2DN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 1.0A/15.0A | |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-56T2DN1

| | | |
|---|----------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-56T2DN1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 1.0A/15.0A | |
| NET WEIGHT | 21.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-71T2DN1

| | | |
|---|----------------|--------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-71T2DN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | 1.1A/15.0A | |
| NET WEIGHT | 25.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-80T2DN1

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-80T2DN1 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.3A/15.0A |
| NET WEIGHT | 36.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-90T2DN1

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-90T2DN1 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.3A/15.0A |
| NET WEIGHT | 37.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-112T2DN1

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-112T2DN1 | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.5A/15.0A |
| NET WEIGHT | 37.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-140T2DN1

| | | |
|---|----------------|------------|
| | | |
| DC FAN MOTOR MIDDLE STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-140T2DN1 | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 15.5kW | |
| POWER SUPPLY | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.6A/15.0A |
| NET WEIGHT | 46.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-22Q2DN1

| | | |
|--|----------------|-------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-22Q2DN1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.47A/15.0A |
| NET WEIGHT | 33.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-28Q2DN1

| | | |
|---|----------------|-------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-28Q2DN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.47A/15.0A |
| NET WEIGHT | 33.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-36Q2DN1

| | | |
|---|----------------|-------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-36Q2DN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.52A/15.0A |
| NET WEIGHT | 33.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-45Q2DN1

| | | |
|---|----------------|-------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-45Q2DN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.59A/15.0A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-56Q2DN1

| | | |
|---|----------------|-------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-56Q2DN1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.9 A/15.0A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-71Q2DN1

| | | |
|---|----------------|------------|
| | | |
| TWO-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-71Q2DN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.3A/15.0A |
| NET WEIGHT | 35kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-18Q1DN1

| | | |
|---|----------------|-----------|
| | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-18Q1DN1 | |
| COOLING CAPACITY | 1.8kW | |
| HEATING CAPACITY | 2.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.38A/15A |
| NET WEIGHT | 11.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-22Q1DN1

MI2-28Q1DN1

MI2-36Q1DN1

| | | | | |
|---|--|------|-----------|--|
| | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI2-22Q1DN1 | | | |
| COOLING CAPACITY | 2.2kW | | | |
| HEATING CAPACITY | 2.6kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.38A/15A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.38A/15A | |
| MAX. | 0.38A/15A | | | |
| | | | | |
| NET WEIGHT | 11.8kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

| | | | | |
|---|--|------|-----------|--|
| | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI2-28Q1DN1 | | | |
| COOLING CAPACITY | 2.8kW | | | |
| HEATING CAPACITY | 3.2kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.39A/15A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.39A/15A | |
| MAX. | 0.39A/15A | | | |
| | | | | |
| NET WEIGHT | 12.3kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

| | | | | |
|---|--|------|-----------|--|
| | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI2-36Q1DN1 | | | |
| COOLING CAPACITY | 3.6kW | | | |
| HEATING CAPACITY | 4.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.39A/15A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.39A/15A | |
| MAX. | 0.39A/15A | | | |
| | | | | |
| NET WEIGHT | 12.3kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI2-45Q1DN1

| | | | | |
|---|--|------|-----------|--|
| | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI2-45Q1DN1 | | | |
| COOLING CAPACITY | 4.5kW | | | |
| HEATING CAPACITY | 5.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.53A/15A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.53A/15A | |
| MAX. | 0.53A/15A | | | |
| | | | | |
| NET WEIGHT | 16.1kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI2-56Q1DN1

| | | | | |
|---|--|------|-----------|--|
| | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI2-56Q1DN1 | | | |
| COOLING CAPACITY | 5.6kW | | | |
| HEATING CAPACITY | 6.3kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.57A/15A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.57A/15A | |
| MAX. | 0.57A/15A | | | |
| | | | | |
| NET WEIGHT | 16.4kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI2-71Q1DN1

| | | | | |
|---|--|------|-----------|--|
| | | | | |
| ONE-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI2-71Q1DN1 | | | |
| COOLING CAPACITY | 7.1kW | | | |
| HEATING CAPACITY | 8.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.59A/15A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.59A/15A | |
| MAX. | 0.59A/15A | | | |
| | | | | |
| NET WEIGHT | 17.6kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH 4.4MPa | | | |
| | LOW 2.6MPa | | | |
| | | | | |

MI2-56DLDN1

| | |
|--|------------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-56DLDN1 |
| COOLING CAPACITY | 5.6kW |
| HEATING CAPACITY | 6.3kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.2A/15.0A |
| NET WEIGHT | 28kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-71DLDN1

| | |
|--|------------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-71DLDN1 |
| COOLING CAPACITY | 7.1kW |
| HEATING CAPACITY | 8.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.2A/15.0A |
| NET WEIGHT | 28kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-80DLDN1

| | |
|--|------------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-80DLDN1 |
| COOLING CAPACITY | 8.0kW |
| HEATING CAPACITY | 9.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.3A/15.0A |
| NET WEIGHT | 35kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-90DLDN1

| | |
|--|------------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-90DLDN1 |
| COOLING CAPACITY | 9.0kW |
| HEATING CAPACITY | 10.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.3A/15.0A |
| NET WEIGHT | 35kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-112DLDN1

| | |
|--|------------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-112DLDN1 |
| COOLING CAPACITY | 11.2kW |
| HEATING CAPACITY | 12.5kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.7A/15.0A |
| NET WEIGHT | 48kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-140DLDN1

| | |
|--|------------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-140DLDN1 |
| COOLING CAPACITY | 14.0kW |
| HEATING CAPACITY | 15.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | MAX. 1.7A/15.0A |
| NET WEIGHT | 48kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-36DLDN1

MI2-45DLDN1

| | |
|--|----------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-36DLDN1 |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | 0.45A/15.0A |
| NET WEIGHT | 27kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

| | |
|--|----------------|
| | |
| FLOOR AND CEILING AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-45DLDN1 |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | 1.2A/15.0A |
| NET WEIGHT | 28kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-28Q4CDN1

| | |
|---|----------------|
| | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-28Q4CDN1 |
| COOLING CAPACITY | 2.8kW |
| HEATING CAPACITY | 3.2kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | 0.43A/15A |
| NET WEIGHT | 18kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-22Q4CDN1

MI2-36Q4CDN1

| | |
|---|----------------|
| | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-36Q4CDN1 |
| COOLING CAPACITY | 3.6kW |
| HEATING CAPACITY | 4.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | 0.48A/15A |
| NET WEIGHT | 19.2kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-250FADN1

MI2-45Q4CDN1

| | |
|---|----------------|
| | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | |
| MODEL | MI2-45Q4CDN1 |
| COOLING CAPACITY | 4.5kW |
| HEATING CAPACITY | 5.0kW |
| POWER SOURCE | 220-240V~ 50Hz |
| RATED CURRENT | 0.48A/15A |
| NET WEIGHT | 19.2kg |
| REFRIGERANT | R410A |
| PS | HIGH 4.4MPa |
| | LOW 2.6MPa |
| | |

MI2-280FADN1

| | | | | |
|---|--|--------|-----------|--|
| | | | | |
| FOUR-WAY CASSETTE(COMPACT) AIR CONDITIONER INDOOR UNIT | | | | |
| MODEL | MI2-22Q4CDN1 | | | |
| COOLING CAPACITY | 2.2kW | | | |
| HEATING CAPACITY | 2.4kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">0.43A/15A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 0.43A/15A | |
| MAX. | 0.43A/15A | | | |
| | | | | |
| NET WEIGHT | 18kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

| | | | | |
|---|---|--------|------------|--|
| | | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | | |
| MODEL | MI2-250FADN1 | | | |
| COOLING CAPACITY | 25.0kW | | | |
| HEATING CAPACITY | 16.0kW | | | |
| POWER SOURCE | 220-240V- 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">5.2A/15.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 5.2A/15.0A | |
| MAX. | 5.2A/15.0A | | | |
| | | | | |
| NET WEIGHT | 130kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

| | | | | |
|---|---|--------|------------|--|
| | | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | | |
| MODEL | MI2-280FADN1 | | | |
| COOLING CAPACITY | 28.0kW | | | |
| HEATING CAPACITY | 18.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">5.2A/15.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 5.2A/15.0A | |
| MAX. | 5.2A/15.0A | | | |
| | | | | |
| NET WEIGHT | 130kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI2-125FADN1

| | | | | |
|---|---|--------|------------|--|
| | | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | | |
| MODEL | MI2-125FADN1 | | | |
| COOLING CAPACITY | 12.5kW | | | |
| HEATING CAPACITY | 10.5kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">3.5A/15.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 3.5A/15.0A | |
| MAX. | 3.5A/15.0A | | | |
| | | | | |
| NET WEIGHT | 68kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI2-140FADN1

| | | | | |
|---|---|--------|------------|--|
| | | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | | |
| MODEL | MI2-140FADN1 | | | |
| COOLING CAPACITY | 14.0kW | | | |
| HEATING CAPACITY | 12.0kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">3.5A/15.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 3.5A/15.0A | |
| MAX. | 3.5A/15.0A | | | |
| | | | | |
| NET WEIGHT | 68kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI2-200FADN1

| | | | | |
|---|---|--------|------------|--|
| | | | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | | | |
| MODEL | MI2-200FADN1 | | | |
| COOLING CAPACITY | 20.0kW | | | |
| HEATING CAPACITY | 12.8kW | | | |
| POWER SOURCE | 220-240V~ 50Hz | | | |
| RATED CURRENT | <table border="0"> <tr> <td style="text-align: center;">MAX.</td> <td rowspan="2" style="vertical-align: middle;">5.2A/15.0A</td> </tr> <tr> <td style="text-align: center;"></td> </tr> </table> | MAX. | 5.2A/15.0A | |
| MAX. | 5.2A/15.0A | | | |
| | | | | |
| NET WEIGHT | 130kg | | | |
| REFRIGERANT | R410A | | | |
| PS | HIGH | 4.4MPa | | |
| | LOW | 2.6MPa | | |
| | | | | |

MI2-71T1DN1

MI2-80T1DN1

MI2-90T1DN1

| | | |
|--|----------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOO- | | |
| MODEL | MI2-71T1DN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.1A/15.0A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOO- | | |
| MODEL | MI2-80T1DN1 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.1A/15.0A |
| NET WEIGHT | 41kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI2-90T1DN1 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.2A/15.0A |
| NET WEIGHT | 48kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-112T1DN1

| | | |
|--|----------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI2-112T1DN1 | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 2.9A/15.0A |
| NET WEIGHT | 48kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-140T1DN1

| | | |
|--|----------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI2-140T1DN1 | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 16.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 4.5A/15.0A |
| NET WEIGHT | 68kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-160T1DN1

| | | |
|--|----------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI2-160T1DN1 | |
| COOLING CAPACITY | 16.0kW | |
| HEATING CAPACITY | 17.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 4.7A/15.0A |
| NET WEIGHT | 68kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-200T1DN1

MI2-250T1DN1

MI2-280T1DN1

| | | |
|--|---------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI2-200T1DN1 | |
| COOLING CAPACITY | 20.0kW | |
| HEATING CAPACITY | 22.5kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 6.7A/15.0A |
| NET WEIGHT | 130kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-22F3DN1

| | | |
|--|---------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-22F3DN1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.49A/15A |
| NET WEIGHT | 21.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-28F3DN1

| | | |
|--|---------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI2-250T1DN1 | |
| COOLING CAPACITY | 25.0kW | |
| HEATING CAPACITY | 26.0kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 6.7A/15.0A |
| NET WEIGHT | 130kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-22F4DN1

| | | |
|--|---------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-22F4DN1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.49A/15A |
| NET WEIGHT | 28.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-28F4DN1

| | | |
|--|---------------|------------|
| | | |
| DC FAN MOTOR HIGH STATIC PRESSURE DUCT TYPE AIR CONDITIONER INDOORUNIT | | |
| MODEL | MI2-280T1DN1 | |
| COOLING CAPACITY | 28.0kW | |
| HEATING CAPACITY | 31.5kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 6.7A/15.0A |
| NET WEIGHT | 130kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-22F5DN1

| | | |
|--|---------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-22F5DN1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~50Hz | |
| RATED CURRENT | MAX. | 0.49A/15A |
| NET WEIGHT | 28.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-28F5DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-28F3DN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.55A/15A |
| NET WEIGHT | 21.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-36F3DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-36F3DN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.55A/15A |
| NET WEIGHT | 26.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-45F3DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-28F4DN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.55A/15A |
| NET WEIGHT | 28.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-36F4DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-36F4DN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.55A/15A |
| NET WEIGHT | 33.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-45F4DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-28F5DN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.55A/15A |
| NET WEIGHT | 28.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-36F5DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-36F5DN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | | 0.55A/15A |
| NET WEIGHT | 33.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-45F5DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-45F3DN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.55A/15A |
| NET WEIGHT | 26.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-56F3DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-56F3DN1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.85A/15A |
| NET WEIGHT | 31.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-71F3DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-45F4DN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.55A/15A |
| NET WEIGHT | 33.1kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-56F4DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-56F4DN1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.85A/15A |
| NET WEIGHT | 38.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-71F4DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-45F5DN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.55A/15A |
| NET WEIGHT | 33.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-56F5DN1

| | | |
|--|----------------|-----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-56F5DN1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.85A/15A |
| NET WEIGHT | 39.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-71F5DN1

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-71F3DN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.4A/15A |
| NET WEIGHT | 31.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-71F4DN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.4A/15A |
| NET WEIGHT | 38.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-71F5DN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.4A/15A |
| NET WEIGHT | 39.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-80F3DN1

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-80F3DN1 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.4A/15A |
| NET WEIGHT | 32.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-80F4DN1

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-80F4DN1 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.4A/15A |
| NET WEIGHT | 40.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-80F5DN1

| | | |
|--|----------------|----------|
| | | |
| DC FAN MOTOR FLOOR STANDING TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-80F5DN1 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.4A/15A |
| NET WEIGHT | 40.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-28Q4DN1

MI2-36Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|-------------|
| MODEL | MI2-28Q4DN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.41A/15.0A |
| NET WEIGHT | 21.3kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|-------------|
| MODEL | MI2-36Q4DN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.41A/15.0A |
| NET WEIGHT | 21.3kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-45Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|-------------|
| MODEL | MI2-45Q4DN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.56A/15.0A |
| NET WEIGHT | 23.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-56Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|-------------|
| MODEL | MI2-56Q4DN1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.56A/15.0A |
| NET WEIGHT | 23.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-71Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|-------------|
| MODEL | MI2-71Q4DN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.56A/15.0A |
| NET WEIGHT | 23.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-80Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|-------------|
| MODEL | MI2-80Q4DN1 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.76A/15.0A |
| NET WEIGHT | 23.2kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-90Q4DN1

MI2-100Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|-------------|
| MODEL | MI2-90Q4DN1 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.88A/15.0A |
| NET WEIGHT | 28.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|------------|
| MODEL | MI2-100Q4DN1 | |
| COOLING CAPACITY | 10.0kW | |
| HEATING CAPACITY | 11.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.0A/15.0A |
| NET WEIGHT | 28.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-112Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|------------|
| MODEL | MI2-112Q4DN1 | |
| COOLING CAPACITY | 11.2kW | |
| HEATING CAPACITY | 12.5kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.0A/15.0A |
| NET WEIGHT | 28.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-140Q4DN1

| FOUR-WAY CASSETTE AIR CONDITIONER INDOOR UNIT | | |
|---|----------------|------------|
| MODEL | MI2-140Q4DN1 | |
| COOLING CAPACITY | 14.0kW | |
| HEATING CAPACITY | 16.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.2A/15.0A |
| NET WEIGHT | 30.7kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |

MI2-22GDN1

MI2-28GDN1

MI2-36GDN1

| | | |
|---|----------------|-----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-22GDN1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.4kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.32A/15A |
| NET WEIGHT | 8.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-45GDN1

| | | |
|---|----------------|-----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-28GDN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.32A/15A |
| NET WEIGHT | 9.5kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-56GDN1

| | | |
|---|----------------|-----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-36GDN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.45A/15A |
| NET WEIGHT | 11.4kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-71GDN1

| | | |
|---|----------------|-----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-45GDN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.47A/15A |
| NET WEIGHT | 12.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-80GDN1

| | | |
|---|----------------|-----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-56GDN1 | |
| COOLING CAPACITY | 5.6kW | |
| HEATING CAPACITY | 6.3kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.58A/15A |
| NET WEIGHT | 12.8kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-90GDN1

| | | |
|---|----------------|-----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-71GDN1 | |
| COOLING CAPACITY | 7.1kW | |
| HEATING CAPACITY | 8.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.90A/15A |
| NET WEIGHT | 17.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-22ZDN1

| | | |
|---|----------------|-----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-80GDN1 | |
| COOLING CAPACITY | 8.0kW | |
| HEATING CAPACITY | 9.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.90A/15A |
| NET WEIGHT | 17.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|---|----------------|----------|
| | | |
| DC FAN MOTOR WALL-MOUNTED AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-90GDN1 | |
| COOLING CAPACITY | 9.0kW | |
| HEATING CAPACITY | 10.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 1.1A/15A |
| NET WEIGHT | 17.0kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

| | | |
|--|----------------|-----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-22ZDN1 | |
| COOLING CAPACITY | 2.2kW | |
| HEATING CAPACITY | 2.6kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.37A/15A |
| NET WEIGHT | 14kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-28ZDN1

| | | |
|--|----------------|----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-28ZDN1 | |
| COOLING CAPACITY | 2.8kW | |
| HEATING CAPACITY | 3.2kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.4A/15A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-36ZDN1

| | | |
|--|----------------|-----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-36ZDN1 | |
| COOLING CAPACITY | 3.6kW | |
| HEATING CAPACITY | 4.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.42A/15A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |

MI2-45ZDN1

| | | |
|--|----------------|-----------|
| | | |
| CONSOLE TYPE AIR CONDITIONER INDOOR UNIT | | |
| MODEL | MI2-45ZDN1 | |
| COOLING CAPACITY | 4.5kW | |
| HEATING CAPACITY | 5.0kW | |
| POWER SOURCE | 220-240V~ 50Hz | |
| RATED CURRENT | MAX. | 0.53A/15A |
| NET WEIGHT | 15kg | |
| REFRIGERANT | R410A | |
| PS | HIGH | 4.4MPa |
| | LOW | 2.6MPa |
| | | |