

Destinatar

Firma
Referinta
Adresa
Phone
Fax
E-mail

Expeditor

Cod articol : 60151025
Customer pos. no.:

Articol:
EVOPLUS D 120/360.80 M

Date pompa

Presiune nominala: 1600 kPa
Temperatura min. fluid: -10 °C
Temperatura max. fluid: 110 °C
EEI: ≤ 0,20

Presiune minima la nivelul apei:

Temperatura: °C 90 - 100
Presiune minima la nivelul apei: m 20 - 25

Date de functionare cerute

Debit:
Inaltime de pompare:
Fluid pompat (%):
Temperatura fluid: 20 °C
Densitate: 998.3 kg/m³
Vasozitate cinematica: 1.005 mm²/s
Presiune de vapori: 2.34 kPa

Date disponibile:

Debit:
Inaltime de pompare:

Materiale



Corp pompa: Cast iron 250 UNI ISO 185 - CTF
Rotor: Tecnopolimer
Arbore motor: Otel inox
Inel de etansare: EPDM
Carcasa motorului: Aluminu turnat la cald
Flansa de inchidere: Otel inox
Suport inel de echilibrare: Otel inox

Date motor

Marca: DAB
Putere absorbita P1: 1 X 1.235 kW
Tensiune nominala: 1~ 220-240 V 50 Hz
Curent nominal: 1 X 5.5 A
Grad de protectie: IP 44

Curve tolerance according to ISO 9906

Number of working motors: 1



Dimensiuni de gabarit mm

A1	19	D3	132	H4	253	L1	200
B	437	D4	80	I	130	L2	160
B1	96	H	515	I1	130	M	M12
B2	341	H1	480	I2	160		
D	200	H2	273	I3	58		
D1	160	H3	262	L	360		

Masa 55.8 kg

Racorduri pompa:

Partea cu aspiratia: DN 80 / PN 6
Partea cu refularea: DN 80 / PN 6

Destinatar


Expeditor

Firma
Referinta
Adresa
Phone
Fax
E-mail

EVOPLUS D 120/360.80 M

Number of working motors : 1

Curve tolerance according to ISO 9906



Partea cu aspiratia:

DN 80

PN 6

Partea cu refularea:

DN 80

PN 6

Debit :

Înaltime de pompare :

Viteza nominala:

2900 1/min

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_ID

OWNER_

ISSUE_DATE

01/31/2023



DESEN DIMENSIONAL

01/31/2023

Pagina 3 / 3



DAB PUMPS S.p.A.
Via Marco Polo, 14 - 35035 Mestrino (PD), Italy
Tel. +39 049 5125000 - Fax +39 049 5125950
www.dabpumps.com

Destinatar

Expeditor

Firma
Referinta
Adresa
Phone
Fax
E-mail

EVOPLUS D 120/360.80 M



Dimensiuni in mm

Racorduri pompa:

1	A1	19	H3	262			
2	B	437	H4	253			
3	B1	96	I	130			Aspiratie
4	B2	341	I1	130			DN 80
5	D	200	I2	160			PN 6
6	D1	160	I3	58			
7	D3	132	L	360			Refulare
8	D4	80	L1	200			DN 80
9	H	515	L2	160			PN 6
10	H1	480	M	M12			
11	H2	273					

MAIN_PROJECT_TITLE

BUSINESS_PROCESS_IC

OWNER_

ISSUE_DATE

01/31/2023