

Fisa Tehnica – plutitoare electrice tip TECNO 2:

| Cod Romstal | Denumire Romstal | Foto |
|-------------|---|--|
| 74P 0021 | PLUTITOR ELECTRIC CU CONTRAGREUTATE, TECNO 2, 10(8)A, 2m, cablu PVC 3x1 mm |  <p>The image displays three electric float switches (74P 0022, 74P 0021, and 74P 0024) arranged in a triangular formation. Each switch has a rectangular, rounded top plate in blue, red, or yellow, and a black base. They are connected by black PVC cables. Labels with arrows point to each switch: '74P 0022' points to the blue one, '74P 0021' points to the red one, and '74P 0024' points to the yellow one.</p> |
| 74P 0022 | PLUTITOR ELECTRIC FARA CONTRAGREUTATE, TECNO 2, 10(8)A, 5m, cablu PVC 3x1 mm | |
| 74P 0024 | PLUTITOR ELECTRIC FARA CONTRAGREUTATE, TECNO 2, 10(8)A, 10m, cablu PVC 3x1 mm | |

L'avanzata tecnologia costruttiva, la qualità dei componenti impiegati, il design ed i rigorosi controlli fanno del sensore elettromeccanico di livello TECNO un apparecchio di alta affidabilità e massima economia per applicazioni in impianti civili, industriali (pozzi, cisterne, fosse biologiche, fognature, impianti di depurazione) ed in tutti quei casi ove occorra il controllo del livello di liquidi non aggressivi. L'involucro esterno è costituito da polipropilene antiurto e viene sigillato a mezzo sovrastampaggio dello stesso materiale iniettato in pressione a 250°.

Disponibile in vari colori.

The advanced constructive technology, the quality of used components, the design and strict controls, make of the TECNO level regulator a highly reliable and economic equipment, for applications in civil and industrial plants (wells, tanks, cesspool, sewages) and in all that cases where it is necessary to control the level of non-aggressive liquids. The outer covering is constuted by an antishock polypropylene material, suitable to contact with foods and it is sealed by over moulding of the same material injected by pressure at 250° C. Available in various colors.



F.A.E.S.

| CARATTERISTICHE TECNICHE // SPECIFICATIONS | TECNO | TECNO 2 |
|--|-------------------------|-------------------------|
| Temperatura dell'acqua // Water temp | TL 50 | TL 50 |
| Temperatura ambiente // Ambient temp | T 50 | T 50 |
| Grado di protezione // Degree protection | Ip 68 | Ip 68 |
| Funzionamento // Type of action | 1 B | 1 B |
| PTI | 175 | 175 |
| Grado di imquinamento // Pollution degree | 2 | 2 |
| Frequenza // Frequency | 50/60 Hz | 50/60 Hz |
| Angolo di commutazione // Commutation angle | +/- 45 | +/- 45 |
| Tensione applicabile R-M // Type of load R-M | Carico resistivo 250Vac | Carico resistivo 250Vac |
| Massima portata contatti // Maximum pump running current | 10(4)A | 10(8)A |
| Dimensioni // Dimensions | mm 91x128x42 | mm 91x128x42 |
| Peso // Weight | g 155 | g 155 |
| Materiale corpo galleggiante // Floating switch shell material | Polipropilene Atox | Polipropilene Atox |
| Classe d'isolamento // Insulation class | I o II | I o II |

RIEMPIMENTO // FILLING

Utilizzare i terminali Nero e Blu.

In questa condizione il regolatore di livello chiude in basso al minimo livello. Variando la distanza tra galleggiante ed il contrappeso si ha la regolazione dei livelli MIN e MAX.

Use od the Black and Blue terminals.

In this condition, the level regulator closes the lower part at the minimum level. By changing the distance between the regulator and the counterweight, the control of the Min. and Max., levels is obtained.

CAVO STANDARD // STANDARD CABLE

PVC A05VV-F 3X1 \ H07RN-F 3G1 - 3G1,5 \ H07RN-F 3X1 \ H07RN-8F 3G1 \ AD8 3G1

NB: Specificare se viene utilizzato per RIEMPIMENTO O SVUOTAMENTO

NOTE: Please specify if needed for FILLING OR EMPTYING FUNCTION

SVUOTAMENTO // EMPTYING

Utilizzare i terminali Nero e Marrone.

In questa condizione il regolatore di livello chiude in alto al massimo livello. Variando la distanza tra galleggiante ed il contrappeso si ha la regolazione dei livelli MIN e MAX.

Use od the Black and Brown terminals.

In this condition, the level regulator closes the upper part at the maximum level. By changing the distance between the regulator and the counterweight, the control of the Min. and Max., levels is obtained.