

Declaration of Performance No. 360-3100-0899 REV 03

Declaration of Performance according to the Construction Products Regulation EU No. 305/2011

1. Unique identification code of the product type	Model(s): 1X-F8, 1X-F8-NL, 1X-F8-SC Brand(s): Aritech
2. Type, batch, or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4)	Each individual product is identified with a label containing a unique serial number.
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer	Control and indicating equipment. Power supply equipment.
4. Name, registered trade name, or registered trade mark and contact address of the manufacturer as required pursuant Article 11(5)	UTC CCS Manufacturing Polska sp. z o.o. ul. Kolejowa 24, 39 - 100 Ropczyce, Poland
5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2)	UTC Fire & Security B.V., Kelvinstraat 7, NL-6003 DH Weert, The Netherlands
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V	System 1
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard	BRE; 0832 performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the certificate(s) of constancy of performance: 0832-CPR-F0508
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:	Not applicable, see point 7
9. Declared performance: All requirements incl. all essential characteristics and corresponding performances as described in the harmonised technical specifications EN 54-2:1997 + A1:2006, EN 54-4:1997 + A1:2002 + A2:2006 for the intended use or uses indicated in point 3 above have been determined.	

Control and Indicating Equipment EN54-2

Essential characteristics	Performance	Harmonized technical specification
Performance under fire conditions	PASS	EN 54-2:1997 + AC:1999 + A1:2006
Response delay (response time to fire)	PASS	EN 54-2:1997 + AC:1999 + A1:2006
Operational reliability	PASS	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability, Temperature resistance	PASS	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability, Vibration resistance	PASS	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability, Electrical stability	PASS	EN 54-2:1997 + AC:1999 + A1:2006
Durability of operational reliability: humidity resistance	PASS	EN 54-2:1997 + AC:1999 + A1:2006

Power Supply Equipment EN54-4

Essential characteristics	Performance	Harmonized technical specification
Performance of power supply	PASS	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Operational reliability	PASS	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability: temperature resistance	PASS	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability: vibration resistance	PASS	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability: electrical stability	PASS	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006
Durability of operational reliability: humidity resistance	PASS	EN 54-4:1997 + AC:1999 + A1:2002 + A2:2006

10. The performance of the product identified in items 1 and 2 is in conformity with the declared performance in point 9.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed by: Charl Du Plessis, Engineering Lead, EMEA Verge de Guadalupe 3, Esplugues de Llobregat 08950, Barcelona, Spain	
Location: Esplugues de Llobregat	Date: December 6 th 2013

Regulation (EU) No. 305/2011 CPR Supplementary CE marking information



Identification of the Certification Body: 0832

Manufacturer:

UTC CCS Manufacturing Polska sp. z o.o. ul. Kolejowa 24, 39 - 100 Ropczyce, Poland

Last two digits of year CE mark was first placed: 09

Declaration of Performance (DoP) Number: 360-3100-0899 REV 03

EN 54-2:1997 + A1:2006, EN 54-4:1997 + A1:2002 + A2:2006

Unique identification of product type: See the product label for the product documentation part number and revision.

Intended use: See DoP point 3.

Essential characteristics: See DoP point 9.

EN: Get this document in your language from: / BG: Вземете този документ на български език от / CZ: Získat tento dokument ve Vašem jazyce od: / DA: Få dette dokument på dit sprog fra: / NL: Krijg dit document in uw taal van: / ET: Dokumendi eestikeelse versiooni leiata siit: / ES: Obtenga este documento en su idioma de: / FI: Hanki tämä asiakirja kielelläsi: / FR: Obtenez ce document dans votre langue de: / DE: Sie erhalten das Dokument in Ihrer Sprache von: / EL: Μπορείτε να παραλάβετε το έγγραφο στη γλώσσα σας από: / HU: A dokumentum megvásárolható a kívánt nyelven: / IT: Ottieni questo documento nella tua lingua da: / LV: Iegūstiet šo dokumentu savā valodā no: / LT: Gauti šį dokumentą jūsų kalba iš: / PL: Pobierz ten dokument w swoim języku z: / PT: Obtenha este documento no seu idioma a partir: / RO: Puteti obtine acest document in limba dumneavoastra de la: / SK: Získať tento dokument vo Vašom jazyku od: / SL: Spravi ta dokument v vašem jeziku od: / SV: Få detta dokument på ditt språk från:

<http://www.utcssecurityproducts.eu/dop/>

DoP.Requests@fs.utc.com

© 2013 UTC Fire & Security. All rights reserved.