



Construction Products Regulation: 305/2011

DECLARATION OF PERFORMANCE

No. 0832-CPR-F0355

1. Unique identification code of the product-type:

55000-023

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

55000-023 XP95 Intelligent UV/IR2 Flame Detector

To be used with the following bases: 45681-200, 45681-201

Each individual product is identified with a label containing a production date code with build standard number

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Fire Fighting Enterprises Limited
9 Hunting Gate, Wilbury Way, Hitchin, Hertfordshire, SG4 0TJ

Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR

5. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

 $7. \quad \text{In case of the declaration of performance concerning a construction product covered by a harmonized standard:} \\$

BRE Global Limited (Notified Body 0832) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the following Certificate of Constancy of Performance:

0832-CPR-F0355

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable

(v5)

A HALMA COMPANY



sessed to ISO 9001:2008 LPCB Cert No. 010





Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, P09 1JR, UK t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

9. Declared performance

Essential Characteristics	Standard EN54-10:2002 + A1:2005	Performance
Nominal activation conditions/Sensitivity Response delay (response time) and Performance under fire conditions	4.2,5.2 to 5.6	Pass
Operational reliability	4.3 to 4.9	Pass
Tolerance to supply voltage	5.16	Pass
Durability of operational reliability and response delay: temperature resistance	5.7,5.8	Pass
Durability of operational reliability: vibration resistance	5.12 to 5.15	Pass
Durability of operational reliability: humidity resistance	5.9,5.10	Pass
Durability of operational reliability: corrosion resistance	5.11	Pass
Durability of operational reliability: electrical resistance	5.17	Pass

The performance of the product identified above is in conformity with the performance and essential characteristics declared within this certificate. The declaration of performance is issued under the sole responsibility of Apollo Fire Detectors Limited.

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. Karl Westhead Technical Director

Place and Date of Issue: Havant - 06 February 2018

K West

