

# Declaration of Performance.

0832-CPR-1342

0832-CPD-1342

<b>Product Type</b>	AS2363		
<b>Type</b>	AS2363		
<b>Intended Use</b>	Fire detection and fire alarm systems installed in and around buildings.		
<b>Manufacturer :</b>	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
<b>Placed on market</b>	UTC Fire and Security B.V. Kelvinstraat 7, NL-6003 DH, Weert, The Netherlands.		
<b>System of assessment</b>	System 1		
<b>Notified Body</b>	BRE Global Limited		
<b>Accreditation Number</b>	0578		
<b>Type Testing</b>	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
<b>EC certificate of conformity</b>	0832-CPD-1342		
<b>Declared Performance</b>			
<b>Essential Characteristics</b>	<b>EN54-3 Subclause</b>	<b>Type A</b>	<b>Type B</b>
Reproducibility	5.2	Pass	Pass
Operational performance	5.3	Pass	Pass
Durability	5.4	Pass	Pass
Dry Heat (operational)	5.5	Pass	Pass
Dry Heat (endurance)	5.6	Pass	Pass
Cold (operational)	5.7	Pass	Pass
Damp heat, cyclic (operational)	5.8	Pass	Pass
Damp heat, steady state (endurance)	5.9	Pass	Pass
SO2 corrosion (endurance)	5.11	Pass	Pass
Shock (operational)	5.12	Pass	Pass
Impact (operational)	5.13	Pass	Pass
Vibration (operational)	5.14	Pass	Pass
Vibration (endurance)	5.15	Pass	Pass
Electrostatic discharge (operational)	5.16	Pass	Pass
Radiated electromagnetic fields (operational)	5.16	Pass	Pass
Voltage transients, fast transient bursts (operational)	5.16	Pass	Pass
Enclosure Protection	5.17	Pass	Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: Jim Ludwig      Function: Managing Director

Signature:



Place and date if issue: 19/06/2013