Declaration of Performance. 0832-CPR-1343

0832-CPD-1343

Product Type	AS2364
Type	AS2364 Deep Base – Red or White
Intended Use	Fire detection and fire alarm systems installed in and around buildings.
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW
Placed on market	UTC Fire and Security B.V. Kelvinstraat 7, NL-6003 DH, Weert, The Netherlands.
System of assessment	System 1
Notified Body	BRE Global Limited
Accreditation Number	0832
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.
EC certificate of conformity	0832-CPD-1343

Declared Performance

Essential Characteristics	**EN54-3 Subclause**	**Type A**	
Reproducibility	5.2	Pass	
Operational performance	5.3	Pass	
Durability	5.4	Pass	
Dry Heat (operational)	5.5	Pass	
Dry Heat (endurance)	5.6	Pass	
Cold (operational)	5.7	Pass	
Damp heat, cyclic (operational)	5.8	Pass	
Damp heat, steady state (endurance)	5.9	Pass	
SO2 corrosion (endurance)	5.11	Pass	
Shock (operational)	5.12	Pass	
Impact (operational)	5.13	Pass	
Vibration (operational)	5.14	Pass	
Vibration (endurance)	5.15	Pass	
Electrostatic discharge (operational)	5.16	Pass	
Radiated electromagnetic fields (operational)	5.16	Pass	
Voltage transients, fast transient bursts (operational)	5.16	Pass	
Enclosure Protection	5.17	Pass	

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: Chris Wright Function: Approvals Manager

Signature:

Place and date if issue: 02/05/2019

C.E.Wright

Digitally signed by Chris Wright
Date: 2019.05.21 15:21:40 +01'00'