



**MANUFACTURERS DECLARATION
OF CONFORMITY**

For

Product identification:

Model/type : ATS125x series BOM rev. level : See model listing
 Category (description) : 4 Door controller DGP Initial year affixing CE Mark : 2008
 Brand : GE Security

Manufacturer:

UTC Fire & Security B.V.
 Kelvinstraat 7
 6003 DH Weert
 The Netherlands
 Tel: +31 495 583000
 Fax: +31 495 550042

EU Representative:

--

Concerning	EMC	Safety
A sample of the product has been tested by:	Bicon UTC Fire & Security	Telefication
Test report reference:	CE_Qualification_Plan_ATS1251_ATS1252_ATS1253_ATS1254_update06Sep2010	
Applied standards:	EN50130-4/A2 (2003) EN61000-6-3 (2007) EN61000-3-2/A2 (2009) EN61000-3-3 (2008)	EN60950-1/A11 (2009)

Equipment class identifier (RF products falling under the scope of R&TTE)

Not Applicable None (class 1 product) (class 2 product)

Means of conformity

We declare under our sole responsibility that this product is in conformity with Directive 2004/108/EC (EMC), 2006/95/EC (LVD) and 93/68/EEC (Marking) based on test results using harmonized standards in accordance with the Directives mentioned.

Model listing (list of all product variants or models for which this declaration is valid)

Model	Description	BOM revision level
ATS1251	4-door access control DGP, 12V AUX and 12V Lock power, 52VA power supply and ATS1642 big enclosure	Pilot C0807333
ATS1252	4-door access control DGP, 12V AUX and 24V Lock power, 52VA power supply and ATS1642 big enclosure	Pilot C0807333
ATS1253	4-door access control DGP, 12V AUX and 12V Lock power, 52VA power supply and ATS1640 small enclosure	Pilot C0807333
ATS1254	4-door access control DGP, 12V AUX and 24V Lock power, 52VA power supply and ATS1640 small enclosure	Pilot C0807333

Signature of representative/manufacturer:

Leon Mintjens
 Technology Leader,
 UTC Fire & Security B.V.
 Kelvinstraat 7, 6003 DH

Place : Weert, The Netherlands
Date : 19 October 2010