

Declaration of Performance No. 360-4227-0499 REV 03

Declaration of Performance according to the Construction Products Regulation EU No. 305/2011

1. Unique identification code of the product type	Model(s): DT2063, FFD4122, DT2073 Brand(s): Aritech,G4S
2. Intended use/es	Fire alarm devices - Point detectors for fire detection and fire alarm systems for buildings EN54-5
3. Manufacturer	United Technologies Safety Systems. No. 80 Changjiang East Road, QETDZ, 066004 Qinhuangdao, Hebei, China
4. Authorized representative	UTC Fire & Security B.V. Kelvinstraat 7 NL-6003 DH Weert, The Netherlands (Tel: + 31 495 58 30 00, Fax: + 31 495 55 00 42)
5. System or systems of AVCP	System 1
6a. Harmonised standard/s: Notified body/ies:	EN54-5:2000 + A1:2002 1134 - ANPI
6b. European Assessment Document: European Technical Assessment: Technical Assessment Body: Notified body/ies:	Not applicable


7. Declared performances:

Fire alarm devices - Point detectors for fire detection and fire alarm systems for buildings EN54-5

Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	PASS --	EN54-5:2000 + A1:2002 --
Operational reliability	PASS	EN54-5:2000 + A1:2002
Tolerance to supply voltage	PASS	EN54-5:2000 + A1:2002
Durability of operational reliability and response delay; temperature resistance	PASS --	EN54-5:2000 + A1:2002 --
Durability of operational reliability, Vibration resistance	PASS	EN54-5:2000 + A1:2002
Durability of operational reliability, Humidity resistance	PASS	EN54-5:2000 + A1:2002
Durability of operational reliability, Electrical stability	PASS	EN54-5:2000 + A1:2002
Durability of operational reliability, Corrosion resistance	PASS	EN54-5:2000 + A1:2002

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:: Charl Du Plessis. Engineering Lead , EMEA Verge de Guadalupe 3, Esplugues de Llobregat 08950, Barcelona, Spain	
At: Esplugues de Llobregat	On: April 2, 2015

Regulation (EU) No. 305/2011 CPR Supplementary CE marking information



Identification of the Certification Body: 1134

Manufacturer:

United Technologies Safety Systems. No. 80 Changjiang East Road, QETDZ, 066004 Qinhuangdao, Hebei, China

Last two digits of year CE mark was first placed: 05

Declaration of Performance (DoP) Number: 360-4227-0499

EN54-5:2000 + A1:2002

Unique identification of product type: See the product label for the product documentation part number and revision.

Intended use: See DoP point 2.

Essential characteristics: See DoP point 7.

EN: Get this document in your language from: / BG: Вземете този документ на български език от / CZ: Získat tento dokument ve Vašem jazyce od: / DA: Få dette dokument på dit sprog fra: / NL: Krijg dit document in uw taal van: / ET: Dokumendi eestikeelse versiooni leiata siit: / ES: Obtenga este documento en su idioma de: / FI: Hanki tämä asiakirja kielelläsi: / FR: Obtenez ce document dans votre langue de: / DE: Sie erhalten das Dokument in Ihrer Sprache von: / EL: Μπορείτε να παραλάβετε το έγγραφο στη γλώσσα σας από: / HU: A dokumentum megvásárolható a kívánt nyelven: / IT: Ottieni questo documento nella tua lingua da: / LV: Iegūstiet šo dokumentu savā valodā no: / LT: Gauti šį dokumentą jūsų kalba iš: / PL: Pobierz ten dokument w swoim języku z: / PT: Obtenha este documento no seu idioma a partir: / RO: Puteti obtine acest document in limba dumneavoastra de la: / SK: Získať tento dokument vo Vašom jazyku od: / SL: Spravi ta dokument v vašem jeziku od: / SV: Få detta dokument på ditt språk från:

<http://www.utcssecurityproducts.eu/dop/>

DoP.Requests@fs.utc.com

© 2015 UTC Fire & Security. All rights reserved