



**Construction Products Regulation:
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

DECLARATION OF PERFORMANCE

No. E0092

1. Unique identification code of the product-type:

Model number and Description:

55000-600 XP95 Analogue Addressable Optical Smoke Detector
55000-620 XP95 Analogue Addressable Optical Smoke Detector
55000-660 Analogue Addressable Optical Smoke Detector
55000-620LIM Analogue Addressable Optical Smoke Detector

Approved Accessories:

45681-210 – XP95 Mounting Base
45681-209 – XP95/Discovery Standard Deep Mounting Base

Harmonised Product Type(s):

Smoke Detectors – Point Detectors

2. Intended use/es:

Fire detection and fire alarm systems installed in and around buildings

3. Manufacturer:

Apollo Fire Detectors Ltd,
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

4. Authorised representative:

Apollo Gesellschaft für Meldetechnologie mbH
Am Anger 31
33332 Gütersloh
Deutschland

5. System(s) of AVCP

System 1

6 Harmonised Standard(s)

EN 54-7:2018

Notified Body/ies:

DBI Certification A/S (Notified Body 2531)

A HALMA COMPANY



Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208

Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

7. Declared performance

| Essential characteristics | Clauses in EN 54-7:2018 | Regulatory classes | Performance |
|---|-------------------------|--------------------|--|
| Operational reliability: | | None | |
| Individual alarm indication | 4.2.1 | | The visual indicator(s) are visible from a distance of 6 m in an ambient light intensity up to 500 lx. |
| Connection of ancillary devices | 4.2.2 | | Open or short circuit failures of connection to ancillary device did not prevent the correct operation of the detector |
| Monitoring of detachable detectors | 4.2.3 | | A fault condition is signaled when the detector is removed from the mounting base. |
| Manufacturer's adjustments | 4.2.4 | | It is not possible to adjust the detector settings without the use of a special tool to access into the detector or use of a code to enabling entry into the panel programming software. |
| On site adjustment of response behavior | 4.2.5 | | The mode(s) of operation are adjustable from the Control and Indicating Equipment by use of a loop communication protocol. Access to enable mode changes is by software control of the protocol communication. |
| Protection against the ingress of foreign bodies | 4.2.6 | | The chamber is designed so that a sphere of diameter $(1,3 \pm 0,05)$ mm cannot pass into the sensor chamber. |
| Response to slowly developing fires | 4.2.7 | | The provision of "drift compensation" (e.g. to compensate for sensor drift due to the build-up of dirt in the detector), does not lead to a significant reduction in the detectors sensitivity to slowly developing fires. |
| Software controlled detectors (when provided) | 4.2.8 | | The software documentation and the software design complies with the requirements of EN 54-7:2018. |
| Nominal activation conditions/sensitivity: | | Threshold | |
| Repeatability | 4.3.1 | | Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\max}:m_{\min} \geq 0.05 \text{ dB m}^{-1}$ |
| Directional dependence | 4.3.2 | | Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\max}:m_{\min} \geq 0.05 \text{ dB m}^{-1}$ |

| | | | |
|---|---------|--|--|
| Reproducibility | 4.3.3 | | Ratio of response values $m_{\max}:\bar{m} \leq 1.33$ Ratio of the response values $\bar{m}: m_{\min} \leq 1.5$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$ |
| Response delay (response time): | | | |
| Air movement | 4.4.1 | | Ratio is > 0.0625 and < 1.60 and the point smoke detector did not emit a fault nor alarm signal during the test with aerosol-free air |
| Dazzling | 4.4.2 | | The specimen did not emit neither an alarm nor a fault signal and Ratio of response thresholds $m_{\max}:m_{\min} \leq 1.6$ |
| Tolerance to supply voltage: | | | |
| Variation in supply parameters | 4.5 | | Ratio of response values $m_{\max}:m_{\min} < 1.6$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$ |
| Performance parameters under fire conditions: | | | |
| Fire sensitivity | 4.6 | | Evaluated as meeting the requirements of TF2 to TF5 |
| Durability of nominal activation conditions/Sensitivity: | | | |
| temperature resistance | | | |
| Cold (operational) | 4.7.1.1 | | The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Dry heat (operational) | 4.7.1.2 | | The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Humidity resistance | | | |
| Damp heat, steady-state (operational) | 4.7.2.1 | | The specimen did not emit neither an alarm nor a fault signal and ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Damp heat, steady-state (endurance) | 4.7.2.2 | | No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Corrosion resistance | | | |
| Sulphur dioxide (SO ₂) corrosion (endurance) | 4.7.3 | | No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Vibration resistance | | | |
| Shock (operational) | 4.7.4.1 | | No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of |

| | | | |
|--|---------|--|---|
| | | | response values $m_{\max}:m_{\min} \leq 1.6$ |
| Impact (operational) | 4.7.4.2 | | No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Vibration, sinusoidal (operational) | 4.7.4.3 | | No fault signal given from the specimen during the conditioning and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Vibration, sinusoidal (endurance) | 4.7.4.4 | | No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |
| Electrical stability EMC immunity (operational) a) Electrostatic discharge (operational) b) Radiated electromagnetic fields (operational) c) Conducted disturbances(operational) d) Fast transient bursts (operational) e) Slow high energy voltage surge (operational) | 4.7.5 | | No alarm or fault signal given during the conditioning and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ |

8. Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:



Mr. David Robbins
Technical Director
Havant - 20.03.2025

(v9)