

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011
N°: DOP1328-CPR-0894

1. Unique identification code:

Advanced Conventional Fire Alarm Control Panel Fighter: FIGHTER MP, FIGHTER MPR, FIGHTER MPR+, FIGHTER XT

2. Type, Batch or serial number or any other element allowing identification of the construction product(s) as required pursuant to Article 11(4):

FIGHTER MP, FIGHTER MPR, FIGHTER MPR+, FIGHTER XT, FIGHTER KZRPS, FIGHTER KZPS (Keypad + 8 zones with extra PSU), FIGHTER ZRPS, FIGHTER ZPS, FIGHTER EKZ, FIGHTER EKR, FIGHTER EXZ, FIGHTER EXR, FIGHTER KSDA, FIGHTER FRTCP-IP, FIGHTER FR5-232, FIGHTER FPS5

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Fire Detection and fire alarm systems installed in buildings
Fixed firefighting systems – Components for gas extinguishing systems

4. Name, registered trade name or registered trade mark and contact address of the manufacturers required pursuant to Article 11(5):

PARADOXHELLAS S.A. - OIKONOMIDIS P. SECURITY SYSTEMS S.A.
3 Korinthou str., Metamorfosi 14451, Attiki, Greece

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in AnnexV:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

CERTIF – Associação para a Certificação, Rua José Afonso, 9-E, 2810-237 Almada

performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

1328 – CPR - 0894

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

NOT APPLICABLE - see item 7

9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the tables below:

EN54-2:1997 + AC:1999 + A1:2006
 EN54-4:1997+ AC:1999 + A1:2002+A2:2006
 EN 12094-1:2003

Essential Characteristics	Performance	Harmonised technical specification	
		EN54-2:1997 + AC: 1999 + A1:2006	EN54-4:1997+ AC: 1999 + A1:2002+A2:2006
Response delay (response time to fire)	Pass	Art.: 7.1, 7.7	-
Performance under fire conditions	Pass	Art.: 5, 7	-
Performance of power supply	Pass	-	Art.: 4, 5, 6
Operational reliability	Pass	Art.: 5, 6, 7, 8, 9, 12, 13, 14	Art.: 4, 5, 6, 7, 8, 9.3
Durability of operational reliability Temperature resistance	Pass	Art.: 15.4	Art.: 9.5, 9.6
Durability of operational reliability Vibration resistance	Pass	Art.: 15.6, 15.7, 15.15	Art.: 9.7, 9.8, 9.15
Durability of operational reliability Electrical stability	Pass	Art.: 15.8, 15.13	Art.: 9.9
Durability of operational reliability Humidity resistance	Pass	Art.: 15.8, 15.13	Art.: 9.6, 9.14

Essential Characteristics	Performance	Harmonised technical specification
		EN 12094-1:2003
Response delay (response time to fire)	Pass	Art.: 4.8
Performance under fire conditions	Pass	Art.: 4.3, 4.4, 4.5, 4.6
Operational reliability	Pass	Art.:4, 5, 6
Durability	Pass	Art.: 9

List of optional functions with requirements included in the c.i.e. EN 12094-1

Clause 4.17: Delay of extinguishing signal

Clause 4.18: Signal representing the flow of extinguishing agent

Clause 4.19.2: Monitoring of the status of components

Clause 4.20: Emergency hold device

Clause 4.23: Manual only mode


Clause 4.24: Triggering signals to equipment within system

Clause 4.26: Triggering of equipment outside the system

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

George Ioannou
Research and Development Manager



Athens, 28th June 2023