

Date Of Issue – 04 January 2016
EMC Directive 2004/108/EC
RoHS Directive 2011/65/EU



APOLLO FIRE DETECTORS LTD

DECLARATION OF CONFORMITY

This document is a declaration that the product family identified below conforms with the essential protection requirements that have been specified in the European Directive on Electromagnetic Compatibility 2004/108/EC. We declare the following products are also compliant with the Directive 2011/65/EU Restriction of the use of certain Hazardous Substances.

Product Family:
Orbis IS Heat/Optical/Multisensor
Detectors_Base

Product Description	Part Number
Class A1R Heat Detectors:	
Standard	ORB-HT-51145
Flashing LED	ORB-HT-51146
Class A2S Heat Detectors:	
Standard	ORB-HT-51147
Flashing LED	ORB-HT-51148
Class BR Heat Detectors	
Standard	ORB-HT-51149
Flashing LED	ORB-HT-51150
Class BS Heat Detectors:	
Standard	ORB-HT-51151
Flashing LED	ORB-HT-51152
Class CR Heat Detectors:	
Standard	ORB-HT-51153
Flashing LED	ORB-HT-51154
Class CS Heat Detectors:	
Standard	ORB-HT-51155
Flashing LED	ORB-HT-51156
Optical Smoke Detectors:	
Standard	ORB-OP-52027
Flashing LED	ORB-OP-52028
Multisensor Smoke Detectors:	
Standard	ORB-OH-53027
Flashing LED	ORB-OH-53028
Base:	
Adaptor*	ORB-BA-50008*
TimeSaver Base*	ORB-MB-50018*

These products are manufactured at the premises of Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, England PO9 1JR.

The part number printed on the product includes a three letter suffix that defines the product packing requirements, compliance with the essential requirements of the EMC and RoHS Directives are not affected.

We declare that the above products conform to the following standards:

- | | | |
|---|-----------------------|--|
| 1 | BS EN 61000-6-3: 2007 | Electromagnetic compatibility - Generic emission standard.
Residential, commercial and light industry |
| 2 | BS EN 50130-4:2011 | Alarm Systems Part 4 Electromagnetic compatibility
Product family standard : Immunity requirements for
components of fire, intruder and social alarm systems |

This declaration is made for and on behalf of Apollo Fire Detectors by the Managing Director, Mr. Steve Brown, who has been designated as the responsible person for the purpose of the Regulations.



SignatureMr. Steve Brown – Managing Director

***Please note these bases are RoHS compliant only**