



EC-Conformity Declaration

For	the	fol	lowing	equipment	
-----	-----	-----	--------	-----------	--

Product Name: Switching Power Supplies

Model Designation: NEX-50-Y (X=S,D,T) (Y=5,12,15,24,48,A,B,C,D); SCP-50-z (z=12,24)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

Low Voltage Directive (2006/95/EC):

IEC60950-1:2005 CB certificate No : JPTUV-031818

Electromagnetic Compatibility Directive (2004/108/EC):

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN55022:2006+A1:2007 EN55011:2007+A2:2007 (Group 1) Class B Class B

Harmonic current EN61000-3-2:2006

Voltage flicker EN61000-3-3: 2008

EMS (Electro-Magnetic Susceptibility)

EN55024:1998+A1:2001+A2:2003 EN61204-3:2000 EN61000-6-1:2007

EN61000-6-3:2007

Level 3 ESD air EN61000-4-2:1995+A1:1998+A2:2001 8KV EN61000-4-2:1995+A1:1998+A2:2001 Level 2 4KV ESD contact RF field susceptibility EN61000-4-3:2006 Level 2 3V/m 1KV/5KHz **EFT** bursts EN61000-4-4:2004 Level 2 1KV/Line-Line 2KV/Line-Earth Level 3 Surge susceptibility EN61000-4-5:2006 3V Conducted susceptibility EN61000-4-6:2007 Level 2 Level 2 Magnetic field immunity EN61000-4-8:1993+A1:2001 3A/m EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods Voltage dip, interruption Keyed carrier immunity ENV50204:1995 Level 2 3V/m 900MHz

Note:

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies".(as available on http://www.meanwell.com)".

This Declaration is effective from serial number HB0xxxxxxx

Person responsible for marking this declaration:

Mean Well Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan (R.O.C.)

(Manufacturer Address)

Johnny Huang/Senior Verification Engineer:

(Name / Position)

Ted Cheng/Product Manager:

(Name / Position)

(Signature)

Taiwan

Feb. 12, 2010

(Signature)

(Place)

(Date)